

## **NOTE**

**The Little Blue Run Disposal Facility Notice of Groundwater Protection Standard Exceedance dated December 14, 2018, did not indicate which Appendix IV constituents were detected at statistically significant levels above groundwater protection standards. A revised notice, dated April 5, 2019, identifies the constituents.**

**The revised notice, dated April 5, 2019, immediately follows this page. The last page is the original notice.**

**COAL COMBUSTION RESIDUALS RULE  
ASSESSMENT MONITORING**

**REVISED NOTICE  
OF  
GROUNDWATER PROTECTION STANDARD EXCEEDANCE**

**FirstEnergy Generation, LLC  
Little Blue Run Disposal Facility  
Greene Township, Beaver County, PA / Grant District, Hancock County, WV  
April 5, 2019  
(Revision to December 14, 2018 Notice)**

As required by 40 CFR § 257.106(h)(6), FirstEnergy Generation, LLC provides this notification that two Appendix IV constituents including arsenic and lithium have been detected in the Federal CCR Rule groundwater monitoring network at a statistically significant level above groundwater protection standards during assessment monitoring activities at the Little Blue Run Disposal Facility.



---

Edward J. Newbaker, P.G.  
Professional Geologist

PG002917G

License No.

PA

License State

4/5/2019

Date

**COAL COMBUSTION RESIDUALS RULE  
ASSESSMENT MONITORING  
NOTICE OF GROUNDWATER PROTECTION STANDARD EXCEEDANCE**

**FirstEnergy Generation, LLC  
Little Blue Run Disposal Facility  
Green Township, Beaver County, PA / Grant District, Hancock County, WV  
December 14, 2018**

As required by § 257.106(h)(6), FirstEnergy Generation, LLC provides this notification that two constituents have been detected at statistically significant levels above groundwater protection standards during assessment monitoring activities at the Little Blue Run Disposal Facility.



---

Edward J. Newbaker, P.G.  
Professional Geologist

---

PG002917G  
License No.

---

PA  
License State

---

12/14/2018  
Date