

NOTE

The Pleasants Power Station McElroy's Run Landfill and Impoundment Notice of Groundwater Protection Standard Exceedance dated February 13, 2019, did not indicate which Appendix IV constituents were detected at statistically significant levels above groundwater protection standards. A revised notice, dated April 5, 2019, identifies the constituents.

The revised notice, dated April 5, 2019, immediately follows this page. The last page is the original notice.

**COAL COMBUSTION RESIDUALS RULE
ASSESSMENT MONITORING**

**REVISED NOTICE
OF
GROUNDWATER PROTECTION STANDARD EXCEEDANCE**

**FirstEnergy
Pleasants Power Station
McElroy's Run Landfill and Impoundment
Pleasants County, WV
April 5, 2019
(Revision to February 13, 2019 Notice)**

As required by 40 CFR § 257.106(h)(6), FirstEnergy provides this notification that five Appendix IV constituents including arsenic, barium, fluoride, lithium, and radium have been detected in the Federal CCR Rule groundwater monitoring network at a statistically significant level above groundwater protection standards during assessment monitoring activities at the McElroy's Run Landfill and Impoundment.



Edward J. Newbaker, P.G.
Professional Geologist

PG002917G
License No.


PA
License State

4/5/2019
Date

**COAL COMBUSTION RESIDUALS RULE
ASSESSMENT MONITORING
NOTICE OF GROUNDWATER PROTECTION STANDARD EXCEEDANCE**

**FirstEnergy
Pleasants Power Station
McElroy's Run Landfill and Impoundment
Pleasants County, WV
February 13, 2019**

As required by § 257.106(h)(6), FirstEnergy provides this notification that five Appendix IV constituents have been detected at a statistically significant levels above groundwater protection standards during assessment monitoring activities at the McElroy's Run Landfill and Impoundment.



Edward J. Newbaker, P.G.
Professional Geologist

PG002917G

License No.

PA

License State

2/13/2019

Date