

McElroy's Run Impoundment History of Construction

Allegheny Energy Supply Company, LLC
A FirstEnergy Company
Pleasants Power Station
Pleasants County, West Virginia

October 2016

Prepared for:
Allegheny Energy Supply Company, LLC
A FirstEnergy Company
800 Cabin Hill Drive
Greensburg, Pennsylvania 15601

Prepared by:
GAI Consultants, Inc.
Murrysville Office
4200 Triangle Lane
Export, Pennsylvania 15632-1358

Report Authors:



Trent I. Muraoka, P.E.
Project Engineer



Arica L. DiTullio, P.E.
Engineering Manager



Kent C. Cockley, P.E.
Engineering Director/Senior Associate

Table of Contents

1.0	Purpose	1
2.0	Introduction	1
3.0	Construction Summary of Impoundment and Embankment	1
Table 1	Physical and Engineering Properties of Foundation and Abutment Materials	
Figure 1	USGS 7.5-Minute Mapping	
Appendix A	McElroy's Run Disposal Site Drawings: APSC 506-103 Detailed Plan of Compacted Ash Embankment and Initial Earth Embankment APSC 506-104 Transverse and Longitudinal Sections of Embankment 101-6514-196 As-Built Construction Sequence	
Appendix B	Stage Storage Verification Calculation	
Appendix C	Design Calculations for Siphon Line	

© 2016 GAI CONSULTANTS

1.0 Purpose

This Report, the Construction History of Pleasants Power Station McElroy's Run Impoundment, covers the following criteria listed in the Code of Federal Regulations (CFR) Coal Combustion Residuals (CCR) Rule 40 CFR 257.73(c)(1), to the extent feasible:

- ▶ name and size of the watershed within which the CCR unit is located;
- ▶ location map;
- ▶ material physical and engineering properties description for foundation and abutment and CCR unit;
- ▶ site preparation and construction methods for each zone;
- ▶ detailed drawings;
- ▶ description of the existing instrumentation;
- ▶ area capacity curves;
- ▶ spillway and diversion features description, capacities, and calculations;
- ▶ construction specifications and provisions for surveillance, maintenance, and repair; and
- ▶ any record or knowledge of structural instability.

2.0 Introduction

The Pleasants Power Station (Station) is a coal-fired electric generating station located near the community of Willow Island in Pleasants County, West Virginia (WV). The Station consists of two generating units, which are capable of producing 1,300 megawatts of electricity. CCRs generated at the Station are placed in the McElroy's Run CCR Surface Impoundment (Impoundment), which is located approximately one-half-mile east-southeast of the Station. The Impoundment location is shown on the United States Geological Survey (USGS) 7.5-Minute Topographic Quadrangle Map provided as Figure 1. According to the USGS, the Impoundment is located in the Little Muskingum-Middle Island Watershed (USGS Hydrologic Unit Code 05030201) and has an area of 1,800 square miles. The WV Department of Environmental Protection identifies the watershed as the Middle Ohio North.

The purpose of the Impoundment is to receive flue gas desulfurization (FGD) scrubber by-product generated at the Station, effluent from the recirculation system from Sedimentation Ponds No. 1 and 2 of the adjacent landfill and their underdrains, and waste materials collected primarily because of general house-cleaning maintenance and/or repair at the Pleasants Power Station. The National Pollutant Discharge Elimination System (NPDES) Water Pollution Control Permit (WV 0079171) authorizes discharge to the Ohio River in accordance with effluent limitations, monitoring requirements, and other conditions set forth in the permit. The McElroy's Run Dam Certificate of Approval was signed on February 7, 1978 (ID No. 07302).

3.0 Construction Summary of Impoundment and Embankment

The Impoundment embankment construction took place from 1979 through 1992, occurring over stages. The approximate dates of construction for each successive stage are depicted on Drawing 101-6514-196. The crest of the dam is at elevation (El.) 900 feet, with El. 887 feet as the permitted final level of CCR. The Impoundment area is approximately 253 acres. A clay blanket on the upstream slope and clay-filled cutoff trench along the upstream toe were constructed to serve as a low permeability barrier. The downstream end was constructed with compacted fly ash. A landfill facility was constructed on the downstream face of the embankment, which is now grass-covered. A blanket drain, consisting of sand or bottom ash, was installed between natural soil and embankment fill downstream of the cut-off keyway.

McElroy's Dam was constructed on native soils with a clay soil cut-off keyway installed through the soft broken claystone layer to the top of bedrock, an interbedded siltstone, sandstone, and claystone formation. Foundation soils in the valley of the McElroy's Dam embankment consist of alluvial and residual soils. These soils are clayey and cohesive, and thus are not susceptible to liquefaction. However, pockets of sandy soil exist within the site soils; Investigations performed by GAI Consultants, Inc. (GAI) indicate that the soil layer over the interbedded bedrock formation is thicker towards the abutments than at the midpoint of the dam. A blanket drain, consisting of sand or bottom ash, was installed between natural soil and embankment fill downstream of the cut-off keyway.

The physical and engineering properties of the foundation, abutment, and embankment materials of which the CCR unit is constructed are listed below.

Table 1

Physical and Engineering Properties of Foundation and Abutment Materials

Soil Description	Soil Unit Weights	Long Term Conditions	
		Effective Stress Parameters	
	γ_{moist} (pcf)	Cohesion, C' (psf)	Friction, ϕ' (degrees)
Compacted Silty Clay	132.9	228	26.8
In-Situ Silty Clay to Clayey Silt and Rock Fragments	127.8	49	24.8
Soft Broken Claystone	135.0	1238	32
Interbedded Siltstone, Sandstone, and Claystone	-	-	-
Compacted Fly Ash	113.1	0	29.7
Bottom Ash Filter Blanket	110.0	0	35

Drawings in Appendix A show the plan view and the typical transverse and longitudinal section of the embankment, as well as the width of the embankment.

Five survey-monitoring points were installed in 1997 in the upstream slope of the embankment slightly below the crest near El. 900 feet. The monitoring points are used to measure horizontal movement and settlement of the embankment, and to determine if there is movement of the embankment over time. Piezometers are installed in the embankment to monitor the water level in the embankment.

Two perforated cross-valley foundation underdrain pipes were installed in a trench below the drainage blanket of the downstream slope of the Impoundment embankment as a part of construction. The drains were installed across the flat bottom of the valley about 100 feet upstream of the toe of the embankment. The two pipes meet near the center of the valley where they turn and extend to the current toe of the ash disposal landfill. The pipes collect any seepage that enters the drainage blanket, either through the embankment or from the subgrade below the Impoundment embankment. This water is transmitted to Sedimentation Pond No. 1.

The dam was constructed with two concrete discharge towers serving as the principal spillway. Current water levels in the Impoundment has made the use of Decant Tower 1 impractical. Decant Tower 1 was sealed such that no water enters the Tower. Decant Tower 2 is outfitted with an operational sluice gate at El. 885 feet, and a 24-inch square (former sluice gate) opening at El. 890 feet. Discharge from this structure is directed under the dam via a 36-inch-diameter concrete pipe that is approximately 3,600 feet long. Flow from the concrete pipe is conveyed to the principal spillway, with discharge directed to a channel that leads to McElroy's Run Creek. However, operational practices currently implemented at the Impoundment prevent discharge from principal spillway from occurring.

Currently, the primary discharge from the Impoundment is by use of a siphon. The siphon line is a 12-inch-diameter, high-density polyethylene pipe that can convey water to the Station for reuse, or discharge to the Ohio River. The maximum discharge of the siphon is 3,800 gallons per minute (GPM), but typically discharges at 1,800 GPM to maintain an adequate operating water elevation. The siphon flow can either be diverted to the plant for makeup water or discharged through a 14-inch pipeline to an NPDES-permitted Outfall. Design calculations for the siphon line area are attached as Attachment C. The siphon line is the primary operating mechanism for withdrawing water from the Impoundment to maintain the operational water elevation behind the dam.

An emergency spillway located near the west abutment serves the Impoundment. The spillway is concrete-lined and has an approach lined with stone rip-rap. The spillway outlet is protected with rip-rap. The spillway bottom width ranges from 20.25 to 20.5 feet with side slopes at 3H:1V or 6H:1V and with a crest El. of 893.5 feet. The spillway has a minimum depth of 6.5 feet and can convey an approximate maximum flow rate of 9,000 cubic feet per second (cfs), which is greater than the probable maximum flood (PMF) design storm of 100 cfs through the emergency spillway. A Stage-Storage curve was developed by GAI as part of a recent Capacity Estimate of the Impoundment (Attachment B). The Stage-Storage curve of the reservoir was based on 2015 Aerial Mapping.

FGD scrubber by-product is pumped to the Impoundment through two eight-inch-diameter slurry lines to a valve station near the west end of the Impoundment dam. The slurry can be discharged into the Impoundment from the valve station or directed into a mobile pipeline boom, for discharge at various locations in the Impoundment.

The Monitoring and Emergency Action Plan and Operations Plan, completed by FirstEnergy Corporation, revised October 2015, outlines the requirements for monitoring, inspection, and maintenance of the Impoundment.

Based on the information reviewed, there have been no identified safety issues for the McElroy's Embankment in the last 10 years.


FIGURE



U.S. DEPARTMENT OF THE INTERIOR
U.S. GEOLOGICAL SURVEY





WILLOW ISLAND QUADRANGLE
WEST VIRGINIA-OHIO
7.5-MINUTE SERIES



Produced by the United States Geological Survey
North American Datum of 1983 (NAD83)
World Geodetic System of 1984 (WGS84) Projection and
1 000-meter grid: Universal Transverse Mercator, Zone 17S
10 000-foot ticks: West Virginia Coordinate System of 1983
(north zone), Ohio Coordinate System of 1983 (south zone)

This map is not a legal document. Boundaries may be
generalized for this map scale. Private lands within government
reservations may not be shown. Obtain permission before
entering private lands.

Imagery.....NAIP, August 2011
Roads.....HERE, ©2013
Roads within US Forest Service Lands.....FS Topo Data
with limited Forest Service updates, 2013
Names.....GNIS, 2013
Hydrography.....National Hydrography Dataset, 2011
Contours.....National Elevation Dataset, 2004
Boundaries.....Multiple sources; see metadata file 1972-2013
Public Land Survey System.....BLM, 2013




CONTOUR INTERVAL 20 FEET
NORTH AMERICAN VERTICAL DATUM OF 1988

This map was produced to conform with the
National Geospatial Program US Topo Product Standard, 2011.
A metadata file associated with this product is draft version 0.6.16



1	2	3
4	5	6
7	8	9

1 Marietta
2 Belmont
3 Raven Rock
4 Valley Mills
5 Schultz
6 Kanawha
7 Petroleum
8 Cairo




Check with local Forest Service unit
for current travel conditions and restrictions.

WILLOW ISLAND, WV-OH
2014



APPENDIX A

McElroy's Run Disposal Site Drawings



REFERENCE
ALLEGHENY POWER SERVICE CORPORATION
DWG. 500-242 TITLED: TOPOGRAPHIC MAP
OF WILLOW ISLAND DATED: 7-23-73,
SCALE: 1" = 200'

LEGEND:


▲ PERMANENT HORIZONTAL CONTROL
MONUMENT LOCATED AND PLACED
IN FIELD BY U. E. & C., 1977.

NOTES:

1. FOR STRUCTURAL DETAILS OF DECANT TOWERS,
SEE DWGS. 101-6514-109 AND 101-6514-110.
2. FOR STRUCTURAL DETAILS OF CLEARWELL,
SEE DWG. 101-6514-112.

- PHASE I CONSTRUCTION WITH AS-BUILT DETAILS
- ▨ LIMIT OF PHASE I PLACEMENT OF SAND FILTER
DRAINAGE BLANKET ALL REQUIRED WORK IN AREA
SHOWN NOT COMPLETED DURING PHASE I.

5. FOR LIMITS OF PHASE I CLEARING,
SEE DRAWING 101-6514-101.
6. FOR REVISED SPILLWAY PLAN SEE DRAWINGS
101-6514-204 TO 101-6514-211.



UPSTREAM TOE OF
COMPACTED EARTH
EMBANKMENT

D'APPOLONIA
CONSULTING ENGINEERS, INC.

ISSUE	NO.	DATE	BY	CHKD	APP	APP	ISSUED FOR
2-2-93	GY		TRE	TDD			REVISED SPILLWAY
3-14-75	RDB						AS-BUILT DETAILS
3-07-78	MEL						CONSTRUCTION
12-27-77	G.J.G.						PHASE I CONSTRUCTION LIMITS
12-27-77	D.W.						

AS SHOWN

ENGINEER
STATE REG.
No.

PLEASANTS POWER STATION-UNITS NO. 1 & NO. 2

MONONGAHELA POWER COMPANY THE POTOMAC EDISON COMPANY WEST PENN POWER COMPANY

SLUDGE STABILIZATION FACILITY

McELROY'S RUN DISPOSAL SITE




DETAILED PLAN OF COMPACTED ASH EMBANKMENT AND INITIAL EARTH EMBANKMENT

APSC 506-103

DRAWING NUMBER 101-6514-103

REVISION 4

Dravo Lime COMPANY



LEGEND

PHASE I CONSTRUCTION WITH AS-BUILT DETAILS

- NOTE**
1. THE DESIGN STRIPPING DEPTH UNDER THE EMBANKMENT IS 2 FEET. ACTUAL DEPTH OF UNSUITABLE MATERIAL TO BE REMOVED WILL BE AS DIRECTED BY THE ENGINEER.
 2. THE AREA UNDER THE FIRST-YEAR COMPACTED ASH EMBANKMENT IS TO BE CLEARED, GRUBBED, AND STRIPPED DURING THE PHASE I CONSTRUCTION.
 3. A COMPACTED EARTH DIKE SHALL BE CONSTRUCTED TO ELEVATION 810 ALONG THE UPSTREAM EDGE OF THE EARTH SEAL DURING THE BEGINNING OF THE 1982 CONSTRUCTION SEASON TO PROVIDE THE DESIGN STORM IMPOUNDMENT CAPACITY. SIDE SLOPES OF THIS STRUCTURE SHALL BE 3:1:1 UPSTREAM AND 2.5:1 DOWNSTREAM. CONSTRUCTION MATERIAL SHALL BE THE SAME AS THAT USED FOR THE COMPACTED EARTH SEAL.
 4. FOR AS-BUILT CONSTRUCTION PROGRESS BETWEEN 1979 AND 1985 SEE DRAWING 101-6514-196.

D'APPOLONIA
CONSULTING ENGINEERS, INC.

PROJ. NO. 76-204 DWG. NO. M 27

ISSUE NO.	DATE	DWN	CHKD	APP	APP	ISSUED FOR
1	2-5-91	NER	TRE			CONSTRUCTION SCHEDULE REVISION
2	2-10-91	NER	TRE	TD		CONSTRUCTION SCHEDULE REVISION
3	6-18-91	GY	TRE	TD		CONSTRUCTION SCHEDULE REVISION
4	7-6-91	RON	W	TD		CONSTRUCTION SCHEDULE REVISION
5	2-22-91	ACS	W	TD		AS-BUILT DETAILS
6	3-30-91	W	W	TD		CONSTRUCTION
7	12-27-91	GJG	W	TD		PHASE I CONSTRUCTION
8	12-27-91	W	W	TD		PHASE I CONSTRUCTION

PLEASANTS POWER STATION-UNITS NO. 1 & NO. 2


MONONGAHELA POWER COMPANY THE POTOMAC EDISON COMPANY WEST PENN POWER COMPANY

SLUDGE STABILIZATION FACILITY
McELROY'S RUN DISPOSAL SITE
TRANSVERSE AND LONGITUDINAL
SECTIONS OF EMBANKMENT

Dravo
Lime
COMPANY

APSC 506-104
DRAWING NUMBER
101-6514-104

REVISION
7



CONTROL MONUMENTS:

1. COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM, NORTH ZONE NAD 83.

PROVIDED BY FIRSTENERGY			
MON.	NORTHING	EASTING	ELEV.
5"	320472.10	1467897.76	955.53
15"	320116.42	1467280.08	900.01
17"	319843.37	1466716.28	899.24

* HELD FOR SURVEY CONTROL

REFERENCE SURVEY DRAWINGS

C79508574 - HYDROGRAPHIC SURVEY JUNE 2015
C79508574 - HYDROGRAPHIC SURVEY NOV. 2013
C79506538 - BOTTOM CONTOURS OCT. 2009
C79503257 - CONTOUR PLAN JUNE 2004
C79500382 - CONTOUR PLAN NOV. 1999
C7950079 - CONTOUR PLAN
C794006 - CONTOUR PLAN
C794005 - CONTOUR PLAN
C794004 - CONTOUR PLAN

LEGEND:

- EDGE OF WATER
- CONTOURS
- EXISTING FE SURVEY CONTROL MONUMENT
- TREE LINE

NOTES:

- COORDINATES AND ELEVATIONS ESTABLISHED BY GPS METHODS. HORIZONTAL DATUM IS NAD 83 SPC WV NORTH ZONE. VERTICAL DATUM IS NAVD OF 1988.
- HYDROGRAPHIC SURVEY OF BOTTOM OF RESERVOIR TOPOGRAPHY WAS PERFORMED USING GPS VRS SURVEY METHODS COMBINED WITH AN OMMEX SONARITE SINGLE BEAM ECHO SOUNDER.
- BOTTOM OF RESERVOIR TOPOGRAPHY IS BASED ON SURVEY PERFORMED JUNE 1-5, 2015.
- TOPOGRAPHY BEYOND LIMIT OF HYDROGRAPHIC SURVEY: AERIAL MAPPING PROVIDED BY FIRSTENERGY CORP. FROM KUCERA INTERNATIONAL, INC. PHOTOGRAPHY ON APRIL 11, 2015.
- THE RESERVOIR VOLUME IS BASED ON ELEVATION 887.0 FEET. THE ELEVATION CONTOUR WAS GENERATED FROM THE AERIAL MAPPING REFERENCED IN NOTE 4.



FUNCTIONAL LOCATION NO. _____

Last: Not editor version: 1.1.2.0

REVISION					REVISION					REVISION					REVISION					REVISION				
NO.	DATE	BY	CHKD	APPD	NO.	DATE	BY	CHKD	APPD	NO.	DATE	BY	CHKD	APPD	NO.	DATE	BY	CHKD	APPD	NO.	DATE	BY	CHKD	APPD


PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER	PROJECT NUMBER
----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------

DWG NO. GAI # C120987.00	REFERENCE DRAWINGS 2013 HYDROGRAPHIC SURVEY SEE REFERENCE DRAWING LIST ON THIS SHEET	ENGINEERING DR JAF CHKD DJP APPD GER SCALE AS NOTED	DATE 11/28/2013 11/28/2013 11/28/2013	HYDROGRAPHIC SURVEY McELROY'S RUN IMPOUNDMENT PLEASANTS COUNTY, WEST VIRGINIA FACILITY PLEASANTS UNIT COMMON FirstEnergy GENERATION, LLC DWG. NO. C7950XXXX REV. 2
-----------------------------	--------------------------------------------------------------------------------------------	-----------------------------------------------------------------	------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

APPENDIX B

Stage Storage Verification Calculation

Stage Storage



APPENDIX C

Design Calculations for Siphon Line

APPENDIX B

CALCULATIONS FOR THE
MINIMUM SIPHON HYDRAULIC CAPACITY

APPENDIX B

Table of Contents

Section 1	Precipitation Data and Analyses
Section 2	Evaporation Data and Analyses
Section 3	Comparative Plot of Precipitation and Evaporation Data
Section 4	Reservoir Elevation versus Storage Table
Section 5	Runoff Analyses
Section 6	Water Balance Flow Chart
Section 7	Reservoir Management Water Balance Analyses

I. SUMMARY OF PRECIPITATION DATA
Parkersburg WSO CI

TABLE 1 SUMMARY OF PRECIPITATION DATA - PARKERSBURG WSO														
Year		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
1971	rainfall	2.43	3.62	1.31	1.22	3.82	3.09	5.20	4.04	4.59	1.38	2.26	1.73	34.69
	departure	-0.91	0.79	-2.22	-2.03	0.12	-1.18	1.09	0.26	1.88	-0.67	-0.10	-1.11	-4.08
	average	3.34	2.83	3.53	3.25	3.70	4.27	4.11	3.78	2.71	2.05	2.36	2.84	38.77
1972	rainfall	2.67	3.02	3.07	6.18	2.07	5.43	1.51	7.97	4.97	1.70	3.93	4.85	47.37
	departure	-0.67	0.19	-0.46	2.93	-1.63	1.16	-2.60	4.19	2.26	-0.35	1.57	2.01	8.60
	average	3.34	2.83	3.53	3.25	3.70	4.27	4.11	3.78	2.71	2.05	2.36	2.84	38.77
1973	rainfall	2.22	1.91	2.68	5.71	3.35	2.02	6.53	2.10	3.32	3.73	3.46	1.86	38.89
	departure	-1.12	-0.92	-0.85	2.46	-0.35	-2.25	2.42	-1.68	0.61	1.68	1.10	-0.98	0.12
	average	3.34	2.83	3.53	3.25	3.70	4.27	4.11	3.78	2.71	2.05	2.36	2.84	38.77
1974	rainfall	4.77	1.62	2.88	2.48	6.12	5.18	2.45	5.89	3.20	1.09	2.46	3.26	41.40
	departure	1.69	-1.15	-0.87	-0.97	2.56	1.17	-1.83	2.55	0.40	-1.02	-0.06	0.49	
	average	3.08	2.77	3.75	3.45	3.56	4.01	4.28	3.34	2.80	2.11	2.52	2.77	
1975	rainfall	2.77	3.77	4.63	4.39	5.01	2.33	2.35	4.42	5.42	4.12	2.59	3.71	45.51
	departure	-0.31	1.00	0.88	0.94	1.45	-1.68	-1.93	1.08	2.62	2.01	0.07	0.94	7.07
	average	3.08	2.77	3.75	3.45	3.56	4.01	4.28	3.34	2.80	2.11	2.52	2.77	38.44
1976	rainfall	2.54	2.17	2.81	0.96	2.77	4.52	6.50	1.94	2.81	5.02	0.34	1.39	33.77
	departure	-0.54	-0.60	-0.94	-2.49	-0.79	0.51	2.22	-1.40	0.01	2.91	-2.18	-1.38	-4.67
	average	3.08	2.77	3.75	3.45	3.56	4.01	4.28	3.34	2.80	2.11	2.52	2.77	38.44
1977	rainfall													
	departure													
	average	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1978	rainfall													
	departure													
	average	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1979	rainfall													
	departure													
	average	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1980	rainfall													
	departure													
	average	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1981	rainfall													
	departure													
	average	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1982	rainfall													
	departure													
	average	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

I. SUMMARY OF PRECIPITATION DATA

[illegible]

I. SUMMARY OF PRECIPITATION DATA
Parkersburg WSO CI

1994	rainfall	5.11	3.51	5.98	5.54	3.71	3.15	7.79	4.60	3.38	0.66	2.40	2.75	48.58
	departure	0.00	1.03	2.43	2.22	-0.04	-0.28	3.58	0.88	0.31	-2.02	-0.52	-0.17	0.00
	average	5.11	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.92	48.58
1995	rainfall	4.38	2.29	1.57	2.21	8.99	4.84	1.06	4.71	2.42	4.60	2.69	2.50	42.26
	departure	0.00	-0.19	-1.98	-1.11	5.24	1.41	-3.15	0.99	-0.65	1.92	-0.23	0.00	0.00
	average	4.38	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.50	42.26
1996	rainfall	5.04	3.34	4.30	3.26	9.06	4.68	7.43	2.53	5.79	1.49	3.26	3.29	53.47
	departure	2.73	0.86	0.75	-0.06	5.31	1.25	3.22	-1.19	2.72	-1.19	0.34	0.37	15.11
	average	2.31	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.92	38.36
1997	rainfall	2.23	1.48	9.42	2.16	3.80	6.82	5.29	5.70	1.84	1.19	1.91	2.10	43.94
	departure	-0.08	-1.00	5.87	-1.16	0.05	3.39	1.08	1.98	-1.23	-1.49	-1.01	0.00	0.00
	average	2.31	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.10	43.94
1998	rainfall	3.63	4.71	3.55	4.91	3.85	13.20	2.56	0.67	2.31	2.02	1.65	2.23	45.29
	departure	1.32	2.23	0.00	1.59	0.10	9.77	-1.65	-3.05	-0.76	-0.66	-1.27	-0.69	6.93
	average	2.31	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.92	38.36
1999	rainfall	5.79	2.67	3.23	2.79	3.08	1.77	1.86	4.13	1.12	3.36	4.40	3.37	37.57
	departure	3.48	0.19	-0.32	-0.53	-0.67	-1.66	-2.35	0.41	-1.95	0.68	1.48	0.45	-0.79
	average	2.31	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.92	38.36

Statistical analyses can be performed based on the Average Annual Precipitation, or on the individual Average Monthly Precipitation values.
Analysis based on the Average Annual Precipitation have a more direct correlation to exceedance probability, which is typically based on an annual basis.
Analysis based on the individual Average Monthly Precipitation values provide some insight in the variability of precipitation that may occur.

II. STATISTICAL ASSESSMENT, MONTHLY BASIS


A Statistical Analysis is performed on the monthly precipitation for comparative purposes only.
The standard deviation is computed for the Monthly Precipitation values, and monthly precipitation values equal to the Average Monthly Ppt plus a multiple of the standard deviation are computed.
The results will be compared to results on statistical analyses performed on annual precipitation.

TABLE 2 SUMMARY OF MONTHLY PRECIPITATION COMPARATIVE ANALYSES													
Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Average Monthly Values	2.31	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.92	38.36
Standard Deviation of Monthly Values	1.21	1.38	1.81	1.58	2.27	2.59	2.41	1.93	1.56	1.43	1.44	1.65	
Average Monthly Precipitation + One Standard Deviation	3.52	3.86	5.36	4.90	6.02	6.02	6.62	5.65	4.63	4.11	4.36	4.57	59.63
Maximum Monthly Values	5.79	7.26	9.42	6.18	9.06	13.20	8.46	8.06	6.94	5.02	7.39	8.21	94.99
The Maximum Annual Rainfall Recorded is													55.56

III. STATISTICAL ASSESSMENT, ANNUAL BASIS

Year	Precipitation (inches)	Data Counter
1971	34.69	1
1972	47.37	1
1973	38.89	1
1974	41.4	1
1975	45.51	1
1976	33.77	1
1977	36.03	1
1978	43.82	1
1979	43.92	1
1980	42.34	1
1981	35.65	1
1982	38.14	1
1983	50.57	1
1984	36.16	1
1985	41.53	1
1986	43.15	1
1987	25.52	1
1988	31.13	1
1989	54.52	1
1990	55.56	1
1991	48.02	1
1992	37.73	1
1993	36.05	1
1994	48.58	1
1995	42.26	1
1996	53.47	1
1997	43.94	1
1998	45.29	1
1999	37.57	1

B&V
study
data



total precipitation, inches 1212.58

number of years with data 29

Average Annual Precipitation 41.81 inches Parkersburg WSO CI

supplemented with Black & Veatch data
Additional data is available for the Wood County Airport, as taken directly from "Scrubber Solids Pond Hydrologic Study Report",
by Black & Veatch, Project 26287, February 1995. (noted in above table)

Average Annual Precipitation 41.06 inches Wood County Airport

Use Average Annual Precipitation = 41.81 inches		
Variance	48.54	
Standard Deviation	6.97	computed as square root of variance spreadsheet built-in formula

Sum of Average Monthly Ppt values	38.36	inches
Average Annual Precipitation	41.81	inches

Note the relatively large difference between these two values

Average Annual Precipitation	41.81	inches
Standard Deviation of Annual Precipitation	6.97	inches
Average Annual Ppt + 1 Standard Deviation	48.78	inches
Average Annual Ppt + 1-1/2 Standard Deviation	52.26	inches
Average Annual Ppt + 2 Standard Deviation	55.75	inches

Exceedance Probability Analysis

ASSUME Precipitation can be approximated as a Normal Distribution

Set $N_z(Z) = \text{Normal Function } [(x - \text{mean}) / (\text{standard deviation})]$

The probability that the precipitation in a given year will be equalled or exceeded is expressed as $1 - N_z(Z)$

Given		Average Annual Precipitation Standard Deviation		41.8131 6.97	inches inches	
parameter "x"	multiple of std dev	x	Z	Nz(Z)	1 - Nz(Z)	Probability of Exceedance
mean	0	41.81	0.00	0.5	0.5	50%
mean + std dev	1	48.78	1.00	0.8413	0.1587	16%
mean + 1.25 std dev	1.25	50.52	1.25	0.8997	0.1003	10%
mean + 1.5 std dev	1.5	52.26	1.50	0.9332	0.0668	7%
mean + 2 std dev	2	55.75	2.00	0.9773	0.0227	2%

obtain value from "Standard Normal Distribution Function" table, in Introduction to Probability Theory and Statistical Inference, H.J.Larson, (2nd ed), . Wiley & Sons, 1974

TABLE 3 ANNUAL PRECIPITATION ANALYSES

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Average Monthly Values	2.31	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.92	38.36
Percentage of Average Monthly Ppt to Sum of Average Monthly Values	6.02%	6.47%	9.25%	8.65%	9.78%	8.94%	10.97%	9.70%	8.00%	6.99%	7.61%	7.61%	
Monthly Ppt Distribution of Average Annual Ppt	2.52	2.70	3.87	3.62	4.09	3.74	4.59	4.05	3.35	2.92	3.18	3.18	41.81
Monthly Ppt Distribution of Average Annual Ppt plus 1 Standard Deviation	2.94	3.15	4.51	4.22	4.77	4.36	5.35	4.73	3.90	3.41	3.71	3.71	48.78
Monthly Ppt Distribution of Average Annual Ppt plus 1-1/2 Standard Deviation	3.15	3.38	4.84	4.52	5.11	4.67	5.74	5.07	4.18	3.65	3.98	3.98	52.26
Monthly Ppt Distribution of Average Annual Ppt plus 2 Standard Deviation	3.36	3.60	5.16	4.82	5.45	4.98	6.12	5.41	4.46	3.89	4.24	4.24	55.75

IV. COMPARISON OF MONTHLY AVERAGE RAINFALL AMOUNTS, 1971 & 1999 CALENDAR YEARS, RAINFALL IN INCHES

1971	average	3.34	2.83	3.53	3.25	3.70	4.27	4.11	3.78	2.71	2.05	2.36	2.84	38.77
1999	average	2.31	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.92	38.36
		-1.03	-0.35	0.02	0.07	0.05	-0.84	0.10	-0.06	0.36	0.63	0.56	0.08	-0.41

V. DEVELOPMENT OF "WET YEAR" MONTHLY PRECIPITATION DISTRIBUTION

The Maximum Annual Precipitation recorded (calendar basis) is 55.56 inches

The Average Annual Precipitation is 41.81 inches

Sum of Average Monthly Precipitation values 38.36 inches

The Average Annual Precipitation plus One Standard Deviation is 48.78 inches
This precipitation has been exceeded 4 times since 1971.

The Annual Precipitation for Average Monthly Ppt plus Monthly Standard Deviation is 59.63 inches
(year where the monthly ppt is equal to the average monthly value plus one standard deviation)

A "Wet Year" will be considered to be a Year in which the precipitation in any month is equal to the Average Monthly Precipitation plus 1 Standard Deviation.
This yields a probability of exceedance of about 16%

TABLE 3 SUMMARY OF PRECIPITATION ANALYSES

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Average Monthly Ppt	2.31	2.48	3.55	3.32	3.75	3.43	4.21	3.72	3.07	2.68	2.92	2.92	38.36
Monthly Average Annual Ppt	2.52	2.70	3.87	3.62	4.09	3.74	4.59	4.05	3.35	2.92	3.18	3.18	41.81
Wet Year Ppt, 1 Std Dev, based on Monthly Average Annual Ppt	2.94	3.15	4.51	4.22	4.77	4.36	5.35	4.73	3.90	3.41	3.71	3.71	48.78
Wet Year Ppt, 1.5 Std Dev, based on Monthly Average Annual Ppt	3.15	3.38	4.84	4.52	5.11	4.67	5.74	5.07	4.18	3.65	3.98	3.98	52.26
Wet Year Ppt, 2 Std Dev, based on Monthly Average Annual Ppt	3.36	3.60	5.16	4.82	5.45	4.98	6.12	5.41	4.46	3.89	4.24	4.24	55.75

Evaporation

I. Available Evaporation Data

I.A. Clarksburg 1948 (8) to 1964 (9)

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	total
Average Value				3.11	3.90	4.44	4.90	3.85	2.47	1.69			24.36

I.B. Evaporation Maps, Weather Atlas of the United States, U.S. Department of Commerce, Environmental Data Service, June 1968.

I.B.1. Mean Annual Class A Pan Evaporation - Plate 1

Clarksburg area 40
McElroy's Run site 45

I.B.2. Mean Annual Lake Evaporation - Plate 2

Clarksburg area 30 inches
McElroy's Run site 34 inches

I.B.3. Mean Annual Class A Pan Coefficient - Plate 3

Clarksburg area 75 percent
McElroy's Run site 75 percent

I.B.4. Calculated Class A Pan Coefficient, from Class A Pan & Lake Evaporation

Clarksburg area 75 percent
McElroy's Run site 76 percent

I.B.5. Mean May-October Evaporation in Percent of Annual Evaporation - Plate 4

Clarksburg area 72 percent
McElroy's Run site 74 percent

Evaporation

II. Analyses and Correlations

Pan evaporation is usually not measured from late fall to late spring in the northern climes, due to freezing of the water. However, some evaporation does occur during this period.

Given the above information from the Weather Atlas, one can adjust the Clarksburg data to fill in the remaining portion of the year, and then adjust again to correlate it to the McElroy's Run site.

II.A. Adjust Clarksburg data to get full year info

At Clarksburg area

The mean annual lake evaporation

The May - October evaporation from the Clarksburg data is

The Clarksburg data (Section I.A. above) is believed to be "lake" evaporation

The proportion of the Clarksburg May - October evaporation to the

Mean Annual Evaporation is then

The Weather Atlas indicates that the proportion should be

30 inches	(Weather Atlas, Plate 2)
21.25 inches	(Clarksburg data)
71 percent	(calculation)
72 percent	(Weather Atlas, Plate 1 & 2)

Use 72 percent in the water balance analyses.

Given that 72 percent of the Mean Annual (Pan or Lake) Evaporation occurs in the 6 month period May to October.

The remaining 28 percent of the Mean Annual (Pan or Lake) Evaporation would occur in the remaining 6 month period November to April.

For Lake Evaporation, the corresponding evaporation values would be

Mean Annual Lake Evaporation

May to October

November to April

30 inches	(Weather Atlas, Plate 2)
21.25 inches	(Clarksburg data)
8.75 inches	(calculation)
3.11 inches	(Clarksburg data)
5.64 inches	(calculation)
1.13 inches/month	(calculation)

The Clarksburg data indicates that the monthly average for April is

Therefore, Lake Evaporation from November to March would be

Divide this amount evenly between the 5 months

The resulting monthly distribution of lake evaporation for the Clarksburg area is therefore

Clarksburg area											
Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1.13	1.13	1.13	3.11	3.90	4.44	4.90	3.85	2.47	1.69	1.13	1.13
										total	30.00

Evaporation

I.C. The Weather Atlas indicates that the ratio of evaporation at the McElroy's Run site to evaporation at the Clarksburg area is on the order of

pan evaporation

lake evaporation

1.13

1.13


(Weather Atlas, Plate 1)

(Weather Atlas, Plate 2)

Use **Ratio of McElroy's Evaporation to Clarksburg Evaporation =** **1.13**

The Average Monthly distribution of lake evaporation at the McElroy's Run site is estimated as the Clarksburg monthly values multiplied by the above ratio.
The Below-Average Monthly distribution of lake evaporation assumes negligible evaporation occurs between November through March.

McElroy's Run Site		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	total
Average		1.27	1.27	1.27	3.50	4.39	5.00	5.51	4.33	2.78	1.90	1.27	1.27	33.75
Below-Average		0	0	0	3.50	4.39	5.00	5.51	4.33	2.78	1.90	0.00	0.00	27.41




Reservoir Normal Operating Pool Target Elevation
Surface Elevation of Reservoir at Target Elevation

887 ft, msl
241.5 acres

	Evaporation (inches)	Evaporation (gpm)	Average Runoff (inches)	Average Runoff (gpm)	Wet Year Runoff (inches)	Wet Year Runoff (inches)
Jan	1.27	186	2.01	296	1.73	254
Feb	1.27	206	2.19	321	1.90	279
Mar	1.27	186	3.29	483	3.05	449
Apr	3.50	531	3.05	448	2.80	411
May	4.39	644	3.50	514	3.28	481
Jun	5.00	758	3.16	465	2.92	429
Jul	5.51	810	3.98	585	3.80	558
Aug	4.33	636	3.47	509	3.24	477
Sep	2.78	422	2.79	410	2.53	371
Oct	1.90	279	2.39	351	2.11	310
Nov	1.27	193	2.64	387	2.36	347
Dec	1.27	186	2.64	387	2.36	347

Evaporation & Runoff



146

Elevation - Area Measurements obtained using CADD of digitized 2000 Topo of the McElroy's Run Reservoir Area. Volume is computed using the Average End Area Method. Computed Volumes were checked against the Elevation-Storage Curve originally developed for the Reservoir by D'Appolonia, Inc., and good agreement (+/- 1-2 percent) was obtained. Therefore, these values are used in subsequent reservoir analyses in this spreadsheet.

Reservoir Water Level at Time of Aerial Mapping	876.10	ft, msl
Reported Reservoir Water Level (March 2001)	880.5	ft, msl
Reported Reservoir Water Level (November 2001)	881.4	ft, msl
Current Reservoir Water Level (December 2001)	880.9	ft, msl

TABLE 1

Reservoir Elevation (ft, msl)	Surface Area (ac)	Average Surface Area (sf)	Increm. Storage Volume (ac-ft)	Total Storage Volume (ac-ft)	Reservoir Elevation (ft,msl)
876.10	160			14500	<i>Ref. 2, Drawing 6056-F-211434</i>
		167	151		
877.00	175	182	182	14651	877.00
		196	196	14833	878.00
878.00	190	208	208	15029	879.00
		216	216	15237	880.00
879.00	202	220	220	15454	881.00
		224	224	15674	882.00
880.00	214	228	228	15898	883.00
		232	232	16127	884.00
881.00	218	236	236	16359	885.00
		240	240	16595	886.00
882.00	223	243	243	16835	887.00
		248	248	17078	888.00
883.00	226	253	253	17326	889.00
		256	256	17578	890.00
884.00	230	259	259	17835	891.00
		262	262	18094	892.00
885.00	234	264	264	18355	893.00
		267	267	18620	894.00
886.00	238	270	270	18887	895.00
		272	272	19157	896.00
887.00	241	275	275	19429	897.00
		278	278	19704	898.00
888.00	245	280	280	19982	899.00
				20263	900.00
889.00	250				
890.00	255				
891.00	258				
892.00	260				
893.00	263				
894.00	266				
895.00	268				
896.00	271				
897.00	274				
898.00	276				
899.00	279				
900.00	282				

Runoff

I. First Order Approximation of Monthly Runoff Volume

The SCS Soil Cover Complex Method is adopted to estimate monthly average runoff volumes to the reservoir. This method is also used in the HELP model for the prediction of runoff. The method uses an initial abstraction parameter, which accounts for some minimum level losses (infiltration & interception) before the start of runoff. For water balance methods using monthly rainfall, predicted runoff volumes using the SCS method are considered to be slightly conservative, because the computed initial abstraction is taken from the entire monthly rainfall, rather than only for those rainfall events which exceed the initial abstraction. During the winter months, the volume of runoff may differ somewhat from the predicted values. The effective curve number may be increased because of the probability of frozen ground, which reduces infiltration. Precipitation may also occur as snowfall, whose fate depends upon temperature and relative humidity levels in addition to ground moisture conditions. The scope of the analyses does not permit evaluation of long-term records of daily temperature, relative humidity, and precipitation values. Also, the availability of this information, both in quantity and in proximity to the McElroy's site, is limited. Therefore, monthly values of precipitation and evaporation are used, as this data would provide reasonable prediction of reservoir levels.

II.	Data		ft. msl	ft. msl	
	Reservoir	Normal Operating Target Level			
II.A.	Areas				
	Reservoir		241.5 acres	(Elevation	887
II.B.1.	Upland Areas		386.5 acres		
	upland area, woods, fair condition		96.6 acres		
	upland area, pasture, fair condition		289.9 acres		
	subtotal, area upland of reservoir		628.0 acres		
	Ash Disposal Area		204.0 acres		Solid Waste/NPDES Application (81-237-67, March 1997), Addendum II, Section 4, p. 6 of 17, 81-237-41
	active disposal		30.4 acres		Solid Waste/NPDES Application (81-237-67, March 1997), Addendum II, Section 4, p. 6 of 17, 81-237-41
	revegetated pile		114.0 acres		estimated, by trial & error to get composite CN
	off-site areas		55.6 acres		estimated, by trial & error to get composite CN
	pond		4.0 acres		estimated, by trial & error to get composite CN
	total		832.0 acres		
II.B.2.	Curve Numbers				
	reservoir		100		
	upland areas				
	fair woods, HSG "B/C"		67		
	fair pasture, HSG "C"		79		
	ash disposal area		86		
	active disposal		74		
	revegetated pile		68		
	off-site areas		100		
	pond				
II.B.3.	Composite Curve Numbers				
	reservoir plus upland area		85	rounded	(see calcs by TRV, "Emergency Spillway, 2-13-92, in letter, GAI to APSC (H.McCullough), Project 81-237-41, April 14, 1992; and Solid Waste/NPDES Application (81-237-67, March 1997), Addendum II, Section 4, p. 6 of 17, 81-237-41
	reservoir alone		100	rounded	
	upland areas alone		76	rounded	
	ash disposal area		74	rounded	

Runoff

II.B.4.	S Factor	1.73	using unrounded CN values
	reservoir plus upland area	0.00	using unrounded CN values
	reservoir alone	3.16	using unrounded CN values
	upland areas alone	3.51	using unrounded CN values
	ash disposal area		
II.B.5.	Minimum Rainfall Resulting in Runoff	0.35	inch
	reservoir plus upland area	0	inch
	reservoir alone	0.63	inch
	upland areas alone	0.70	inch
	ash disposal area		

Table 1
Summary of Monthly Average Runoff Volumes
Areas Draining to the Reservoir
Precipitation Records 1971-1999

Average Year Monthly Precipitation, Average Monthly Precipitation Values adjusted to obtain Average Annual Precipitation												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
average annual monthly rainfall	2.52	2.70	3.87	3.62	4.09	3.74	4.59	4.05	3.35	2.92	3.18	3.18
predicted runoff, composite, CN= 85	1.21	1.36	2.36	2.14	2.56	2.25	3.01	2.53	1.90	1.54	1.76	1.76
predicted runoff, reservoir, CN= 100	2.52	2.70	3.87	3.62	4.09	3.74	4.59	4.05	3.35	2.92	3.18	3.18
predicted runoff, upland, CN= 76	0.71	0.82	1.64	1.45	1.81	1.54	2.20	1.78	1.25	0.96	1.14	1.14
predicted runoff, ash site, CN= 74	0.62	0.73	1.50	1.32	1.66	1.41	2.04	1.64	1.14	0.86	1.03	1.03

for comparison purposes only, consider the following
Maximum Monthly Values

5.79	7.26	9.42	6.18	9.06	13.20	8.46	8.06	6.94	5.02	7.39	8.21	94.99
maximum annual total rainfall												
55.56												


Wet Year Monthly Precipitation = Average Monthly Precipitation plus 1 Standard Deviation based on Annual Rainfall												
Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Predicted Monthly Precipitation	2.94	3.15	4.51	4.22	4.77	4.36	5.35	4.73	3.90	3.41	3.71	3.71
departure of adjusted rainfall from average	0.42	0.45	0.64	0.60	0.68	0.62	0.76	0.68	0.56	0.49	0.53	0.53
predicted runoff, composite, CN= 85	1.55	1.74	2.94	2.68	3.18	2.80	3.72	3.14	2.39	1.95	2.22	2.22
predicted runoff, reservoir, CN= 100	2.94	3.15	4.51	4.22	4.77	4.36	5.35	4.73	3.90	3.41	3.71	3.71
predicted runoff, upland, CN= 76	0.97	1.12	2.14	1.91	2.35	2.02	2.83	2.32	1.67	1.30	1.52	1.52
predicted runoff, ash site, CN= 74	0.87	1.01	1.98	1.76	2.18	1.87	2.65	2.15	1.53	1.18	1.39	1.39
total												
48.78												
30.54												
48.78												
21.86												
19.95												

Very Wet Year Monthly Precipitation = Average Monthly Precipitation plus 1-1/2 Standard Deviation based on Annual Precipitation												
Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Predicted Monthly Precipitation	3.15	3.38	4.84	4.52	5.11	4.67	5.74	5.07	4.18	3.65	3.98	3.98
departure of adjusted rainfall from average	0.63	0.68	0.97	0.90	1.02	0.93	1.15	1.01	0.84	0.73	0.80	0.80
predicted runoff, composite, CN= 85	1.73	1.93	3.24	2.95	3.49	3.09	4.08	3.45	2.64	2.17	2.46	2.46
predicted runoff, reservoir, CN= 100	3.15	3.38	4.84	4.52	5.11	4.67	5.74	5.07	4.18	3.65	3.98	3.98
predicted runoff, upland, CN= 76	1.12	1.28	2.40	2.15	2.63	2.27	3.15	2.59	1.88	1.48	1.72	1.72
predicted runoff, ash site, CN= 74	1.00	1.16	2.23	1.99	2.45	2.11	2.96	2.42	1.73	1.35	1.58	1.58
total												
52.26												
33.69												
52.26												
24.38												
22.56												

Runoff

Extremely Wet Year Monthly Precipitation = Average Monthly Precipitation plus 2 Standard Deviation based on Annual Precipitation													
Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	total
Predicted Monthly Precipitation	3.36	3.60	5.16	4.82	5.45	4.98	6.12	5.41	4.46	3.89	4.24	4.24	55.75
departure of adjusted rainfall from average	0.84	0.90	1.29	1.21	1.36	1.25	1.53	1.35	1.12	0.97	1.06	1.06	
predicted runoff, composite, CN= 85	1.91	2.13	3.54	3.23	3.81	3.38	4.44	3.77	2.90	2.38	2.70	2.70	36.87
predicted runoff, reservoir CN= 100	3.36	3.60	5.16	4.82	5.45	4.98	6.12	5.41	4.46	3.89	4.24	4.24	55.75
predicted runoff, upland CN= 76	1.26	1.44	2.67	2.39	2.91	2.52	3.48	2.87	2.10	1.66	1.93	1.93	27.16
predicted runoff, ash site CN= 74	1.14	1.31	2.49	2.23	2.73	2.35	3.28	2.69	1.94	1.52	1.78	1.78	25.25

FIGURE 2
WATER BALANCE FLOW DIAGRAM



indicates value obtained from another worksheet in this spreadsheet
indicates required manual input of value by user
indicates value obtained from Allegheny Energy Supply/Pleasants Power Station

DESIGN DATA					
	Average Year			90% Confidence	
	flow (gpm)	volume (ac-ft)		flow (gpm)	volume (ac-ft)
INFLOWS					
Annual Precipitation in Reservoir	522	841		652	1052
Upland Runoff	328	530		487	785
Ash Disposal Site Runoff	158	254		238	384
Slurry Flows *	600	968		600	968
Ash Disposal Site Leachate	100	161		100	161
OUTFLOWS					
Siphon Discharge ***	1721	2776		2077	3350
Mix Tank Siphon Withdrawal **	1300	2097		1735	2799
Average Evaporation	200	323		200	323
	421	679		342	552

- * Station Slurry Flow set at 600 gpm, based on review by Ray Kustra
 - ** Mix Tank Siphon Withdrawal set at 200 gpm, estimate made by Ralph Curtiss & Ray Kustra
 - *** For the Average Year, the hydraulic capacity of the existing siphon is shown
For the 90% Confidence, the minimum hydraulic capacity of the improved siphon is shown.
- Note: See Worksheet "reservoir_operation" for actual tracking of flows and volumes into and from the reservoir.

Outline of Analyses	
Data Summary	
Reservoir Normal Operating Level	flowchart
Station Slurry (Process) Flows, long-term average	flowchart
Gypsum Process/Mix Tank Withdrawal, est. long-term average	flowchart
Siphon, flow monitor measurement	flowchart
Net Siphon, considering Mix Tank operation	
Leachate Flows from Sediment Pond, ultimate development	flowchart
Reservoir Elevation-Area-Volume Rating Table	elev_area_volume
I. Average Year Analysis: Average Precipitation and Average Evaporation	
Predict the response, on a monthly basis, of reservoir levels during an "Average Year".	
I.A. Inflows (Average Monthly Precipitation & Design Estimates)	
I.A.1. Direct Precipitation onto Reservoir Area	Rainfall_Parkersburg_WSO
I.A.2. Runoff from Upland Area	Runoff
I.A.3. Runoff from Ash Site (Sediment Pond Effluent System)	Runoff
I.A.4. Slurry Flows	flowchart
I.A.5. Sediment Pond Base Flow	
I.B. Outflows	
I.B.1. Siphon Discharge (Current Capacity)	Station measurement
I.B.2. Evaporation (Average Monthly Evaporation, "Lake")	Evaporation
I.C. Mass Balance of Inflows and Outflows	calc
I.D. Summary of Analysis	
I.E. Conclusion	
II. Minimum Required Total Reservoir Discharge for an "Average" Year	
What is the Minimum Total Reservoir Discharge Required to Maintain a Given Reservoir Level Over the Course of a Year with Average Precipitation and Average Evaporation?	
II.A. Estimated Minimum Discharge and Monthly Discharge Volume	
II.B. Mass Balance of Inflows and Outflows	
II.C. Summary of Analysis	
III. Wet Year Analysis: Above-Average Precipitation with Below-Average Evaporation	
Predict the response, on a monthly basis, of reservoir levels during a "Wet Year".	
A "Wet Year" is defined here as a year in which the total annual precipitation has approximately a 15 percent probability of being exceeded.	
A "Wet Year" is based on the Average Annual Precipitation plus One (1) Standard Deviation.	
III.A. Inflows	
III.A.1. Direct Precipitation onto Reservoir Area	
III.A.2. Runoff from Upland Areas	
III.A.3. Runoff from Ash Site (Sediment Pond Effluent System)	
III.A.4. Slurry Flows	
III.A.5. Sediment Pond Base Flow	

III. Wet Year Analysis: Above-Average Precipitation with Below-Average Evaporation (con't)

- III.B. Outflows
 - III.B.1. Siphon Discharge (Current Design Capacity)
 - III.B.2. Evaporation (Below-Average Monthly Evaporation ("Lake"))
- III.C. Mass Balance of Inflows and Outflows
- III.D. Summary of Analysis

IV. Minimum Required Total Reservoir Discharge for a "Wet Year"
What is the Minimum Total Reservoir Discharge Required to Maintain a Given Reservoir Level Over the Course of a Year with Above-Average Precipitation and Below-Average Evaporation?
Above-Average Precipitation is Set as the Average Annual Precipitation plus One (1) Standard Deviation. The Probability that a year would have a total precipitation greater than this precipitation is about 15%.

- IV.A. Estimated Minimum Discharge and Discharge Volume
- IV.B. Mass Balance of Inflows and Outflows
- IV.C. Summary of Analysis

V. Sensitivity Analysis # 1:
What Reservoir Level Would Result for a "Wet Year" if the Total Reservoir Discharge is Based on an "Average Year"?

- IV.A. Estimated Minimum Discharge and Discharge Volume
- IV.B. Mass Balance of Inflows and Outflows

VI. Very Wet Year Analysis: More-than-Above Average Precipitation with Below-Average Evaporation
What Reservoir Level would result for a "Very Wet Year" under Current Siphon Discharge Conditions?
A "Very Wet Year" is defined as a year in which the Annual Precipitation that occurs has a 10% or less probability of being exceeded.
The precipitation that would have a 10% or less probability of occurring corresponds approximately to the Average Annual Precipitation plus One-and-One-Half (1-1/2) Standard Deviation.

- VI.A. Inflows
 - VI.A.1. Direct Precipitation onto Reservoir Area
 - VI.A.2. Runoff from Upland Areas
 - VI.A.3. Runoff from Ash Site (Sediment Pond Effluent System)
 - VI.A.4. Slurry Flows
 - VI.A.5. Sediment Pond Base Flow
- VI.B. Outflows
 - VI.B.1. Siphon Discharge (Current Design Capacity)
 - VI.B.2. Evaporation (Below-Average Monthly Evaporation ("Lake"))
- VI.C. Mass Balance of Inflows and Outflows
- VI.D. Estimated Minimum Discharge and Discharge Volume
- VI.E. Summary of Analysis

- VII. Minimum Required Total Reservoir Discharge for a "Very Wet Year"
What is the Minimum Total Reservoir Discharge Required to Maintain a Given Reservoir Level Over the Course of a Year with More-Than-Above-Average Precipitation and Below-Average Evaporation?
The probability that this amount of precipitation would occur is approximately ten (10) percent or less.

VII.A. Mass Balance of Inflows and Outflows
VII.B. Estimated Minimum Discharge and Discharge Volume
VII.C. Summary of Analysis
- VIII. Minimum Total Reservoir Discharge for an "Extremely Wet Year"
What is the Minimum Total Reservoir Discharge to Maintain a Given Reservoir Level Over the Course of a Year with a Greatly-More-Than-Above-Average Precipitation and Below-Average Evaporation?
Greatly-More-Than-Above Precipitation is set as the Average Annual Precipitation plus Two (2) Standard Deviations (92% confidence). The Probability that a year would have a total precipitation greater than this precipitation is about 2%.

VIII.A. Estimated Minimum Discharge and Discharge Volume
VIII.B. Mass Balance of Inflows and Outflows
VIII.C. Summary of Analysis
- VIII. Compare Reservoir Range Fluctuations with Maximum Normal Pool Level for the Reservoir.
- IX. Evaluate Fluctuation of the Reservoir during the Course of the Year Analyzed
- X. Plot of Monthly Reservoir Elevation Performance for Selected Discharge Rates

I. Average Year Analysis: Average Precipitation and Average Evaporation

Predict the response, on a monthly basis, of reservoir levels during an "Average Year".

NORMAL RESERVOIR OPERATING LEVEL 887.00 ft, msl flowchart
AVERAGE ANNUAL PRECIPITATION 41.81 inches rainfall_parkersburg_wso
PROBABILITY OF EXCEEDANCE 50 percent

I.A. Inflows (Average Monthly Precipitation & Design Estimates)

I.A.1. Direct Precipitation onto Reservoir Area

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Values	2.52	2.70	3.87	3.62	4.09	3.74	4.59	4.05	3.35	2.92	3.18	3.18
Average Reservoir Area (acres)	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5
(reservoir level @ Normal Operating Level)												
Inflow Volume (ac-ft)	50.67	54.40	77.87	72.83	82.26	75.24	92.35	81.60	67.34	58.79	64.05	64.05

Note: Average Monthly Values = long-term average of monthly average values of precipitation.

I.A.2. Runoff from Upland Area

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Values	0.71	0.82	1.64	1.45	1.81	1.54	2.20	1.78	1.25	0.96	1.14	1.14
Average Upland Area (acres)	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5
Inflow Volume (ac-ft)	22.72	26.43	52.80	46.77	58.17	49.63	70.89	57.35	40.42	31.00	36.72	36.72

I.A.3. Runoff from Ash Site (Sediment Pond Effluent System)

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Values	0.62	0.73	1.50	1.32	1.66	1.41	2.04	1.64	1.14	0.86	1.03	1.03
Average Disposal Area (acres)	204	204	204	204	204	204	204	204	204	204	204	204
Inflow Volume (ac-ft)	10.51	12.34	25.52	22.48	28.23	23.93	34.70	27.82	19.30	14.60	17.45	17.45

NOTE: Runoff from the ash disposal site drains to the sediment ponds. Outflow from the ponds is directed to the Sediment Pond Effluent System lift station, and then pumped to the reservoir. The design capacity of the pumps (2 in operation, 1 in reserve) is about 1150 gpm.

Total Rainfall-Runoff Inflow Volume (ac-ft) 83.91 93.17 156.19 142.08 168.66 148.80 197.94 166.78 127.06 104.38 118.22 118.22

I.A.4. Slurry Flows (based on Station estimate, December 2001, revised November 2002)

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	600	600	600	600	600	600	600	600	600	600	600	600
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100
Inflow Volume (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20

I. Average Year Analysis: Average Precipitation and Average Evaporation

I.A.5. Sediment Pond Base Flow (based on design predictions, ultimate pile development)

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	100	100	100	100	100	100	100	100	100	100	100	100
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100
Inflow Volume (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70

I.B. Outflows

I.B.1. Siphon Discharge (Current Capacity)

Use the Net Siphon Discharge, which equals to measured siphon line flow less the Station withdrawal for mix tank uses

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100
Discharge Volume (ac-ft)	178.11	160.87	178.11	172.36	178.11	172.36	178.11	178.11	172.36	178.11	172.36	178.11

I.B.2. Evaporation (Average Monthly Evaporation, "Lake")

data provided by U.S. Army Corps of Engineers, Huntington District, WV, for Clarksburg WV, 1948-1964.

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
evaporation (inches)	1.27	1.27	1.27	3.50	4.39	5.00	5.51	4.33	2.78	1.90	1.27	1.27
Reservoir Area (acres)	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5
Evaporative Loss (ac-ft)	25.54	25.54	25.54	70.41	88.30	100.52	110.94	87.16	55.92	38.26	25.54	25.54

I.C. Mass Balance of Inflows and Outflows

I.C.1. Determination of Individual Component Volumes and Net Changes to Reservoir Volume

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
I.C.1.a Inflows to Reservoir	179.81	179.80	252.10	234.89	264.56	241.61	293.84	262.68	219.87	200.29	211.03	214.12
I.C.1.a.1 Direct Rainfall (ac-ft)	50.67	54.40	77.87	72.83	82.26	75.24	92.35	81.60	67.34	58.79	64.05	64.05
I.C.1.a.2 Upland Areas (ac-ft)	22.72	26.43	52.80	46.77	58.17	49.63	70.89	57.35	40.42	31.00	36.72	36.72
I.C.1.a.3 Ash Disposal Area (ac-ft)	10.51	12.34	25.52	22.48	28.23	23.93	34.70	27.82	19.30	14.60	17.45	17.45
I.C.1.a.4 Slurry Disposal (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20
I.C.1.a.5 Sediment Pond (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70
I.C.1.b Outflows from Reservoir	203.64	186.41	203.64	242.77	266.40	272.88	289.04	265.27	228.28	216.37	197.90	203.64
I.C.1.b.1 Siphon (Net, ac-ft)	178.11	160.87	178.11	172.36	178.11	172.36	178.11	178.11	172.36	178.11	172.36	178.11
I.C.1.b.2 Evaporation (ac-ft)	25.54	25.54	25.54	70.41	88.30	100.52	110.94	87.16	55.92	38.26	25.54	25.54
I.C.1.c Net Change in Reservoir Volume (ac-ft)	(23.84)	(6.61)	48.45	(7.88)	(1.84)	(31.27)	4.80	(2.59)	(8.41)	(16.08)	13.13	10.48

I. Average Year Analysis: Average Precipitation and Average Evaporation

I.C.2. Tracking Reservoir Elevations based on Net Changes in Reservoir Volume

BEGINNING NORMAL RESERVOIR OPERATING LEVEL **887.00** **ft, msl** **AS OF 1 JANUARY OF FIRST YEAR OF ANALYSIS**
Beginning Reservoir Volume at Normal Operating Water Level 16835 ac-ft

THEN AVERAGE PREDICTED RESERVOIR LEVEL AT THE END OF EACH SUCCEEDING MONTH WOULD BE AS GIVEN BELOW:

Monthly Tracking of Reservoir Volumes and Elevations

Year 1	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
At Start of Month												
Reservoir Water Level	887	886.90	886.87	887.07	887.04	887.03	886.90	886.92	886.91	886.88	886.81	886.87
Reservoir Volume	16,835	16,811	16,804	16,853	16,845	16,843	16,812	16,817	16,814	16,806	16,790	16,803
At End of Month												
Net Change in Volume (ac-ft)	(23.84)	(6.61)	48.45	(7.88)	(1.84)	(31.27)	4.80	(2.59)	(8.41)	(16.08)	13.13	10.48
Reservoir Volume	16,811	16,804	16,853	16,845	16,843	16,812	16,817	16,814	16,806	16,790	16,803	16,813
Approx. Reservoir Water Level	886.90	886.87	887.07	887.04	887.03	886.90	886.92	886.91	886.88	886.81	886.87	886.91
low elevation of interpolation	886	886	887	887	887	886	886	886	886	886	886	886
high elevation of interpolation	887	887	888	888	888	887	887	887	887	887	887	887
low storage of interpolation	16595	16595	16835	16835	16835	16595	16595	16595	16595	16595	16595	16595
high storage of interpolation	16835	16835	17078	17078	17078	16835	16835	16835	16835	16835	16835	16835

I.D. Summary of Analysis

month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
first of month reservoir level	887.00	886.90	886.87	887.07	887.04	887.03	886.90	886.92	886.91	886.88	886.81	886.87
last of month reservoir level	886.90	886.87	887.07	887.04	887.03	886.90	886.92	886.91	886.88	886.81	886.87	886.91
Minimum Reservoir Level During the Year	886.81 ft, msl											
Maximum Reservoir Level During the Year	887.07 ft, msl											

I.E. Conclusion

The Existing Siphon, given its current operation, has sufficient capacity to prevent an net increase in reservoir level over the course of an average year.

II. Minimum Required Total Reservoir Discharge for an "Average" Year

Using the above information and procedure, estimate the total reservoir discharge rate needed to maintain, at year's end, a "no net increase" in reservoir water level.

II.A. Estimated Minimum Discharge and Monthly Discharge Volume

Trial & Error Solution: Assume a Reservoir Discharge Rate, compute resulting End-of-the-Year Reservoir Level, and compare to First-of-the-Year Reservoir Level.

First-of-the-Year Reservoir Level

Required NET Total Reservoir Discharge Capacity

Average Monthly Discharged Volume

End-of-the-Year Reservoir Level

Maximum Reservoir Level during the Year

887 ft, msl

1286 gpm

170.50 ac-ft

887.00 ft, msl

Assumed Starting Point for Analysis

manually input this value until the "End-of-the-Year Reservoir Level"

matches the "First-of-the-Year Reservoir Level"

This value must equal the "First-of-the-Year Reservoir Level"

II.B. Mass Balance of Inflows and Outflows

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Inflows to Reservoir	179.81	179.80	252.10	234.89	264.56	241.61	293.84	262.68	219.87	200.29	211.03	214.12
Reservoir (ac-ft)	50.67	54.40	77.87	72.83	82.26	75.24	92.35	81.60	67.34	58.79	64.05	64.05
Upland Areas	22.72	26.43	52.80	46.77	58.17	49.63	70.89	57.35	40.42	31.00	36.72	36.72
Ash Disposal Areas	10.51	12.34	25.52	22.48	28.23	23.93	34.70	27.82	19.30	14.60	17.45	17.45
Slurry Disposal (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20
Sediment Pond (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70
Outflows from Reservoir	201.73	184.68	201.73	240.91	264.48	271.03	287.12	263.35	226.42	214.45	196.04	201.73
Reservoir Discharge (ac-ft)	176.19	159.14	176.19	170.50	176.19	170.50	176.19	176.19	170.50	176.19	170.50	176.19
Evaporation (ac-ft)	25.54	25.54	25.54	70.41	88.30	100.52	110.94	87.16	55.92	38.26	25.54	25.54
Net Change in Reservoir Volume (ac-ft)	(21.92)	(4.88)	50.37	(6.02)	0.08	(29.42)	6.72	(0.67)	(6.55)	(14.16)	14.99	12.40

Year 1

At Start of Month

Reservoir Water Level

Reservoir Volume

At End of Month

Net Change in Volume

Reservoir Volume

Approx. Reservoir Water Level

low elevation of interpolation

high elevation of interpolation

low storage of interpolation

high storage of interpolation

Summary of Analysis

month

first of month reservoir level

end of month reservoir level

Minimum Reservoir Level During the Year

Maximum Reservoir Level During the Year

Fluctuation in reservoir Level

ft, msl

ft, msl

ft

March

Apr

ft, msl

ft, msl

ft

ft, msl

ft, msl

ft

III. Wet Year Analysis: Above-Average Precipitation with Below-Average Evaporation

Current Reservoir Discharge Capabilities
NORMAL RESERVOIR OPERATING LEVEL
SIPHON DISCHARGE CAPACITY
WET YEAR ANNUAL PRECIPITATION
PROBABILITY OF EXCEEDANCE

887 ft, msl
1300 gpm
48.78 inches
85 percent

flowchart
capacity of existing siphon
rainfall_parkersburg_wso

III.A. Inflows

III.A.1. Direct Precipitation onto Reservoir Area

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Adj. Maximum Monthly Rainfall	2.94	3.15	4.51	4.22	4.77	4.36	5.35	4.73	3.90	3.41	3.71	3.71
Average Reservoir Area (acres)	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5
(reservoir level Normal Operating Level)												
Inflow Volume (ac-ft)	59.12	63.47	90.85	84.96	95.97	87.78	107.74	95.20	78.56	68.58	74.73	74.73

III.A.2. Runoff from Upland Areas

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Adj. Maximum Monthly Runoff	0.97	1.12	2.14	1.91	2.35	2.02	2.83	2.32	1.67	1.30	1.52	1.52
Average Upland Area (acres)	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5
Inflow Volume (ac-ft)	31.35	36.07	68.97	61.52	75.57	65.06	91.14	74.57	53.64	41.84	49.02	49.02

III.A.3. Runoff from Ash Site (Sediment Pond Effluent System)

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Adj. Maximum Monthly Runoff	0.87	1.01	1.98	1.76	2.18	1.87	2.65	2.15	1.53	1.18	1.39	1.39
Average Disposal Area (acres)	204	204	204	204	204	204	204	204	204	204	204	204
Inflow Volume (ac-ft)	14.77	17.12	33.72	29.94	37.08	31.73	45.04	36.57	25.95	20.01	23.62	23.62

NOTE: Runoff from the ash disposal site drains to the sediment ponds. Outflow from the ponds is directed to the Sediment Pond Effluent System lift station, and then pumped to the reservoir. The design capacity of the pumps (2 in operation, 1 in reserve) is about 1150 gpm.

Total Rainfall-Runoff Inflow Volume (ac-ft)	105.23	116.66	193.53	176.42	208.62	184.57	243.92	206.34	158.15	130.43	147.36	147.36
---------------------------------------------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

III.A.4. Slurry Flows

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	600	600	600	600	600	600	600	600	600	600	600	600
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100
Inflow Volume (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20

III.A.5. Sediment Pond Base Flow

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	100	100	100	100	100	100	100	100	100	100	100	100
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100

Inflow Volume (ac-ft) 13.70 12.37 13.70 13.26 13.70 13.26 13.70 13.26 13.70 13.26 13.70

III. Wet Year Analysis: Above-Average Precipitation with Below-Average Evaporation

III.B. Outflows

III.B.1. Siphon Discharge (Current Design Capacity)

Use the Net Siphon Discharge, which equals to measured siphon line flow less the Station withdrawal for mix tank uses

Net Siphon Discharge Capacity = 1300 gpm

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100
Discharge Volume (ac-ft)	178.11	160.87	178.11	172.36	178.11	172.36	178.11	178.11	172.36	178.11	172.36	178.11

III.B.2. Evaporation (Below-Average Monthly Evaporation ("Lake"))

values based on data from U.S. Army Corps of Engineers, Huntington District, WV, for Clarksburg WV, 1948-1964.

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
evaporation (inches)	0.00	0.00	0.00	3.50	4.39	5.00	5.51	4.33	2.78	1.90	0.00	0.00
Reservoir Area (acres)	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5
Evaporative Loss (ac-ft)	0.00	0.00	0.00	70.41	88.30	100.52	110.94	87.16	55.92	38.26	0.00	0.00

III.C. Mass Balance of Inflows and Outflows

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Inflows to Reservoir	201.13	203.28	289.44	289.23	304.52	277.38	339.82	302.25	250.96	226.33	240.17	243.27
III.A.1. Direct Rainfall (ac-ft)	59.12	63.47	90.85	84.96	95.97	87.78	107.74	95.20	78.56	68.58	74.73	74.73
III.A.2.a. Upland Areas (ac-ft)	31.35	36.07	68.97	61.52	75.57	65.06	91.14	74.57	53.64	41.84	49.02	49.02
III.A.2.b. Ash Disposal Area (ac-ft)	14.77	17.12	33.72	29.94	37.08	31.73	45.04	36.57	25.95	20.01	23.62	23.62
III.A.3. Slurry Disposal (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20
III.A.4. Sediment Pond (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70
III.B. Outflows from Reservoir	178.11	160.87	178.11	242.77	266.40	272.88	289.04	265.27	228.28	216.37	172.36	178.11
III.B.1. Siphon (Net, ac-ft)	178.11	160.87	178.11	172.36	178.11	172.36	178.11	178.11	172.36	178.11	172.36	178.11
III.B.2. Evaporation (ac-ft)	0.00	0.00	0.00	70.41	88.30	100.52	110.94	87.16	55.92	38.26	0.00	0.00
Net Change in Reservoir Volume (ac-ft)	23.03	42.41	111.33	26.46	38.12	4.50	50.78	36.98	22.68	9.97	67.81	65.16

BEGINNING NORMAL RESERVOIR OPERATING LEVEL

Beginning Reservoir Volume at Normal Operating Water Level

887 ft. msl

16835 ac-ft

AS OF 1 JANUARY OF FIRST YEAR OF ANALYSIS

III. Wet Year Analysis: Above-Average Precipitation with Below-Average Evaporation

[illegible]

III.D. Summary of Analysis

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
first of month reservoir level	887.00	887.09	887.27	887.73	887.84	887.99	888.01	888.22	888.36	888.46	888.50	888.77
end of month reservoir level	887.09	887.27	887.73	887.84	887.99	888.01	888.22	888.36	888.46	888.50	888.77	889.03
The existing siphon cannot handle a "Wet Year".												
Minimum Reservoir Level During the Year				ft. msl	Jan							
Maximum Reservoir Level During the Year				ft. msl	Dec							
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec

IV. Minimum Required Total Reservoir Discharge for a "Wet Year"

What is the Minimum Total Reservoir Discharge Required to Maintain a Given Reservoir Level Over the Course of a Year with Above-Average Precipitation and Below-Average Evaporation?
Above-Average Precipitation is Set as the Average Annual Precipitation plus One (1) Standard Deviation.
The Probability that a year would have a total precipitation greater than this precipitation is about 15%.

Annual "Wet Year" Precipitation 48.78 inches
Probability of Exceedance 16%
Number of Times Exceeded Since 1970 3

IV.A. Estimated Minimum Discharge and Discharge Volume

Trial & Error Solution: Assume a Reservoir Discharge Rate, compute resulting End-of-the-Year Reservoir Level, and compare to First-of-the-Year Reservoir Level.

First-of-the-Year Reservoir Level 887 ft, msl Assumed Starting Point for Analysis
Required NET Total Reservoir Discharge Capacity 1610 gpm manually input this value until the "End-of-the-Year Reservoir Level"
Average Monthly Discharged Volume 213.46 ac-ft
End-of-the-Year Reservoir Level 887.00 ft, msl This value must equal the "First-of-the-Year Reservoir Level"
Maximum Reservoir Level during the Year 887.22 ft, msl

IV.B. Mass Balance of Inflows and Outflows

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Inflows to Reservoir	201.13	203.28	289.44	269.23	304.52	277.38	339.82	302.25	250.96	226.33	240.17	243.27
IV.A. Direct Rainfall (ac-ft)	59.12	63.47	90.85	84.96	95.97	87.78	107.74	95.20	78.56	68.58	74.73	74.73
IV.A.2 Upland Areas (ac-ft)	31.35	36.07	68.97	61.52	75.57	65.06	91.14	74.57	53.64	41.84	49.02	49.02
IV.A.2.a Ash Disposal Area (ac-ft)	14.77	17.12	33.72	29.94	37.08	31.73	45.04	36.57	25.95	20.01	23.62	23.62
IV.A.2.b Slurry Disposal (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20
IV.A.3 Sediment Pond (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70
IV.A.4 Outflows from Reservoir	220.58	199.23	220.58	283.87	308.87	313.98	331.51	307.74	269.38	258.84	213.46	220.58
IV.B. Siphon (Net, ac-ft)	220.58	199.23	220.58	213.46	220.58	213.46	220.58	220.58	213.46	220.58	213.46	220.58
IV.B.1 Evaporation (ac-ft)	0.00	0.00	0.00	70.41	88.30	100.52	110.94	87.16	55.92	38.26	0.00	0.00
IV.B.2 Net Change in Reservoir Volume (ac-ft)	(19.44)	4.05	68.86	(14.64)	(4.35)	(36.60)	8.31	(5.49)	(18.42)	(32.51)	26.71	22.69

NORMAL RESERVOIR OPERATING LEVEL AS OF 31 DEC OF THE PRECEDING YEAR

Reservoir Volume at Assumed Reservoir Water Level 887 ft, msl
16835 ac-ft

IV. Minimum Required Total Reservoir Discharge for a "Wet Year"

THEN THE PREDICTED RESERVOIR LEVEL AT THE END OF EACH SUCCEEDING MONTH WOULD BE AS GIVEN BELOW:

Year 1	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec						
At Start of Month																		
Reservoir Water Level	887.00	886.92	886.94	887.22	887.16	887.14	886.99	887.03	887.00	886.93	886.79	886.90						
Reservoir Volume	16,835	16,815	16,819	16,888	16,874	16,869	16,833	16,841	16,836	16,817	16,785	16,811						
At End of Month																		
Net Change in Volume (ac-ft)	-19	4	69	-15	-4	-37	8	-5	-18	-33	27	23						
Reservoir Volume	16,815	16,819	16,888	16,874	16,869	16,833	16,841	16,836	16,817	16,785	16,811	16,834						
Approx. Reservoir Water Level	886.92	886.94	887.22	887.16	887.14	886.99	887.03	887.00	886.93	886.79	886.90	887.00						
low elevation of interpolation	886	886	887	887	887	886	887	887	886	886	886	886						
high elevation of interpolation	887	887	888	888	888	887	888	888	887	887	887	887						
low storage of interpolation	16595	16595	16835	16835	16835	16595	16835	16835	16595	16595	16595	16595						
high storage of interpolation	16835	16835	17078	17078	17078	16835	17078	17078	16835	16835	16835	16835						
Summary of Analysis																		
first of month reservoir level	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec						
end of month reservoir level	887.00	886.92	886.94	887.22	887.16	887.14	886.99	887.03	887.00	886.93	886.79	886.90						
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec						
	886.92	886.94	887.22	887.16	887.14	886.99	887.03	887.00	886.93	886.79	886.90	887.00						
<table><tr><td>Minimum Reservoir Level During the Year</td><td>ft. msl</td><td>Jan</td></tr><tr><td>Maximum Reservoir Level During the Year</td><td>ft. msl</td><td>Dec</td></tr></table>													Minimum Reservoir Level During the Year	ft. msl	Jan	Maximum Reservoir Level During the Year	ft. msl	Dec
Minimum Reservoir Level During the Year	ft. msl	Jan																
Maximum Reservoir Level During the Year	ft. msl	Dec																

V. Sensitivity Analysis # 1:

What Reservoir Level Would Result for a "Wet Year" if the Total Reservoir Discharge is Based on an "Average Year"?

NORMAL RESERVOIR OPERATING LEVEL

IV.A. Estimated Minimum Discharge and Discharge Volume

Trial & Error Solution: Assume a Reservoir Discharge Rate, compute resulting End-of-the-Year Reservoir Level, and compare to First-of-the-Year Reservoir Level.

First-of-the-Year Reservoir Level

Required Reservoir Discharge for Average Year

887 ft, msl

1286 gpm

II.A.

IV.A. Estimated Minimum Discharge and Discharge Volume

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
IV.A. Inflows to Reservoir	201.13	203.28	289.44	269.23	304.52	277.38	339.82	302.25	250.96	226.33	240.17	243.27
IV.A.2 Direct Rainfall (ac-ft)	59.12	63.47	90.85	84.96	95.97	87.78	107.74	95.20	78.56	68.58	74.73	74.73
IV.A.2.a Upland Areas (ac-ft)	31.35	36.07	68.97	61.52	75.57	65.06	91.14	74.57	53.64	41.84	49.02	49.02
IV.A.2.b Ash Disposal Area (ac-ft)	14.77	17.12	33.72	29.94	37.08	31.73	45.04	36.57	25.95	20.01	23.62	23.62
IV.A.3 Slurry Disposal (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20
IV.A.4 Sediment Pond (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70
IV.B. Outflows from Reservoir	176.19	159.14	176.19	240.91	264.48	271.03	287.12	263.35	226.42	214.45	170.50	176.19
IV.B.1 Siphon (Net, ac-ft)	176.19	159.14	176.19	170.50	176.19	170.50	176.19	176.19	170.50	176.19	170.50	176.19
IV.B.2 Evaporation (ac-ft)	0.00	0.00	0.00	70.41	88.30	100.52	110.94	87.16	55.92	38.26	0.00	0.00

Net Change in Reservoir Volume (ac-ft)

	24.95	44.14	113.25	28.32	40.04	6.36	52.70	38.89	24.53	11.88	69.67	67.08
--	-------	-------	--------	-------	-------	------	-------	-------	-------	-------	-------	-------

BEGINNING NORMAL RESERVOIR OPERATING LEVEL

Beginning Reservoir Volume at Normal Operating Water Level

887 ft, msl

16835 ac-ft

THEN THE PREDICTED RESERVOIR LEVEL AT THE END OF EACH SUCCEEDING MONTH WOULD BE AS GIVEN BELOW:

Year 1

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
At Start of Month												
Reservoir Water Level	887	887.10	887.28	887.75	887.87	888.03	888.06	888.27	888.43	888.52	888.57	888.85
Reservoir Volume	16835	16860	16904	17017	17045	17086	17092	17145	17183	17208	17220	17290
At End of Month												
Net Change in Volume	25	44	113	28	40	6	53	39	25	12	70	67
Reservoir Volume	16860	16904	17017	17045	17086	17092	17145	17183	17208	17220	17290	17357
Approx. Reservoir Water Level	887.10	887.28	887.75	887.87	888.03	888.06	888.27	888.43	888.52	888.57	888.85	889.12
low elevation of interpolation	887	887	887	887	888	888	888	888	888	888	888	889
high elevation of interpolation	888	888	888	888	889	889	889	889	889	889	889	890
low storage of interpolation	16835	16835	16835	16835	17078	17078	17078	17078	17078	17078	17078	17326
high storage of interpolation	17078	17078	17078	17078	17326	17326	17326	17326	17326	17326	17326	17578
first of month reservoir level	887.00	887.10	887.28	887.75	887.87	888.03	888.06	888.27	888.43	888.52	888.57	888.85
end of month reservoir level	887.10	887.28	887.75	887.87	888.03	888.06	888.27	888.43	888.52	888.57	888.85	889.12

VI. Very Wet Year Analysis: More-than-Above Average Precipitation with Below-Average Evaporation

What Reservoir Level would result for a "Very Wet Year" under Current Siphon Discharge Conditions?

A "Very Wet Year" is defined as a year in which the Annual Precipitation that occurs has a 10% or less probability of being exceeded.

The precipitation that would have a 10% or less probability of occurring corresponds approximately to the Average

Annual Precipitation plus One-and-One-Half (1-1/2) Standard Deviation.

THIS IS THE PROPOSED DESIGN CONDITION

NORMAL RESERVOIR OPERATING LEVEL

887 ft, msl

VI.D. Estimated Minimum Discharge and Discharge Volume

VI.A.1. Direct Precipitation on the Reservoir

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Adj. Maximum Monthly Rainfall	3.15	3.38	4.84	4.52	5.11	4.67	5.74	5.07	4.18	3.65	3.98	3.98
Average Reservoir Area (acres)	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5
(reservoir level Normal Operating Level)												
Inflow Volume (ac-ft)	63.34	68.00	97.34	91.03	102.82	94.05	115.43	102.00	84.18	73.48	80.06	80.06

VI.A.2. Runoff from Upland Areas

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Adj. Maximum Monthly Runoff	1.12	1.28	2.40	2.15	2.63	2.27	3.15	2.59	1.88	1.48	1.72	1.72
Average Upland Area (acres)	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5	386.5
Inflow Volume (ac-ft)	35.93	41.17	77.35	69.20	84.57	73.08	101.57	83.48	60.54	47.55	55.46	55.46

VI.A.3 Runoff from Ash Disposal Site (Sediment Pond Effluent System)

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Adj. Maximum Monthly Runoff	1.00	1.16	2.23	1.99	2.45	2.11	2.96	2.42	1.73	1.35	1.58	1.58
Average Disposal Area (acres)	204	204	204	204	204	204	204	204	204	204	204	204
Inflow Volume (ac-ft)	17.05	19.67	37.99	33.84	41.68	35.81	50.39	41.12	29.44	22.87	26.87	26.87

NOTE: Runoff from the ash disposal site drains to the sediment ponds. Outflow from the ponds is directed to the Sediment Pond Effluent System lift station, and then pumped to the reservoir. The design capacity of the pumps (2 in operation, 1 in reserve) is about 1150 gpm.

Total Rainfall-Runoff Inflow Volume (ac-ft)	116.32	128.84	212.68	194.07	229.07	202.94	267.39	226.60	174.16	143.90	162.40	162.40
---------------------------------------------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

VI.A.4 Slurry Flows

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	600	600	600	600	600	600	600	600	600	600	600	600
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100
Inflow Volume (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20

VI. Very Wet Year Analysis: More-than-Above Average Precipitation with Below-Average Evaporation

VI.A.5 Sediment Pond Underdrain Flows

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	100	100	100	100	100	100	100	100	100	100	100	100
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100
Inflow Volume (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70

VI.B. Outflows

VI.B.1 Siphon Discharge (Current Discharge Capacity)

Net Siphon Discharge Capacity = 1300 gpm percent of the time

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Monthly Value (gpm)	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300	1300
Percent of Time in Operation	100	100	100	100	100	100	100	100	100	100	100	100
Discharge Volume (ac-ft)	178.11	160.87	178.11	172.36	178.11	172.36	178.11	178.11	172.36	178.11	172.36	178.11

VI.B.2 Evaporation (Below-Average)

values based on data from U.S. Army Corps of Engineers, Huntington District, WV, for Clarksburg WV, 1948-1964.

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
evaporation (inches)	0.00	0.00	0.00	3.50	4.39	5.00	5.51	4.33	2.78	1.90		
Reservoir Area (acres)	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5	241.5
Evaporative Loss (ac-ft)	0.00	0.00	0.00	70.41	88.30	100.52	110.94	87.16	55.92	38.26	0.00	0.00

III.C. Mass Balance of Inflows and Outflows

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
III.A. Inflows to Reservoir	212.22	215.46	308.59	286.88	324.98	295.75	363.30	322.51	266.97	239.80	255.20	258.30
III.A.1. Direct Rainfall (ac-ft)	63.34	68.00	97.34	91.03	102.82	94.05	115.43	102.00	84.18	73.48	80.06	80.06
III.A.2.a. Upland Areas (ac-ft)	35.93	41.17	77.35	69.20	84.57	73.08	101.57	83.48	60.54	47.55	55.46	55.46
III.A.2.b. Ash Disposal Area (ac-ft)	17.05	19.67	37.99	33.84	41.68	35.81	50.39	41.12	29.44	22.87	26.87	26.87
III.A.3. Slurry Disposal (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20
III.A.4. Sediment Pond (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70
III.B. Outflows from Reservoir	178.11	160.87	178.11	242.77	266.40	272.88	289.04	265.27	228.28	216.37	172.36	178.11
III.B.1. Siphon (Net, ac-ft)	178.11	160.87	178.11	172.36	178.11	172.36	178.11	178.11	172.36	178.11	172.36	178.11
III.B.2. Evaporation (ac-ft)	0.00	0.00	0.00	70.41	88.30	100.52	110.94	87.16	55.92	38.26	0.00	0.00
Net Change in Reservoir Volume (ac-ft)	34.11	54.59	130.48	44.11	58.58	22.86	74.26	57.24	38.69	23.44	82.84	80.19

BEGINNING NORMAL RESERVOIR OPERATING LEVEL 887 ft, msl AS OF 1 JANUARY OF FIRST YEAR OF ANALYSIS

Beginning Reservoir Volume at Normal Operating Water Level 16835 ac-ft

VI. Very Wet Year Analysis: More-than-Above Average Precipitation with Below-Average Evaporation
THEN AVERAGE PREDICTED RESERVOIR LEVEL AT THE END OF EACH SUCCEEDING MONTH WOULD BE

Year 1	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
At Start of Month												
Reservoir Water Level	887.00	887.09	887.27	887.73	887.84	887.99	888.01	888.22	888.36	888.46	888.50	888.77
Reservoir Volume	16835	16858	16900	17012	17038	17076	17081	17131	17168	17191	17201	17269
At End of Month												
Net Change in Volume (ac-ft)	34	55	130	44	59	23	74	57	39	23	83	80
Reservoir Volume	16869	16912	17031	17056	17097	17099	17155	17189	17207	17215	17284	17349
Approx. Reservoir Water Level	887.14	887.32	887.81	887.91	888.07	888.08	888.31	888.45	888.52	888.55	888.83	889.09
low elevation of interpolation	887	887	887	887	888	888	888	888	888	888	888	889
high elevation of interpolation	888	888	888	888	889	889	889	889	889	889	889	890
low storage of interpolation	16835	16835	16835	16835	17078	17078	17078	17078	17078	17078	17078	17326
high storage of interpolation	17078	17078	17078	17078	17326	17326	17326	17326	17326	17326	17326	17578

III.D. Summary of Analysis

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
887.00	887.09	887.27	887.73	887.84	887.99	888.01	888.22	888.36	888.46	888.50	888.77
887.14	887.32	887.81	887.91	888.07	888.08	888.31	888.45	888.52	888.55	888.83	889.09
Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec

Minimum Reservoir Level During the Year	ft, msl	Jan
Maximum Reservoir Level During the Year	ft, msl	Dec

VII. Minimum Required Total Reservoir Discharge for a "Very Wet Year"

What is the Minimum Total Reservoir Discharge Required to Maintain a Given Reservoir Level Over the Course of a Year with More-Than-Above-Average Precipitation and Below-Average Evaporation?

The probability that this amount of precipitation would occur is approximately ten (10) percent or less.

THIS CASE IS THE BASIS FOR DESIGN OF THE IMPROVED SIPHON WITH THE EFFLUENT GRAVITY PIPELINE

VI.A. Estimated Minimum Siphon Discharge and Discharge Volume

Probability of Exceedance is 7%

Number of Times Exceeded Since 1970 3

Trial & Error Solution: Assume a Reservoir Discharge Rate, compute resulting End-of-the-Year Reservoir Level, and compare to First-of-the-Year Reservoir Level.

First-of-the-Year Reservoir Level 887 ft, msl
Required NET Total Reservoir Discharge Capacity 1735 gpm
Average Monthly Discharged Volume 230.03 ac-ft

End-of-the-Year Reservoir Level 887.00 ft, msl
Maximum Reservoir Level during the Year 887.19 ft, msl

This value must equal the "First-of-the-Year Reservoir Level"

IV.B. Mass Balance of Inflows and Outflows

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Inflows to Reservoir	212.22	215.46	308.59	286.88	324.98	295.75	363.30	322.51	266.97	239.80	255.20	258.30
IV.A. Direct Rainfall (ac-ft)	63.34	68.00	97.34	91.03	102.82	94.05	115.43	102.00	84.18	73.48	80.06	80.06
IV.A.2 Upland Areas (ac-ft)	35.93	41.17	77.35	69.20	84.57	73.08	101.57	83.48	60.54	47.55	55.46	55.46
IV.A.2.a. Ash Disposal Area (ac-ft)	17.05	19.67	37.99	33.84	41.68	35.81	50.39	41.12	29.44	22.87	26.87	26.87
IV.A.2.b. Slurry Disposal (ac-ft)	82.20	74.25	82.20	79.55	82.20	79.55	82.20	82.20	79.55	82.20	79.55	82.20
IV.A.3. Sediment Pond (ac-ft)	13.70	12.37	13.70	13.26	13.70	13.26	13.70	13.70	13.26	13.70	13.26	13.70
IV.A.4 Outflows from Reservoir	237.70	214.70	237.70	300.45	326.00	330.56	348.64	324.87	285.96	275.96	230.03	237.70
IV.B. Siphon (Net, ac-ft)	237.70	214.70	237.70	230.03	237.70	230.03	237.70	237.70	230.03	237.70	230.03	237.70
IV.B.1. Evaporation (ac-ft)	0.00	0.00	0.00	70.41	88.30	100.52	110.94	87.16	55.92	38.26	0.00	0.00
IV.B.2. Net Change in Reservoir Volume (ac-ft)	-25.48	0.76	70.88	-13.57	-1.02	-34.81	14.66	-2.36	-18.99	-36.16	25.17	20.60

NORMAL RESERVOIR OPERATING LEVEL 887 ft, msl AS OF 31 DEC OF THE PRECEDING YEAR

Reservoir Volume at Assumed Reservoir Water Level 16835 ac-ft

VII. Minimum Required Total Reservoir Discharge for a "Very Wet Year"

THEN THE PREDICTED RESERVOIR LEVEL AT THE END OF EACH SUCCEEDING MONTH WOULD BE AS GIVEN BELOW:

Year 1	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
At Start of Month												
Reservoir Water Level	887	886.89	886.90	887.19	887.13	887.13	886.99	887.05	887.04	886.96	886.81	886.91
Reservoir Volume	16,835	16,809	16,810	16,881	16,867	16,866	16,832	16,846	16,844	16,825	16,789	16,814
At End of Month												
Net Change in Volume (ac-ft)	-25	1	71	-14	-1	-35	15	-2	-19	-36	25	21
Reservoir Volume	16,809	16,810	16,881	16,867	16,866	16,832	16,846	16,844	16,825	16,789	16,814	16,834
Approx. Reservoir Water Level	886.89	886.90	887.19	887.13	887.13	886.99	887.05	887.04	886.96	886.81	886.91	887.00
low elevation of interpolation	886	886	887	887	887	886	887	887	886	886	886	886
high elevation of interpolation	887	887	888	888	888	887	888	888	887	887	887	887
low storage of interpolation	16595	16595	16835	16835	16835	16595	16835	16835	16595	16595	16595	16595
high storage of interpolation	16835	16835	17078	17078	17078	16835	17078	17078	16835	16835	16835	16835

IV.C. Summary of Analysis

first of month reservoir level	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
end of month reservoir level	887.00	886.89	886.90	887.19	887.13	887.13	886.99	887.05	887.04	886.96	886.81	886.91
	886.89	886.90	887.19	887.13	887.13	886.99	887.05	887.04	886.96	886.81	886.91	887.00
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Minimum Reservoir Level During the Year	886.81	887.19	887.19	887.19	887.13	887.13	886.99	887.05	887.04	886.96	886.81	886.91
Maximum Reservoir Level During the Year	887.19	887.19	887.19	887.13	887.13	886.99	887.05	887.04	886.96	886.81	886.91	887.00

IX. Evaluate Fluctuation of the Reservoir during the Course of the Year Analyzed

Maximum Heights and Fluctuations of Reservoir Levels for Analyzed Conditions

Maximum Normal Pool Level in Reservoir	888.45	ft, msl	spreadsheet h&h.xls, worksheet reservoir_level.
Normal Operating Level in Reservoir	887.00	ft, msl	
Analyzed Condition	Total Reservoir Discharge (gpm)	Maximum Reservoir Level (ft, msl)	Annual Fluctuation in Reservoir Level (ft)
Average Year	1300	887.07	0.26
Current Siphon	1286	887.10	0.21
Minimum Required Reservoir Discharge			
Wet Year	1300	889.03	2.03
Current Siphon	1610	887.22	0.43
Minimum Required Reservoir Discharge			
Very Wet Year	1300	889.09	2.09
Current Siphon	1735	887.19	0.38
Minimum Required Reservoir Discharge			


Average Year, 1300 gpm siphon

[illegible]

NORMAL RESERVOIR OPERATING LEVEL

887 ft, msl

Reservoir Water Level Operation for Selected Siphon Capacities



Note: user must manually change custom footer to indicate Normal Operating Level of Reservoir.

APPENDIX C

CALCULATIONS FOR THE PROPOSED
IMPROVED SIPHON EFFLUENT GRAVITY PIPELINE DESIGN

APPENDIX C

Table of Contents

Section 1	Siphon Layout and Geometry
Section 2	General Data
Section 3	Hydraulic Design Analyses for Proposed Effluent Gravity Pipeline
Section 4	Pressure and Water Hammer Analyses

I. Objective

Design of a Proposed Pipeline, to convey water from the Reservoir to the Ohio River. The pipeline is to operate as a siphon, similar to the existing siphon pipeline. The pipeline would incorporate the hdpe pipe portion of the existing siphon line, with a new hdpe pipe installed from the downstream end of the existing pipe to a new outfall at the Ohio River. The outfall segment of the pipeline would be ductile iron pipe. The discharge of the pipeline may be either to the Ohio River or to a treatment plant, depending upon technical feasibility and regulatory acceptance. The pipeline would operate as a siphon to the treatment plant, if one is required.

II. Design Parameters & Constraints

The siphon must be capable of handling, at a minimum, the design discharge withdrawal rate that has been determined for maintenance of the reservoir water level with the desired operating range. The piping must be capable of withstanding the anticipated internal and surge pressures, to include potential water hammer pressures.

It is desired that the new siphon pipeline be designed and constructed so as to be positively-draining (no high or low spots in the line) except for the siphon crest. This may require passing surface drainage structures over or under the Proposed Pipeline, and/or the placement of fill over the pipeline for frost protection.

III. Geometry

Horizontal and vertical geometry of the Proposed New Siphon Pipeline is given on worksheet "geometry" of this spreadsheet file. The geometry is obtained from GAI Drawing 1999-170-51-F1003, dated 22 January 2002, by MAM. Revised 5 March 2002

III. Layout

Based on the geometry, alignment and the anticipated hydraulic features of the Proposed New Siphon Pipeline, a hydraulic schematic is developed, from which various hydraulic features of the pipeline can be identified and tabulated.

IV. Method of Analysis

The Energy Equation (Bernoulli Equation) is used to calculate headlosses in the proposed pipeline, and thereby estimate hydraulic capacity and pipe size. The Energy Equation is applied in a downstream direction, starting with the water level in the reservoir. The energy and hydraulic grade elevations at selected points along the pipeline are then computed. The hydraulic capacity of the pipeline is based on maintaining the hydraulic grade line above the crown of the pipeline, or above the river level, whichever is the more critical.

The hydraulic analysis is presented in worksheet "hyd_anal_*_*" in this spreadsheet file. "*" indicates either "des" (design) or "max" (maximum hydraulic capacity), and nominal pipe size "12" (12 inches) or "14" (14 inches).

V. Pipe Design

Based on the predicted hydraulic conditions, the class of pipe for the proposed pipeline is determined. Three conditions are analyzed. The first condition is when the valve is closed at the downstream end, and a static head exists in the pipeline. The second condition is when the pipeline is operating under design and under maximum flow conditions. The third condition is for waterhammer, assuming a valve is shut rapidly. The Class of pipe (SDR for hdpe, and pressure class for ductile iron) required to withstand the most critical of these conditions, if considered practical, is determined.

Under any scenario, controls should be placed on the rate at which flow control ("throttle") valves can operate, to reduce surge pressures and prevent water hammer.

Summary of Geometry
Proposed Siphon Pipeline

Point	Description	Northing	Easting	Length of Pipeline between Points (ft)	Stationing		Length by Stationing (ft)	Ground Elevation (ft, msl)	Invert Elevation of pipe (ft, msl)	Computed Slope of Pipeline (ft/ft)
					Hundreds (ft)	Ones (ft)				
0	intake in reservoir	319500	1466700					881	877	
				702.14						0.0014
1	headwall connection at dam	319370	1466010					881	876	
				128.55						-0.0389
2	crest at siphon vault	319400	1465885					900	881	
				1054.34						0.0152
3	Pigcatcher Road slope break	319540	1464840					870	865	
				785.06						0.1847
4	Ash Haul Road slope break	319875	1464130					725	720	
				64.23						0.0654
5	PT-101 of new siphon route & connection w/ extg line	319891.82	1464068.01		0	0		718	715.80	
				54.63			54.63			0.1333
6	PT-102	319932.00	1464031.00		0	54.63		713	708.52	
				270.37			270.37			0.1912
7	PT-103	320084.88	1463808.00		3	25.00		662	656.82	
				200.05			201.05			0.1091
8	PT-104	320198.00	1463643.00		5	26.05		644	635.00	
				206.38			205.39			0.0120
9	PT-105	320047.84	1463501.42		7	31.44		641	632.52	
				274.70			274.70			0.0025
10	PT-106	319985.00	1463234.00		10	6.14		636	631.83	
				135.00			135.00			0.0024
11	PT-107	319959.11	1463101.51		11	41.14		637	631.50	
				99.77			98.95			0.0025
12	PT-108	319926.89	1463007.09		12	40.09		636	631.25	
				620.24			621.06			0.0025
13	PT-109	320125.37	1462419.46		18	61.15		626	629.70	
				200.26			200.26			0.0025
14	PT-110	320119.64	1462219.28		20	61.41		633	629.20	
				199.99			199.98			0.0025
15	PT-111	320318.44	1462241.05		22	61.39		636	628.70	
				185.07			185.07			0.0025
16	PT-112	320503.44	1462246.05		24	46.46		636	628.23	
	Route 2 Xing			139.94			139.94			0.0025
17	PT-113	320623.44	1462174.05		25	86.40		634	627.88	
				110.76			110.76			0.0043
18	PT-114	320706.48	1462100.76		26	97.16		634	627.40	
				198.12			198.11			0.0025
19	PT-115	320841.48	1462245.76		28	95.27		632	626.90	
				99.06			99.06			0.0273
20	PT-116	320916.59	1462310.34		29	94.33		630	624.20	
				159.85			159.85			0.0025
21	PT-117	321025.40	1462427.44		31	54.18		627	623.80	
				672.10			672.10			0.0025
22	PT-118 (bend at Eureka Road)	321606.00	1462766.00		38	26.28		631	622.12	
				161.79			161.79			0.0025
23	PT-119	321766.00	1462742.00		39	88.07		631	621.72	
				309.16			309.15			0.0025
24	PT-120	322059.71	1462645.50		42	97.22		634	620.94	
				212.59			212.60			0.0025
25	PT-121	322259.29	1462572.27		45	9.82		635	620.41	
				86.76			86.75			0.2007
26	PT-122	322340.74	1462542.39		45	96.57		605	603.00	
				275.23			275.43			0.0654
27	outfall in Ohio River	322600.00	1462450.00		48	72		585	585	
total length of pipeline				7,331						

Summary of Pipeline Layout
Proposed Siphon Pipeline

Point	Description	Pipeline Segment	Type of Pipe (hdpe or duct. iron)	Length of Pipeline Segment (ft)	Entrance Condition	Exit Condition	# of Bends	# of Tees or Wyes	# of Shutoff Valves	# of Check Valves	# of Throttle Valves
0	intake in reservoir	1	hdpe	702.14	1	0	1	0	0	0	0
1	headwall connection at dam	1	hdpe	128.55	0	0	1	0	0	0	0
2	crest at siphon vault	1	hdpe	1054.34	0	0	4	0	0	0	0
3	Pigcatcher Road slope break	1	hdpe	785.06	0	0	1	0	0	0	0
4	Ash Haul Road slope break	1	hdpe	64.23	0	0	1	0	0	0	0
5	PT-101 of new siphon route & connection w/ extg line	2	hdpe	54.63	0	0	0	1	0	0	0
6	PT-102	2	hdpe	270.37	0	0	0	0	0	0	0
7	PT-103	2	hdpe	200.05	0	0	0	0	0	0	0
8	PT-104	2	hdpe	206.38	0	0	1	0	0	0	0
9	PT-105	2	hdpe	274.70	0	0	1	0	0	0	0
10	PT-106	2	hdpe	135.00	0	0	0	0	0	0	0
11	PT-107	2	hdpe	99.77	0	0	0	0	0	0	0
12	PT-108	2	hdpe	620.24	0	0	1	0	0	0	0
13	PT-109	2	hdpe	200.26	0	0	1	0	0	0	0
14	PT-110	2	hdpe	199.99	0	0	1	0	0	0	0
15	PT-111	2	hdpe	185.07	0	0	0	0	0	0	0
16	PT-112	2	hdpe	139.94	0	0	1	0	0	0	0
17	PT-113	2	hdpe	110.76	0	0	0	0	0	0	0
18	PT-114	2	hdpe	198.12	0	0	1	0	0	0	0
19	PT-115	2	hdpe	99.06	0	0	0	0	0	0	0
20	PT-116	2	hdpe	159.85	0	0	0	0	0	0	0
21	PT-117	2	hdpe	672.10	0	0	1	0	0	0	0
22	PT-118 (bend at Eureka Road)	2	hdpe	161.79	0	0	1	0	1	1	1
23	PT-119	2	hdpe	309.16	0	0	0	0	0	0	0
24	PT-120	2	hdpe	212.59	0	0	0	0	0	0	0
25	PT-121	2	hdpe	86.76	0	0	1	0	0	0	0
26	PT-122	3	duct. iron	275.23	0	1	1	0	0	0	0
27	outfall in Ohio River										
subtotals					1	1	19	1	1	1	1

pipeline segment refers to (1)
(2)
(3)

hdpe pipe portion of existing siphon line
hdpe pipe portion of proposed new siphon line
ductile iron pipe portion of proposed new siphon line

Headloss Coefficients for Pipeline, and various fittings

Sudden Expansions											
A1/A2	0	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1
k	1	0.81	0.64	0.49	0.36	0.25	0.16	0.09	0.04	0.01	0
k is applied to the velocity head for the smaller diameter of the pipes (the A1 pipe)								k v_1^2/2g			
For entrance of a pipe into a reservoir or manhole, use						1					

Sudden Contractions											
A2/A1	0	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1
k	0.5	0.48	0.45	0.41	0.36	0.29	0.21	0.13	0.07	0.01	0
k is applied to the velocity head for the smaller diameter of the pipes (the A2 pipe)								k v ₂ ² /2g			
For exit from a manhole or pond to a pipe, use						0.5					

Conical Diffusers						Rouse, p. 421					
angle of cone	0	20	30	45	60						
k for D2/D1 = 1.5	0.2	0.4	0.7	1.05	1.2						
k for D2/D1 = 3	0.2	0.4	0.65	0.87	1.03						
k is applied to the square of the difference of the two velocities								$k (v_1 - v_2)^2/2g$			

Valves					Rouse, p. 421						
Gate Valve											
% open	25	50	75	100							
k	24	5.6	1.15	0.19							
Check Valve (Swing), fully open					2.5						

Bends, 90 degrees			Rouse, p. 421								
standard sweep		0.9									
medium-sweep		0.75									
long-sweep		0.6									

Ductile Iron Pipe

Nominal Diameter (inches)	Outside Diameter (inches)	Nominal Thickness and Inside Diameter (inches) for Selected Pressure Classes				from DIPRA, "Ductile Iron Pipe"
		PC = 350		PC = 300		
		t (inch)	ID (inch)	t (inch)	ID (inch)	
3	3.96	0.25	3.46	---	---	
4	4.8	0.25	4.3	---	---	
6	6.9	0.25	6.4	---	---	
8	9.05	0.25	8.55	---	---	
10	11.1	0.26	10.58	---	---	
12	13.2	0.28	12.64	---	---	
14	15.3	0.31	14.68	0.3	14.7	
16	17.4	0.34	16.72	0.32	16.76	
18	19.5	0.36	18.78	0.34	18.82	
20	21.6	0.38	20.84	0.36	20.88	
24	25.8	0.43	24.94	0.4	25	
30	32	0.49	31.02	0.45	31.1	
36	38.3	0.56	37.18	0.51	37.28	
42	44.5	0.63	43.24	0.57	43.36	
48	50.8	0.7	49.4	0.64	49.52	
54	57.56	0.79	55.98	0.72	56.12	
60	61.61	0.83	59.95	0.76	60.09	
64	65.67	0.87	63.93	0.8	64.07	

Cone Sleeve Flow Chart Cv Red Valve Control Valve manufacturer literature

Valve Size	Port Size	Valve Opening (% of Total Travel)									
		10	20	30	40	50	60	70	8	90	100
8	6	62	156	311	427	653	810	948	1055	1173	1300
10	6	33.8	59.2	127	220	363	482	549	609	659	710
10	8	140	315	648	834	1047	1222	1547	1732	1805	2010
12	8	85.9	153	317	709	904	1034	1202	1333	1531	1680
12	10	171	355	726	1418	1923	2407	2824	3101	3420	3800
14	10	155	328	616	983	1349	1773	2273	2524	2755	2928
14	12	250	520	1063	2077	2816	3525	4136	4541	5008	5565

Solution Procedure For Valve Sizing

ASSUME a pressure drop across the valve (psi) for each Flow Condition

Minimum Flow Condition Q = 1200 gpm

Design Flow Condition Q = 1700 gpm

Maximum Flow Condition Q = 3200 gpm

Calculate the Cv values for each flow condition

For a Control Valve whose Valve Size is equal to or smaller than the line size,

Find the Port Size whose Cv range encompasses the computed Cv values within 20% and 80% travel (manufacturer recommendation).

Calculate the Maximum Allowable Pressure Drop (psi)

Compare the Maximum Allowable Pressure Drop to the Assumed Pressure Drop.

KLP

If Assumed Pressure Drop is less than the Maximum Allowable Pressure Drop, then cavitation will not occur.

Nominal Pipe Diameter	12	inches
Inside Pipe Diameter	10.43	inches
Flow Conditions		
Minimum Flow Condition	1200	gpm
Design Flow Condition	1700	gpm
Maximum Flow Condition	3200	gpm
ASSUMED PRESSURE DROP		
Minimum Flow Condition	5	psi
Design Flow Condition	7	psi
Maximum Flow Condition	10	psi

Calculate the Cv values for the Flow Conditions

$C_v = Q \sqrt{G / dP}$

Cv flow in gpm of 60 degree water through the valve with 1 psi pressure drop, at a stated upstream pressure
Q flow (gpm)
G specific gravity of fluid
dP drop in pressure across valve (psi)

Q	dP	Cv
gpm	psi	
1200	5	537
1700	7	643
3200	10	1012

The Range of Computed Cv values is 537 to 1012
From the manufacturer's (Red Valve) literature, bracketing the above Cv values between 20% and 80% opening, the following Control Valve appears applicable.

Valve Size	10	10
Port Size	6	8
Cv @ 20%	59.2	315
Cv @ 80%	609	1732

Calculate the Maximum Allowable Pressure Drop

$dP_{allowable} = FL^2 * (P_1 + 14.7 - rc * P_v)$

Ket

FL	Pressure Recovery Factor
P1	Inlet Pressure (psi)
14.7	conversion factor from psig to psia
rc	Critical Pressure Ratio, = 0.94
Pv	Vapor Pressure at Flow Temperature
	ASSUME Temperature = 80 degrees F (to provide cushion against cavitation)
	0.5 psi
FL	10 x 6 Cone Sleeve Control Valve
FL	10 x 8 Cone Sleeve Control Valve
P1	34.13 ft Energy Grade Elevation - Invert of Pipe Elevation at Valve Location
	15 psi
rc	0.94
Pv	0.5 psi

dP_allowable = 14
10

because dP assumed > dP allowable, cavitation may result.

Assume a less drop in pressure across the valve

KLC

The energy at any point in the system can be predicted using the Energy Equation (the general form of Bernoulli's Equation), assuming sufficient information is known about the pipe and the flow conditions. For this analysis, it is assumed that the pipeline will flow full throughout its entire length. This assumption will be verified, and subsequent modifications will be made as appropriate.

For this analysis, a downstream approach is used. Starting with a known water level in the reservoir, the energy losses in the pipeline are then calculated. By comparing the resulting energy grade and hydraulic grade elevations with the pipeline profile, confirmation that the pipe does indeed flow full can be determined. If, at any point along the pipeline alignment, the hydraulic grade line dips below the crown of the pipe, then the pipe size may not be adequate to convey the flow, and a larger pipe size should be selected.

If, for a Selected Pipe Size (Nominal Diameter) and Flow, the computed Hydraulic Grade Line is above the crown of the pipe everywhere along the pipe, and is above the ground elevation at Point 118, where the proposed Control Valve Vault is to be located, then the Selected Pipe Size will be considered to be adequate to convey the flow.

This Worksheet computes flow conditions for the Design Reservoir Withdrawal Discharge Rate, for a given Pipe Type and Size. The cells indicated in PINK require USER INPUT for the selection of the Pipe Type, Size, and Class, and of the Flow.

The worksheet automatically calculates the inside diameter of HDPE pipe, given the provided information, for pipe of 10 inches Nominal Diameter or larger. Smaller pipe sizes result in a warning to the USER. The inside diameter for ductile iron pipe is obtained from a lookup table in the Worksheet "REF_INFO".

Pipe Segments "1" and "2" are reserved for HDPE pipe only. Pipe Segment "3" is reserved for Ductile Iron Pipe.

General Design Data

Reservoir Water Level	881.00	ft, msl	as of December 2001
Ohio River Water Level			
Normal Pool Level	602.00	ft, msl	

Pipe Design Data

The proposed pipeline is divided into three (3) segments, corresponding to (1) the hdpe pipe portion of the existing siphon line; (2) the proposed new hdpe portion of the new siphon line; and (3) the proposed new ductile iron portion of the new siphon line.

Type of Pipe Pipe Size, Nominal (inches) SDR or Class	segment 1		segment 2		segment 3	
	HDPE	as-built	HDPE	proposed	duct. iron	Proposed
12	12	as-built	11	proposed	350	DIPRA info, ductile iron pipe
17	17	as-built	10.432	calc	12.64	DIPRA info, ductile iron pipe, look up from worksheet "Ref_Info"
Inside Diameter of Pipe (inches)	11.250	calc, manufacturer info, Driscopipe	1700	reservoir design discharge	1700	reservoir design discharge
Design Flow (gpm)	1700	reservoir design discharge	0.59	calc	0.87	calc
Full Flow Pipe Area (sq ft)	0.89	calc	6.38	calc	4.35	calc
Full Flow Velocity (fps)	5.49	calc	0.000017	water at 40 degrees F	0.000017	water at 40 degrees F
Dynamic Viscosity (R+2/s)	3.03E+05	calc	3.26E+05	calc	2.69E+05	calc
Reynold's Number RE	smooth	Rouse, Engineering Hydraulics, p. 405	smooth	Rouse, Engineering Hydraulics, p. 405	smooth	average for cast iron, Rouse, p. 405
pipe "k" factor	smooth	Rouse, Engineering Hydraulics, p. 405	smooth	Rouse, Engineering Hydraulics, p. 405	878	calc
pipe "D/k" factor	0.015	Rouse, Engineering Hydraulics, p. 405	0.015	Rouse, Engineering Hydraulics, p. 405	0.022	Rouse, Engineering Hydraulics, p. 405
Darcy-Weisbach Friction Factor "f"	0.47	calc	0.63	calc	0.29	calc
Velocity Head (ft)						

Throttle Valve Design Data

The headloss for a throttle valve is dependent upon the "% open" setting of the valve and the valve's Cv value.

Cv is a measurement of the valve's capacity to pass flow with a one (1) foot drop in pressure.

For water, the equation for Cv is

$$Cv = Q / \sqrt{\text{drop in pressure}}$$

Q = flow

dP = drop in pressure

The Cv values are obtained from manufacturer's literature.

For the tabulation below for Throttle Valve Headloss to function correctly, the User must specify pertinent data on the valve, to allow computation of the headloss through the valve.

This information must be provided for the Worksheet to accurately predict headlosses through the piping system.

Manufacturer of Valve	DeZunk	
Type of Valve	ball	
Size of Valve	10	inches
Number of Valves (in Series)	1	
% Open Setting of Valve	50	manufacturer's literature
Cv of valve for % Open Setting	204	manufacturer's literature
		dummy value, use only to set Cv below GIVEN, from JLS (back calculated to get loss = 69.23 +/-)

NOTE:

Point	Description	Pipeline Segment	Type of pipe	Energy Head (ft)	Length of Pipeline Segment	Friction Gradient (ft/ft)	Pipe Friction (ft)	Headlosses	Tees	Shutoff Valves	Throttle Valves	Check Valves	Exit	Total Headloss (ft)	Energy Head Elevation (ft, msl)	Hydraulic Grade Elevation (ft, msl)	Invert Elevation (ft, msl)	Crown Elevation of Pipe (ft, msl)	Is Pipe Adequate to Pass Flow (y/n)
0	intake in reservoir	1	hdpe	881.00	702.14	0.007481	5.25	0.23	0.00	0.00	0.00	0.00	0.00	5.91	881.00	880.53	877	878.00	yes
1	headwall connection at dam	1	hdpe	875.09	128.55	0.007481	0.96	0.00	0.00	0.00	0.00	0.00	0.00	1.38	875.09	874.63	876	877.00	no
2	crest at siphon vault	1	hdpe	873.71	1054.34	0.007481	7.89	0.00	0.00	0.00	0.00	0.00	0.00	9.57	873.71	873.24	881	882.00	no
3	Pigcatcher Road slope break	1	hdpe	864.14	795.06	0.007481	5.87	0.00	0.00	0.00	0.00	0.00	0.00	6.29	864.14	863.67	865	866.00	no
4	Ash Haul Road slope break	1	hdpe	857.85	64.23	0.007481	0.48	0.00	0.00	0.00	0.00	0.00	0.00	0.90	857.85	857.38	720	721.00	yes
5	PT-101 of new siphon route & connection w/ extg line	2	hdpe	856.94	54.63	0.010912	0.60	0.00	0.57	0.00	0.00	0.00	0.00	1.17	856.94	856.31	715.8	716.80	yes
6	PT-102	2	hdpe	855.78	270.37	0.010912	2.95	0.00	0.00	0.00	0.00	0.00	0.00	2.95	855.78	855.15	708.52	709.52	yes
7	PT-103	2	hdpe	852.83	200.05	0.010912	2.18	0.00	0.00	0.00	0.00	0.00	0.00	2.18	852.83	852.20	656.82	657.82	yes
8	PT-104	2	hdpe	850.65	206.38	0.010912	2.25	0.00	0.00	0.00	0.00	0.00	0.00	2.82	850.65	850.01	635	636.00	yes
9	PT-105	2	hdpe	847.82	274.70	0.010912	3.00	0.00	0.00	0.00	0.00	0.00	0.00	3.57	847.82	847.19	632.52	633.52	yes
10	PT-106	2	hdpe	844.26	135.00	0.010912	1.47	0.00	0.00	0.00	0.00	0.00	0.00	1.47	844.26	843.62	631.83	632.83	yes
11	PT-107	2	hdpe	842.78	99.77	0.010912	1.09	0.00	0.00	0.00	0.00	0.00	0.00	1.09	842.78	842.15	631.5	632.50	yes
12	PT-108	2	hdpe	841.70	620.24	0.010912	6.77	0.00	0.00	0.00	0.00	0.00	0.00	7.34	841.70	841.06	631.25	632.25	yes
13	PT-109	2	hdpe	834.36	200.26	0.010912	2.19	0.00	0.00	0.00	0.00	0.00	0.00	2.75	834.36	833.73	629.7	630.70	yes
14	PT-110	2	hdpe	831.60	199.99	0.010912	2.18	0.00	0.00	0.00	0.00	0.00	0.00	2.75	831.60	830.97	629.2	630.20	yes
15	PT-111	2	hdpe	828.85	185.07	0.010912	2.02	0.00	0.00	0.00	0.00	0.00	0.00	2.02	828.85	828.22	628.7	629.70	yes
16	PT-112	2	hdpe	826.83	139.94	0.010912	1.53	0.00	0.00	0.00	0.00	0.00	0.00	2.10	826.83	826.20	628.23	629.23	yes
17	PT-113	2	hdpe	824.74	110.76	0.010912	1.21	0.00	0.00	0.00	0.00	0.00	0.00	1.21	824.74	824.10	627.88	628.88	yes
18	PT-114	2	hdpe	823.53	198.12	0.010912	2.16	0.00	0.00	0.00	0.00	0.00	0.00	2.73	823.53	822.89	627.4	628.40	yes
19	PT-115	2	hdpe	820.80	99.06	0.010912	1.08	0.00	0.00	0.00	0.00	0.00	0.00	1.08	820.80	820.16	626.9	627.90	yes
20	PT-116	2	hdpe	819.72	159.85	0.010912	1.74	0.00	0.00	0.00	0.00	0.00	0.00	1.74	819.72	819.08	624.2	625.20	yes
21	PT-117	2	hdpe	817.97	672.10	0.010912	7.33	0.00	0.00	0.00	0.00	0.00	0.00	7.90	817.97	817.34	623.8	624.80	yes
22	PT-118 (bend at Eureka Road)	2	hdpe	810.07	161.79	0.010912	1.77	0.00	0.00	0.12	69.44	1.17	0.00	73.07	810.07	809.43	622.12	623.12	yes
23	PT-119	2	hdpe	737.00	309.16	0.010912	3.37	0.00	0.00	0.00	0.00	0.00	0.00	3.37	737.00	736.37	621.72	622.72	yes
24	PT-120	2	hdpe	733.63	212.59	0.010912	2.32	0.00	0.00	0.00	0.00	0.00	0.00	2.32	733.63	732.99	620.94	621.94	yes
25	PT-121	2	hdpe	731.31	86.76	0.010912	0.95	0.00	0.00	0.00	0.00	0.00	0.00	1.52	731.31	730.67	620.41	621.41	yes
26	PT-122	3	duct. iron	729.79	275.23	0.006128	1.69	0.00	0.00	0.00	0.00	0.00	0.29	2.24	729.79	729.50	603	604.00	yes
27	outfall in Ohio River			727.55											727.55	727.25	595	602.00	yes
subtotal, headloss to Proposed Control Valve Vault							62.21	0.23	7.92	0.57	0.00	0.00	0.00	70.93					
subtotal, headloss to Ohio River							72.30	0.23	9.32	0.57	0.12	69.44	1.17	153.45					

GIVEN, from JLS (back calculated to get 2.31 ft of headloss)

Point	Description	Pipeline Segment	type of pipe	Energy Head (ft)	Length of Pipeline Segment	Friction Gradient (ft/ft)	Pipe Friction (ft)	Headlosses Entrance	Bends	Tees	Shutoff Valves	Throttle Valves	Check Valves	Exit	Total Headloss (ft)	Energy Head Elevation (ft, msl)	Hydraulic Grade Elevation (ft, msl)	Invert Elevation (ft, msl)	Crown Elevation of Pipe (ft, msl)	Is Pipe Adequate to Pass Flow (v/h)
0	intake in reservoir			881.00	702.14	0.02316	16.26	0.84	1.50	0.00	0.00	0.00	0.00	0.00	18.60	881.00	879.33	877	878.00	yes
1	headwall connection at dam	1	hdpe	862.40	128.55	0.02316	2.98	0.00	1.50	0.00	0.00	0.00	0.00	0.00	4.48	862.40	860.73	876	877.00	no
2	crest at siphon vault	1	hdpe	857.92	1054.34	0.02316	24.42	0.00	6.01	0.00	0.00	0.00	0.00	0.00	30.43	857.92	856.25	881	882.00	no
3	Pigcalcher Road slope break	1	hdpe	827.49	785.06	0.02316	18.18	0.00	1.50	0.00	0.00	0.00	0.00	0.00	19.69	827.49	825.82	865	866.00	no
4	Ash Haul Road slope break	1	hdpe	807.80	64.23	0.02316	1.49	0.00	1.50	0.00	0.00	0.00	0.00	0.00	2.99	807.80	806.13	720	721.00	yes
5	PT-101 of new siphon route & connection w/ extg line	2	hdpe	804.81	54.63	0.033783	1.85	0.00	0.00	2.03	0.00	0.00	0.00	0.00	3.88	804.81	802.55	715.8	716.80	yes
6	PT-102	2	hdpe	800.93	270.37	0.033783	9.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.13	800.93	798.68	708.52	709.52	yes
7	PT-103	2	hdpe	791.80	200.05	0.033783	6.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.76	791.80	789.54	656.82	657.82	yes
8	PT-104	2	hdpe	785.04	206.38	0.033783	6.97	0.00	2.03	0.00	0.00	0.00	0.00	0.00	9.01	785.04	782.78	635	636.00	yes
9	PT-105	2	hdpe	776.04	274.70	0.033783	9.28	0.00	2.03	0.00	0.00	0.00	0.00	0.00	11.31	776.04	773.78	632.52	633.52	yes
10	PT-106	2	hdpe	764.72	135.00	0.033783	4.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.56	764.72	762.46	631.83	632.83	yes
11	PT-107	2	hdpe	760.16	99.77	0.033783	3.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.37	760.16	757.90	631.5	632.50	yes
12	PT-108	2	hdpe	756.79	620.24	0.033783	20.95	0.00	2.03	0.00	0.00	0.00	0.00	0.00	22.99	756.79	754.53	631.25	632.25	yes
13	PT-109	2	hdpe	733.80	200.26	0.033783	6.77	0.00	2.03	0.00	0.00	0.00	0.00	0.00	8.80	733.80	731.55	629.7	630.70	yes
14	PT-110	2	hdpe	725.01	199.99	0.033783	6.76	0.00	2.03	0.00	0.00	0.00	0.00	0.00	8.79	725.01	722.75	629.2	630.20	yes
15	PT-111	2	hdpe	716.22	185.07	0.033783	6.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.25	716.22	713.96	628.7	629.70	yes
16	PT-112	2	hdpe	709.96	139.94	0.033783	4.73	0.00	2.03	0.00	0.00	0.00	0.00	0.00	6.76	709.96	707.71	628.23	629.23	yes
17	PT-113	2	hdpe	703.20	110.76	0.033783	3.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.74	703.20	700.94	627.88	628.88	yes
18	PT-114	2	hdpe	699.46	196.12	0.033783	6.69	0.00	2.03	0.00	0.00	0.00	0.00	0.00	8.73	699.46	697.20	627.4	628.40	yes
19	PT-115	2	hdpe	690.74	99.06	0.033783	3.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.35	690.74	688.48	626.9	627.90	yes
20	PT-116	2	hdpe	687.39	159.85	0.033783	5.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.40	687.39	685.13	624.2	625.20	yes
21	PT-117	2	hdpe	681.99	672.10	0.033783	22.71	0.00	2.03	0.00	0.00	0.00	0.00	0.00	24.74	681.99	679.73	623.8	624.80	yes
22	PT-118 (bend at Eureka Road)	2	hdpe	657.25	161.79	0.033783	5.47	0.00	2.03	0.00	0.00	0.00	0.00	0.00	15.80	657.25	654.99	622.12	623.12	yes
23	PT-119	2	hdpe	641.45	309.16	0.033783	10.44	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.44	641.45	639.19	621.72	622.72	yes
24	PT-120	2	hdpe	631.00	212.59	0.033783	7.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.18	631.00	628.75	620.94	621.94	yes
25	PT-121	2	hdpe	623.82	86.76	0.033783	2.93	0.00	2.03	0.00	0.00	0.00	0.00	0.00	4.96	623.82	621.56	620.41	621.41	yes
26	PT-122	3	duct. iron	618.86	275.23	0.020895	5.75	0.00	0.94	0.00	0.00	0.00	0.00	1.05	7.74	618.86	617.81	603	604.00	yes
27	outfall in Ohio River			611.12												611.12	610.07	585	586.00	yes
subtotal, headloss to Proposed Control Valve Vault							192.59													
subtotal, headloss to Ohio River							224.36													

1999-170/d51/newsiphon_R4/waterhammer/klf/12/04/2002/4:30 PM/1 of 1

Pressure Rating of Pipe (12" Diameter DR 11)			
Maximum Operating Pressure in Line	160	psi	
Location with Highest Operating Pressure	93.4	psi	
Pipe Invert Elevation at PT-104	635	ft, msl	
150% Operating Pressure at PT-104	140.2	psi	
Lowest Pipe Invert Elevation on Line	622.12	ft, msl	
Location of Lowest (Invert Elevation) Point of Line	PT-118 (bend at Eureka Road)		
Operating Pressure in Line at PT-118 (bend at Eureka Road)	81.4	psi	
150% Operating Pressure at PT-118 (bend at Eureka Road)	122.2	psi	

Point	Description (Upper Siphon Pipeline)	Operating Pressure in Pipe (psi)	150% of Operating Pressure (psi)	Invert Elevation of pipe (ft, msl)	Is 150% of Operating Pressure Less Than Pipe's Pressure Rating?	Test Pressure if Pipe is Tested to a Minimum of 150% of Operating Pressure at any Point	% of Operating Pressure	Is the Test Pressure Less Than the Pipe's Pressure Rating?	Recommended Test Procedure Test Pressure if Pipe is Tested to 150% of Operating Pressure at Lowest Point on Line	% of Operating Pressure
5	PT-101 of new siphon route & connection w/ extg line	61.2	91.7	715.80	OK	105.2	172	OK	81.6	133
6	PT-102	63.8	95.7	708.52	OK	108.3	170	OK	84.8	133
7	PT-103	84.9	127.4	656.82	OK	130.7	154	OK	107.1	126
8	PT-104	93.4	140.2	635.00	OK	140.2	150	OK	116.6	125
9	PT-105	93.3	139.9	632.52	OK	141.2	151	OK	117.7	126
10	PT-106	92.1	138.1	631.83	OK	141.5	154	OK	118.0	128
11	PT-107	91.6	137.3	631.50	OK	141.7	155	OK	118.1	129
12	PT-108	91.2	136.8	631.25	OK	141.8	155	OK	118.2	130
13	PT-109	88.7	133.0	629.70	OK	142.5	161	OK	118.9	134
14	PT-110	87.7	131.6	629.20	OK	142.7	163	OK	119.1	136
15	PT-111	86.7	130.1	628.70	OK	142.9	165	OK	119.3	138
16	PT-112	86.1	129.1	628.23	OK	143.1	166	OK	119.5	139
17	PT-113	85.3	128.0	627.88	OK	143.3	168	OK	119.7	140
18	PT-114	85.0	127.5	627.40	OK	143.5	169	OK	119.9	141
19	PT-115	84.0	126.0	626.90	OK	143.7	171	OK	120.1	143
20	PT-116	84.7	127.1	624.20	OK	144.8	171	OK	121.3	143
21	PT-117	84.1	126.2	623.80	OK	145.0	172	OK	121.4	144
22	PT-118 (bend at Eureka Road)	81.4	122.2	622.12	OK	145.7	179	OK	122.2	150

LOOKUP table columns

5 PT-101 of new siphon route & connection w/ extg line
6 PT-102
7 PT-103
8 PT-104
9 PT-105
10 PT-106
11 PT-107
12 PT-108
13 PT-109
14 PT-110
15 PT-111
16 PT-112
17 PT-113
18 PT-114
19 PT-115
20 PT-116
21 PT-117
22 PT-118 (bend at Eureka Road)

Determine What Class of Pipe is Required for the New Siphon Line

REFERENCE manufacturer literature on DRISCOPE, 1000 Series

psi rating	51	64	80	100	128	160	200	267	267
DR of pipe	32.5	26	21	17	13.5	11	9	7	7
	26	21	17	13.5	11	9	7	7	0

Reservoir Water Level

Ohio River Water Level
Normal Pool Level
Maximum Static Head in Pipe
Maximum Static Pressure in Pipe
Conversion Factor

881.00 ft, msl

602.00 ft, msl

279 ft

121 psi

1 of water weighs 62.4 lbs

1 of water per sq ft = 0.433 psi

Point	Description	Static Conditions				Design Flow Conditions				Maximum Flow Conditions				Controlling Condition in Pipe	Maximum Pressure in Pipe (psi)	Minimum DR Rating of Pipe	Minimum DR Rating of Pipe
		Invert Elevation (ft, msl)	Static Pressure in Pipe (psi)	Static Head (ft)	Operating Head in Pipe (ft)	Operating Pressure in Pipe (psi)	Energy Head Elevation (ft, msl)	Operating Head in Pipe (ft)	Operating Pressure in Pipe (psi)	Water Hammer Pressure (psi)	Maximum Pressure in Pipe (psi)	Controlling Condition in Pipe	Minimum DR Rating of Pipe				
0	intake in reservoir	877.00	4.00	2	881.00	4.00	0	48	48	48	48	Waterhammer	32.5	Waterhammer	91	Waterhammer	17
1	headwall connection at dam	876.00	5.00	2	875.09	-0.91	0	48	48	48	48	Waterhammer	32.5	Waterhammer	85	Waterhammer	17
2	crest at siphon vault	881.00	0.00	0	873.71	-7.29	-3	48	45	45	45	Waterhammer	32.5	Waterhammer	81	Waterhammer	17
3	Pipealcher Road slope break	885.00	16.00	7	884.14	-0.86	0	48	48	48	48	Waterhammer	32.5	Waterhammer	75	Waterhammer	21
4	Ash Haul Road slope break	720.00	161.00	70	857.85	137.85	60	48	108	108	108	Waterhammer	13.5	Waterhammer	129	Waterhammer	11
5	PT-101 of new siphon route & connection w/ extg line	715.80	165.20	72	856.94	141.14	61	48	110	110	110	Waterhammer	13.5	Waterhammer	130	Waterhammer	11
6	PT-102	708.52	172.48	75	855.78	147.26	64	48	112	112	112	Waterhammer	13.5	Waterhammer	131	Waterhammer	11
7	PT-103	656.82	224.18	97	852.83	196.01	85	48	133	133	133	Waterhammer	11	Waterhammer	150	Waterhammer	11
8	PT-104	635.00	246.00	107	850.65	215.65	93	48	142	142	142	Waterhammer	11	Waterhammer	156	Waterhammer	11
9	PT-105	632.52	248.48	108	847.82	215.30	93	48	142	142	142	Waterhammer	11	Waterhammer	154	Waterhammer	11
10	PT-106	631.83	249.17	108	844.26	212.43	92	48	140	140	140	Waterhammer	11	Waterhammer	149	Waterhammer	11
11	PT-107	631.50	249.50	108	842.78	211.28	92	48	140	140	140	Waterhammer	11	Waterhammer	147	Waterhammer	11
12	PT-108	631.25	249.75	108	841.70	210.45	91	48	140	140	140	Waterhammer	11	Waterhammer	146	Waterhammer	11
13	PT-109	629.70	251.30	109	834.36	204.66	89	48	137	137	137	Waterhammer	11	Waterhammer	136	Waterhammer	11
14	PT-110	629.20	251.80	109	831.60	202.40	88	48	136	136	136	Waterhammer	11	Waterhammer	133	Waterhammer	11
15	PT-111	628.70	252.30	109	828.85	200.15	87	48	135	135	135	Waterhammer	11	Waterhammer	129	Waterhammer	11
16	PT-112	628.23	252.77	110	826.63	198.60	86	48	134	134	134	Waterhammer	11	Waterhammer	127	Waterhammer	13.5
17	PT-113	627.86	253.12	110	824.74	196.86	85	48	134	134	134	Waterhammer	11	Waterhammer	124	Waterhammer	13.5
18	PT-114	627.40	253.60	110	823.53	196.13	85	48	133	133	133	Waterhammer	11	Waterhammer	123	Waterhammer	13.5
19	PT-115	626.90	254.10	110	820.80	193.90	84	48	132	132	132	Waterhammer	11	Waterhammer	119	Waterhammer	13.5
20	PT-116	624.20	256.80	111	819.72	195.52	85	48	133	133	133	Waterhammer	11	Waterhammer	119	Waterhammer	13.5
21	PT-117	623.80	257.20	111	817.97	194.17	84	48	132	132	132	Waterhammer	11	Waterhammer	117	Waterhammer	13.5
22	PT-118 (bend at Eureka Road)	622.12	258.88	112	810.07	187.95	81	48	130	130	130	Waterhammer	11	Waterhammer	107	Waterhammer	13.5
23	PT-119	621.72	259.28	112	737.00	115.28	50	48	112	112	112	Static	13.5	Static	100	Static	17
24	PT-120	620.94	260.06	113	733.63	112.69	49	48	113	113	113	Static	13.5	Static	96	Static	17
25	PT-121	620.41	260.59	113	731.31	110.90	48	48	113	113	113	Static	13.5	Static	93	Static	17
26	PT-122	603.00	278.00	120	729.79	128.79	55	48	120	120	120	Static	13.5	Static	98	Static	17
	MAXIMUM PRESSURE IN PIPE		120								142				156		