McElroy's Run Impoundment Safety Factor Assessment Report

Allegheny Energy Supply Company, LLC *A FirstEnergy Company* Pleasants Power Station Pleasants County, West Virginia

October 2016

Prepared for: Allegheny Energy Supply Company, LLC *A FirstEnergy Company* 800 Cabin Hill Drive Greensburg, Pennsylvania 15601

Prepared by: GAI Consultants, Inc. Murrysville Office 4200 Triangle Lane Export, Pennsylvania 15632-1358

Table of Contents

Certif	ication/	'Statem	ent of Professional Opinion	i						
1.0	Purpos	se		1						
2.0	Introduction1									
3.0	Factor of Safety Assessment13.1Long-Term Maximum Storage Pool Loading Condition23.2Maximum Surcharge Pool Loading Condition23.3Seismic Factor of Safety23.4Liquefaction Factor of Safety2									
4.0	Conclu	ision		3						
5.0	Refere	nces		1						
Appendix A Appendix A-3.1 Appendix A-3.2 Appendix A-3.3 Appendix A-3.4		3.1 3.2 3.3 3.4	Calculations Long-Term Maximum Storage Pool Loading Condition Maximum Surcharge Pool Loading Condition Seismic Factor of Safety Liquefaction Factor of Safety							

© 2016 GAI CONSULTANTS



Certification/Statement of Professional Opinion

The Safety Factor Assessment (Assessment) Report for the McElroy's Run Impoundment was prepared by GAI Consultants, Inc. (GAI). The Assessment Report was based on certain information that, other than for information GAI originally prepared, GAI has relied on, but not independently verified. Therefore, this Certification/Statement of Professional Opinion is limited to the information available to GAI at the time the Assessment Report was written. On the basis of and subject to the foregoing, it is my professional opinion as a Professional Engineer licensed in the State of West Virginia (WV), that the Assessment has been prepared in accordance with good and accepted engineering practices, as exercised by other engineers practicing in the same discipline(s), under similar circumstances, and at the time and in the same locale. It is my professional opinion that this Safety Factor Assessment was prepared consistent with the requirements of the United States Environmental Protection Agency's Federal Coal Combustion Residuals (CCR) Rule 40 CFR § 257.73(e), published in the Federal Register on April 17, 2015 with an effective date of October 19, 2015.

The use of the words "certification" and/or "certify" in this document shall be interpreted and construed as a Statement of Professional Opinion and is not and shall not to be interpreted or construed as a guarantee, warranty or legal opinion.

Arica L. DiTullio, P.E. Engineering Manager





1.0 Purpose

Pursuant to the Federal Coal Combustion Residuals (CCR) Rule 40 CFR § 257.73(e)(1)(i-iv), each CCR impoundment is required to conduct an initial and periodic safety factor assessment to determine whether the CCR unit achieves the minimum safety factors at the critical cross section of the embankment. The critical cross section is the cross section anticipated to be the most susceptible of all cross sections to structural failure based on appropriate engineering considerations including loading conditions.

2.0 Introduction

The Pleasants Power Station (Station) is a coal-fired electric generating station located near the community of Willow Island in Pleasants County, West Virginia (WV). The Station consists of two generating units, which are capable of producing 1,300 megawatts of electricity.

CCRs generated at the Station are placed in the McElroy's Run CCR surface impoundment (Impoundment), which is located approximately one-half mile east-southeast of the Station. The Impoundment is a captive facility that receives flue gas desulfurization scrubber by-product generated at the Station, effluent from the recirculation system through Sedimentation Ponds 1 and 2 of the adjacent landfill and their underdrains, and waste materials collected primarily because of general house-cleaning maintenance and/or repair at the Pleasants Station.

The dam of the Impoundment is approximately 243 feet (ft) high with a maximum storage of approximately 20,000 acre-ft. The crest of the dam is at elevation (El.) 900 ft, with El. 887.00 ft as the permitted final level of CCR and recommended normal operating pool level. The Impoundment area is approximately 253 acres.

3.0 Factor of Safety Assessment

GAI reviewed all the documents listed under the References (Section 5.0) in its assessment to determine if the impoundment meets the following safety factors:

- i. (3.1) The calculated static factor of safety under the long-term, maximum storage pool loading condition must equal or exceed 1.50.
- ii. (3.2) The calculated static factor of safety under the maximum surcharge pool loading condition must equal or exceed 1.40.
- iii. (3.3) The calculated seismic factor of safety must equal or exceed 1.00.
- iv. (3.4) For dikes constructed of soils that are susceptible to liquefaction, the calculated liquefaction factor of safety must equal or exceed 1.20.

The stability assessments were evaluated using the Slope/W software package (GeoStudio 2007, version 7.15 by GeoSlope International). All analyses were conducted using the Bishop Method. The critical section is shown on Drawing APSC 506-190 (see Appendix A-3.1). The material strength parameters used in the analyses were obtained from a response to EPA comments letter written by GAI in 2010. These parameters were developed based on previous subsurface explorations, laboratory testing, and engineering judgement. The phreatic surface used in the analyses was based on water level readings taken from embankment piezometers.

All calculations are included in Appendix A.



3.1 Long-Term Maximum Storage Pool Loading Condition

Pursuant to the CCR Rule, the maximum storage pool loading is, "the maximum water level that can be maintained that will result in full development of a steady-state seepage condition." Additionally, "the maximum storage pool loading needs to consider a pool elevation in the CCR unit that is equivalent to the lowest elevation of the invert of the spillway, i.e., the lowest overflow point of the perimeter of the embankment." (emergency spillway)

The principal spillway riser structure has a two-foot-by-two-foot opening at El. 890 ft. The spillway maintains an operational sluice gate at El. 885 ft, which is kept closed. Therefore, the long-term maximum storage pool loading condition will have a water elevation of 890 ft (GAI Inflow Design Plan). The CCR material in the Impoundment was permitted to an elevation of 887 ft. The calculated factor of safety is 1.89, which exceeds the requirement for the long term maximum storage pool condition (1.50).

3.2 Maximum Surcharge Pool Loading Condition

The maximum surcharge pool loading condition is based on the inflow design flood, which is the probable maximum flood (PMF). The maximum water surface elevation during the PMF is 894.8 ft. This water elevation corresponds to a water depth in the emergency spillway of 1.3 ft. The CCR material in the Impoundment was set at elevation 887 ft, which corresponds to the maximum permitted level. The calculated factor of safety is 1.89, which exceeds the requirement for the maximum surcharge pool condition (1.40).

3.3 Seismic Factor of Safety

The seismic factor of safety is run with a seismic loading event with a 2 percent probability of exceedance in 50 years, based on the United States Geological Survey (USGS) seismic hazard maps. A peak ground acceleration of 0.1g (acceleration of gravity) was used in the analysis. This value was obtained from a response to an EPA comments letter written by GAI in 2010.

The seismic condition was conducted using the long-term maximum storage pool loading condition. This represents a conservative analysis, as there is a reasonable chance this situation could occur, and it results in full development of the steady-state seepage condition. The calculated factor of safety is 1.36, which exceeds the requirement for a seismic event (1.00).

3.4 Liquefaction Factor of Safety

In 2010, GAI conducted a liquefaction analysis of the foundation soils. The soils underneath the Impoundment were found not to be susceptible to liquefaction. A corresponding analysis in 2010 was conducted on the compacted fly ash in the embankment. The three boring locations analyzed were CP-9, CP-11, and CP-13. CP-9 and CP-13 did not have a groundwater table and the blow counts (i.e. N-value) in the fly ash exceeded 30. According to "Liquefaction Resistance of Soils: Summary Report from the 1996 NCEER and 1998 NCEER/NSF Workshops on Evaluation of Liquefaction Resistance of Soils, 2001," soils with blow counts exceeding 30 are not susceptible to liquefaction. Based on this report, the downstream portion of the embankment is not susceptible to liquefaction.

In 2016, a modification to the 2010 liquefaction analysis on CP-9 was conducted in order to analyze the embankment with a water level. The Station collects data for the piezometers located in and around the embankment. Highest water elevations in the center of the embankment are located in the bottom ash blanket. Boring log data is unavailable for the piezometers located in the centerline of the embankment. Therefore, to complete the liquefaction analysis, CP-9 boring data was used based on proximity to the centerline of the embankment. The liquefaction analysis was performed using the "Simplified Procedure". The highest water level recorded over the past year in CP-1A, CP-4, and CP-6 was applied to the analysis for CP-9 to determine the susceptibility to liquefaction. The analysis



determined that the embankment liquefaction minimum factor of safety is 8.50, which exceeds the requirement of 1.20 for liquefaction.

4.0 Conclusion

GAI reviewed previous stability analyses for this Safety Factor Assessment and conducted new analyses in order to meet the requirements of the CCR Rule. Based on the analyses conducted for the conditions outlined in the CCR Rule, the McElroy's Run impoundment meets or exceeds the required factors of safety.



5.0 References

GAI Consultants. Inflow Design Flood Control System Plan. January 2016.

- GAI Consultants. Liquefaction Evaluation & Analysis. June 2016.
- GAI Consultants. *Responses to Address the Recommendations of the EPA Concerning Pleasants Power Station (McElroy's Run CCB Disposal Site).* Rep. N.p.: n.p., 2010.
- GAI Consultants. *Sludge Stabilization Facility: McElroy's Run Disposal Site As-Built Construction Sequence*. Drawing APSC 506-190.
- *Liquefaction Resistance of Soils: Summary Report,* from the 1996 NCEER and 1998 NCEER/NSF Workshops on Evaluation of Liquefaction Resistance of Soils, 2001.



APPENDIX A Calculations



APPENDIX A-3.1 Long-Term Maximum Storage Pool Loading Condition





	G	H	1		J	K	L
					ASH	EMBANKMENT	
		E	1.884	EL.885		CREDI EL	
		EL. 869	EL. 875~			2	
	EL 857	T	\sim	988		EL.85	BEN 5
EL 836	L826.5	1984			EL.	834	1991 El 804
982	1983	EL 814.5	EL	822			1990
			191	34		Ren	1987
							EL. 78
		1981	10	82			EL 757
CEL. 730	1980		EL.734			1982	
			CEL.	123 EL 719			
		1979			1980		EL. 698
		=10-					<u></u>
OP OF ROCK						l'a Bali.	
			TYPICAL	TRANS	VER	SE SECT	FION
				SCAL	E: $1^{11} = 40^{11}$		
				40' 0	40'	80'	
						X	
						k (
da da "							
					*		
							CONSULTANTS, INC. Engineers - Geologists - Planners Environmental Specialists 570 Bestty Rd Pittsburgh
							Monroeville, Pa. 15146 412-856-6400



J. NO	01-207
NO	81-237-

PLEASANTS POWER STATION McELROY'S RUN CCB DISPOSAL FACILITY LONG TERM MAXIMUM STORAGE POOL LOADING CONDITION

EMERGENCY SPILLWAY ELEVATION: 893.5-FT WATER ELEVATION 890-FT CCR ELEVATION 887-FT



Name: Compacted Silty Clay Unit Weight: 132.9 pcf Cohesion: 228 psf Phi: 26.8 ° Name: In Situ Silty Clay to Clayey Silt and Rock Fragments Unit Weight: 127.8 pcf Cohesion: 49 psf Phi: 24.8 ° Name: Soft Broken Claystone Unit Weight: 135 pcf Cohesion: 1238 psf Phi: 32 ° Name: Interbedded Siltstone, Sandstone and Claystone Name: Compacted Fly Ash Unit Weight: 113.1 pcf Cohesion: 0 psf Phi: 29.7 ° Name: Bottom Ash Filter Blanket Unit Weight: 110 pcf Cohesion: 0 psf Phi: 35 ° Name: Impoundment Sludge Unit Weight: 70 pcf Cohesion: 0 psf Phi: 0.1 °

APPENDIX A-3.2 Maximum Surcharge Pool Loading Condition



PLEASANTS POWER STATION McELROY'S RUN CCB DISPOSAL FACILITY MAXIMUM SURCHARGE POOL LOADING CONDITION



Name: Compacted Silty Clay Unit Weight: 132.9 pcf Cohesion: 228 psf Phi: 26.8 ° Name: In Situ Silty Clay to Clayey Silt and Rock Fragments Unit Weight: 127.8 pcf Cohesion: 49 psf Phi: 24.8 ° Name: Soft Broken Claystone Unit Weight: 135 pcf Cohesion: 1238 psf Phi: 32 ° Name: Interbedded Siltstone, Sandstone and Claystone Name: Compacted Fly Ash Unit Weight: 113.1 pcf Cohesion: 0 psf Phi: 29.7 ° Name: Bottom Ash Filter Blanket Unit Weight: 110 pcf Cohesion: 0 psf Phi: 35 ° Name: Impoundment Sludge Unit Weight: 70 pcf Cohesion: 0 psf Phi: 0.1 °

> Horizontal Scale: 2400 Vertical Scale: 2400

APPENDIX A-3.3 Seismic Factor of Safety



PLEASANTS POWER STATION McELROY'S RUN CCB DISPOSAL FACILITY SEISMIC LONG TERM MAXIMUM STORAGE POOL LOADING CONDITION



Name: Compacted Silty ClayUnit Weight: 132.9 pcfCohesion: 228 psfPhi: 26.8 °Name: In Situ Silty Clay to Clayey Silt and Rock FragmentsUnit Weight: 127.8 pcfCohesion: 49 psfPhi: 24.8 °Name: Soft Broken ClaystoneUnit Weight: 135 pcfCohesion: 1238 psfPhi: 32 °Name: Interbedded Siltstone, Sandstone and ClaystoneName: Compacted Fly AshUnit Weight: 113.1 pcfCohesion: 0 psfPhi: 29.7 °Name: Bottom Ash Filter BlanketUnit Weight: 110 pcfCohesion: 0 psfPhi: 35 °Name: Impoundment SludgeUnit Weight: 70 pcfCohesion: 0 psfPhi: 0.1 °

APPENDIX A-3.4 Liquefaction Factor of Safety



SUBJECT: F	PLEASANTS POWER STATION	– McELROY'S F	RUN CCR		<u>í</u> •
IMPOUNDMENT -	LIQUEFACTION EVALUATION	& ANALYSIS			
BY <u>TIM</u>	DATE 06/06/16	PROJ. NO.	C150917.01		v j
CHKD. BY <u>KRH</u>	DATE <u>6/16/16</u>	SHEET NO.	0F	26	gai consultants

OBJECTIVE:

To evaluate the liquefaction resistance for the existing McElroy's Run Coal Combustion Residual (CCR) embankment at the Pleasants Power Station, Pleasants County, West Virginia.

METHODOLOGY:

Evaluate existing subsurface conditions in conjunction with the highest observed temporal phreatic surfaces to determine if liquefaction analyses are required. Field test data gathered from Standard Penetration Tests (SPT) are used to quantify the factor of safety against liquefaction (FS_L) during a design earthquake of magnitude 6.1 using the "Simplified Procedure for Evaluating Liquefaction Potential".

REFERENCES:

- 1. Liquefaction Resistance of Soils: Summary Report from the 1996 NCEER and 1998 NCEER/NSF Workshops on Evaluation of Liquefaction Resistance of Soils, 2001.
- 2. MSHA Manual on Coal Waste Embankments, Chapter 7 Seismic Design: Stability and Deformation Analyses, May 2009.
- 3. GAI Consultants Inc., 2010. Responses to Address the Recommendations of the EPA Concerning Pleasants Power Station (McElroy's Run CCB Disposal Site). December 22, 2010.
- 4. United States Geological Survey, Earthquake Hazards Program, National Seismic Hazard Mapping Project (2008).
- 5. United States Environmental Protection Agency, 2015. *40 CFR Parts 257 and 261 Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule.* April 17, 2015.

ANALYSIS:

The CCR Rule (Section 257.73(e)(1)(iv)) states "for dikes constructed of soils that have susceptibility to liquefaction, the calculated liquefaction factor of safety must equal or exceed 1.20".

To evaluate liquefaction potential of the embankment, the site stratigraphy must be understood with respect to soil classification, groundwater conditions, overburden and age of the soil deposits. Information from site visits and previous subsurface investigations conducted for the project site were employed to determine the site conditions for liquefaction evaluation. The following paragraphs explain the methodology used in this analysis.

A previous GAI report (Reference 3) determined that the downstream portion of the embankment met the target factor of safety for liquefaction. Piezometer readings show that there is a phreatic surface through the centerline of the embankment (CP-1A, CP-4, and CP-6).

SUBJECT: I	PLEASANTS POWER STATION - LIQUEFACTION EVALUATION &	MCELROY'S I	RUN CCR		(:
BY <u>TIM</u>	DATE06/06/16	PROJ. NO	C150917.01		y
CHKD. BY <u>KRH</u>	DATE <u>6/16/16</u>	SHEET NO.	OF	26	gai consultants

Since piezometers in the centerline of the embankment were installed as the embankment height increased due to placement of CCR, there is no SPT data to evaluate the liquefaction potential of the central part of the embankment. Therefore, CP-9 was selected as it best represents the typical cross section of the embankment. The boring logs show that most of the embankment is constructed of CCR material (i.e. fly ash). The crest of the embankment is at elevation 900 feet, while the boring log for CP-9 shows a ground surface elevation of 875 feet. From 875 feet to 900 feet, the embankment was built from compacted CCR. For a thorough analysis each individual soil interval in the boring log was evaluated for liquefaction resistance.

Reviewing the piezometer data for the past year (June 2015-May 2016), the highest recorded phreatic surface was 743.7 feet in CP-6. . According to the Reference 3, CCR material was placed and compacted to a unit weight of 113.1 pcf.

To determine the potential for liquefaction using the "Simplified Procedure", SPT blow counts were used in conjunction with a design earthquake event having a magnitude 6.1. The earthquake magnitude was obtained from Reference 4.

The following steps, and associated equations, were used to determine factors of safety against liquefaction (FS_L) in accordance with the "Simplified Procedure". Since each individual soil interval was analyzed, a spreadsheet was used to facilitate FS_L calculations for the analyzed boring. Copies of the spreadsheets is included in Attachment 1 of the report.

- Step 1: Develop cross-section including soil properties, layer geometry, groundwater elevation, and average N-values for the analysis (Refer to stability analyses for typical crosssections).
- Step 2: Determine SPT blow count correction factors for the energy ratio (C_E), borehole diameter (C_B), rod length (C_R), and sampling method (C_S) as shown in Table 2 of Reference 1. For the drilling program, safety hammers or automatic trip hammers were used on all of the rigs ($C_E = 0.7$ -- conservative value); hollow stem augers with a diameter of approximately 3.25 inches were used for all of the holes ($C_B=1.0$); standard split-spoon samplers without liners were advanced in all the holes ($C_S=1.0$); and rod lengths up to approximately 25-feet were used.
- Step 3: Calculate standard blow counts, N₆₀, by multiplying the field measured N-values by the correction factors determined in Step 2.
- Step 4: Determine the effective vertical stress (σ_{vo} ') for existing in-situ soil conditions at each test depth as follows:

 $\sigma_{vo}' = \gamma_T \times z \qquad \text{if the test depth, z, is above the water table depth, h} \\ \sigma_{vo}' = (\gamma_{sat} - \gamma_w) \times (z - h) + \gamma_T \times h \qquad \text{if z>h}$

Step 5: Determine overburden pressure correction factor (C_N) for each test depth from Table 2 in Reference 1, with $P_a = 1.04$ tsf:

SUBJECT:	PLEASANTS POWER STATION	<u>í</u> •		
BY <u>TIM</u>	DATE06/06/16	PROJ. NO	C150917.01	_ Y
CHKD. BY <u>KRH</u>	DATE <u>6/16/16</u>	SHEET NO.	OF2	gai consultants

$$C_N = \sqrt{\frac{P_a}{\sigma_{vo}}},$$

 C_N shall be limited to 1.7

- Step 6: Determine the design total vertical stress and the design effective vertical stresses at each test depth using the fly ash impoundment and/or fly ash embankment overburden. Unit weight for embankment fill and CCR material are based off values from Reference 4.
- Step 7: Determine SPT blow counts normalized to overburden pressure, $(N_1)_{60} = N_{60}*C_N$
- Step 8: Correct for fines content, by applying fines correction coefficients to (α and β) to (N₁)₆₀. Fines contents of the CCR were quantified by laboratory testing. To be conservative, a fines contents were based off of minimal values from lab data provided in Reference 3. If multiple soil layers were encountered in a boring, the minimum value for fines was used. Using Eq. 5 from Ref. 1:

$$(N_1)_{60cs} = \alpha + \beta (N_1)_{60}$$

Step 9: Determine the stress reduction factor, rd. (Reference 1)

$$(r_d) = 1.0 - 0.00765z \text{ for } z \le 9.15 \text{ m}$$

or
$$(r_d) = 1.174 - 0.0267z \text{ for } z \le 9.15 \text{ m} \le 23 \text{ m}$$

or
$$(r_d) = \frac{(1.000 - 0.4113z^{0.5} + 0.04052z + 0.001753z^{1.5})}{(1.000 - 0.4177z^{0.5} + 0.05729z - 0.006205z^{1.5} + 0.001210z^2)} \text{ for } z > 23 \text{ m}$$

z is in meters

Step 10: Calculate the Cyclic Stress Ratio (CSR) using $a_{max} = 0.1g$, historic value for the site:

$$CSR = \left(\frac{0.65 \times a_{\max}}{g}\right) \times r_d \times \left(\frac{\sigma_{vo}}{\sigma_{vo}'}\right)$$

Step 11: Determine the Cyclic Resistance Ratio (CRR) for an earthquake of magnitude 6.1 based on the $(N_1)_{60cs}$ values (For $(N_1)_{60cs} < 30$).

$$CRR_{7.5} = \frac{1}{34 - (N_1)_{60}} + \frac{(N_1)_{60}}{135} + \frac{50}{(10 \times (N_1)_{60} + 45)^2} - \frac{1}{200}$$

Step 12: Calculate the earthquake Magnitude Scaling Factor (MSF) based on recommendations by Idriss for engineering practice, (Reference 1):

SUBJECT: PLEAS	SANTS POWER STATION EFACTION EVALUATION	<u>N – McELROY'S F</u> N & ANALYSIS	RUN CCR	(:
BY <u>TIM</u>	DATE <u>06/06/16</u>	_ PROJ. NO	C150917.01	y
CHKD. BY <u>KRH</u>	DATE <u>6/16/16</u>	_ SHEET NO	4_OF_26	gai consultants

Step 13: Calculate K_{σ} based on Reference 1,

$$K_{\sigma} = (\sigma'_{vo} / P_a)^{(f-1)}$$

where f = 0.6 for relative densities greater than or equal to 80%, f = 0.7 for relative densities greater than 40% but less than 80% and f = 0.8 for relative densities less than 40%.

Step 14: Calculate the corrected Cyclic Resistance Ratio using the previously determined correction factors and CRR_{7.5}.

$$CRR = K_{\sigma} \times K_{\alpha} \times CRR_{7.5}$$

Where K_{α} = 1 based on recommendations from Reference 1

Step 15: Calculate the factor of safety against liquefaction, FSL.

$$FS_{L} = \frac{CRR}{CSR} \times MSF$$

SUMMARY:

Materials in the embankment consisted of compacted CCR material. SPT data from the borings were used to analyze the potential for liquefaction resulting from a design earthquake with magnitude of 6.1, using the "Simplified Procedure".

To be conservative, each individual soil interval in the analysis section boring was evaluated for liquefaction potential. Results of the analyses for borings in the embankment exceed the minimum 1.20 factor of safety required in the CCR Rule (Section 257.73(e)(1)(iv)).



ATTACHMENT 1

$\textbf{FS}_{L} \textbf{ SPREADSHEETS}$

G	ente						BORI	NG CP-9				Plea McElroy's Liq	FirstEner sants Powe Run CCR uefaction A	rgy er Station Impoundmo Analysis	ent									C	2150917.01.003 By: TIM 06/1 d by: KRH 06/1 6/26
Jai consulta	G.S. Ele	v. = 875.0)				W.T. Elev. =	743.7	I	Bottom of C	CCR Elev. =	705.0		Fine	es Content =	91	Based on co	mposite sample	e (CP-9,11,1	12,13,14)	Atmosphe	ric Pressure	100	kPa	
	Yoverburd	_n = 113.1	(pcf)							Top of C	CR Elev. =	900.0		Relati	ve Density=	35%							1.04	tsf	
	γ₅ γοα	_{at} = 118.1 _R = 113.1	(pcf)	Tat	ole 2 ⁽¹⁾		Est. EQ Mag	6.1		Eq. (9) ⁽¹⁾			Eq. (8) ⁽¹⁾	Eq. (6) ⁽¹⁾	f= Eq. (7) ⁽¹⁾	0.8 Eq. (5) ⁽¹⁾	Eq. (2) ⁽¹⁾		Eq. (1) ⁽¹⁾	Eq. (4) ⁽¹⁾	Eq. (24) ⁽¹⁾	Eq. (31) ⁽¹⁾			Eq. (30) ⁽¹⁾
Test Depth (m) (ft)	th N	C _E	C _B	Cs	C _R	N ₆₀	Test Elev. (ft MSL)	Existing σ' _{vo} (tsf)	C _N	Design σ _{vo} (tsf)	Design σ _{vo} ' (tsf)	(N ₁) ₆₀	α	β	(N ₁) _{60cs}	r _d	a _{max}	CSR	CRR _{7.5}	MSF	K _σ	K _α	CRR	FSL
0.5	1.5	6	0.7	1.0	1.0	0.75	3	873.5	0.08	1.70	1.50	1.50	5	5	1.2	11	1.00	0.1	0.065	0.12	1.7	0.93	1.00	0.11	-
2.0	6.5	2	0.7	1.0	1.0	0.75	1	868.5	0.37	1.68	1.78	1.78	2	5	1.2	7	0.98	0.1	0.064	0.09	1.7	0.90	1.00	0.08	-
3.5	11.5	3	0.7	1.0	1.0	0.80	2	863.5	0.65	1.26	2.06	2.06	3	5	1.2	9	0.97	0.1	0.063	0.10	1.7	0.87	1.00	0.09	-
5.0	16.5	4	0.7	1.0	1.0	0.85	2	858.5	0.93	1.06	2.35	2.35	2	5	1.2	7	0.96	0.1	0.062	0.09	1.7	0.85	1.00	0.08	-
6.6	21.5	2	0.7	1.0	1.0	0.95	1	853.5	1.22	0.92	2.63	2.63	1	5	1.2	6	0.95	0.1	0.062	0.08	1.7	0.83	1.00	0.07	-
8.1	26.5	2	0.7	1.0	1.0	0.95	5 1	848.5	1.50	0.83	2.91	2.91	1	5	1.2	6	0.94	0.1	0.061	0.08	1.7	0.81	1.00	0.06	-
9.6	31.5	21	0.7	1.0	1.0	0.95	14	843.5	1.78	0.76	3.20	3.20	11	5	1.2	18	0.92	0.1	0.060	0.19	1.7	0.80	1.00	0.15	-
11.1	36.5	22	0.7	1.0	1.0	1.00	15	838.5	2.06	0.71	3.48	3.48	11	5	1.2	18	0.88	0.1	0.057	0.19	1.7	0.79	1.00	0.15	-
12.6	41.5	11	0.7	1.0	1.0	1.00	8	833.5	2.35	0.67	3.76	3.76	5	5	1.2	11	0.84	0.1	0.055	0.12	1.7	0.77	1.00	0.09	-
14.2	46.5	18	0.7	1.0	1.0	1.00	13	828.5	2.63	0.63	4.04	4.04	8	5	1.2	15	0.79	0.1	0.051	0.16	1.7	0.76	1.00	0.12	-
15.7	51.5	7	0.7	1.0	1.0	1.00	5	823.5	2.91	0.60	4.33	4.33	3	5	1.2	9	0.75	0.1	0.049	0.10	1.7	0.75	1.00	0.08	-
17.2	56.5	22	0.7	1.0	1.0	1.00	15	818.5	3.20	0.57	4.61	4.61	9	5	1.2	16	0.71	0.1	0.046	0.17	1.7	0.74	1.00	0.13	-
18.7	61.5	54	0.7	1.0	1.0	1.00	38	813.5	3.48	0.55	4.89	4.89	21	5	1.2	30	0.67	0.1	0.044	0.47	1.7	0.73	1.00	0.34	-
20.3	00.0	17	0.7	1.0	1.0	1.00		808.5	3.70	0.53	5.17	5.17	0	5 F	1.2	12	0.63	0.1	0.041	0.13	1.7	0.73	1.00	0.09	-
21.8	71.5	47	0.7	1.0	1.0	1.00	50	803.5 709.5	4.04	0.51	5.40	5.40	17	5	1.2	30	0.59	0.1	0.038	0.47	1.7	0.72	1.00	0.34	-
23.3	81.5	31	0.7	1.0	1.0	1.00	22	798.5	4.55	0.49	5.74	5.74 6.02	10	5	1.2	17	0.50	0.1	0.035	0.47	1.7	0.71	1.00	0.33	-
24.0	86.5	23	0.7	1.0	1.0	1.00	16	788.5	4.01	0.47	6.31	6.31	7	5	1.2	17	0.54	0.1	0.034	0.10	1.7	0.70	1.00	0.13	
27.8	91.3	93	0.7	1.0	1.0	1.00	65	783.7	5 16	0.40	6.58	6.58	29	5	1.2	30	0.55	0.1	0.034	0.14	1.7	0.69	1.00	0.32	
29.4	96.5	91	0.7	1.0	1.0	1.00	64	778.5	5 46	0.40	6.87	6.87	28	5	1.2	30	0.51	0.1	0.033	0.47	1.7	0.69	1.00	0.32	-
30.9	101.5	80	0.7	1.0	1.0	1.00	56	773.5	5 74	0.43	7 15	7 15	24	5	1.2	30	0.50	0.1	0.033	0.47	1.7	0.68	1.00	0.32	-
32.3	105.9	73	0.7	1.0	1.0	1.00	51	769.1	5.99	0.42	7.40	7.40	21	5	1.2	30	0.49	0.1	0.032	0.47	1.7	0.68	1.00	0.32	-
34.0	111.5	37	0.7	1.0	1.0	1.00	26	763.5	6.31	0.41	7.72	7.72	11	5	1.2	18	0.48	0.1	0.031	0.19	1.7	0.67	1.00	0.13	-
35.4	116.3	82	0.7	1.0	1.0	1.00	57	758.7	6.58	0.40	7.99	7.99	23	5	1.2	30	0.47	0.1	0.031	0.47	1.7	0.67	1.00	0.31	-
37.0	121.5	86	0.7	1.0	1.0	1.00	60	753.5	6.87	0.39	8.28	8.28	23	5	1.2	30	0.47	0.1	0.031	0.47	1.7	0.66	1.00	0.31	-
38.6	126.5	72	0.7	1.0	1.0	1.00	50	748.5	7.15	0.38	8.57	8.57	19	5	1.2	30	0.46	0.1	0.030	0.47	1.7	0.66	1.00	0.31	-
40.1	131.5	50	0.7	1.0	1.0	1.00	35	743.5	7.43	0.37	8.85	8.84	13	5	1.2	21	0.46	0.1	0.030	0.23	1.7	0.65	1.00	0.15	8.50
41.6	136.5	79	0.7	1.0	1.0	1.00	55	738.5	7.57	0.37	9.15	8.98	20	5	1.2	29	0.45	0.1	0.030	0.41	1.7	0.65	1.00	0.27	15.30
43.1	141.5	81	0.7	1.0	1.0	1.00	57	733.5	7.71	0.37	9.44	9.12	21	5	1.2	30	0.44	0.1	0.030	0.47	1.7	0.65	1.00	0.31	17.57
44.7	146.5	70	0.7	1.0	1.0	1.00	49	728.5	7.85	0.36	9.74	9.26	18	5	1.2	27	0.44	0.1	0.030	0.34	1.7	0.65	1.00	0.22	12.47
46.2	151.5	75	0.7	1.0	1.0	1.00	53	723.5	7.99	0.36	10.03	9.40	19	5	1.2	28	0.43	0.1	0.030	0.37	1.7	0.64	1.00	0.24	13.60
47.7	156.5	63	0.7	1.0	1.0	1.00	44	718.5	8.13	0.36	10.33	9.54	16	5	1.2	24	0.43	0.1	0.030	0.27	1.7	0.64	1.00	0.17	9.63
49.2	161.5	64	0.7	1.0	1.0	1.00	45	713.5	8.27	0.35	10.62	9.68	16	5	1.2	24	0.43	0.1	0.031	0.27	1.7	0.64	1.00	0.17	9.32
50.7	166.5	66	0.7	1.0	1.0	1.00	46	708.5	8.41	0.35	10.92	9.82	16	5	1.2	24	0.42	0.1	0.030	0.27	1.7	0.64	1.00	0.17	9.63
51.7	169.5	70	0.7	1.0	1.0	1.00	49	705.5	8.49	0.35	11.09	9.90	17	5	1.2	25	0.42	0.1	0.031	0.29	1.7	0.64	1.00	0.19	10.42

ot present in a layer, then FS_L w

Notes:

 σ'_{vo} Vertical Effective Stress (tons/ft²)

(N1)60 Standardized and Normalized SPT blow counts (blows/foot)

- r_d Stress Reduction Factor (dimensionless)
- a_{max} Peak horizontal ground surface acceleration (in g)
- CSR Cyclic stress ratio based on design earthquake (dimensionless)
- CRR_{7.5} Cyclic resistance ratio based on an earthquake of magnitude 7.5 (dimensionless)
- MSF Magnitude scaling factor (dimensionless)
- K_{σ} High overburden stress correction factor (dimensionless)
- K_{α} Ground slope correction factor (dimensionless) [advised not to be used by reference]
- CRR Corrected cyclic resistance ratio based on overburden pressure and ground surface slope (dimensionless) = CRR7.5 * Ko * Ko

FS_L Factor of safety against liquefaction (dimensionless)

References: (1) Liquefaction Resistance of Soils: Summary Report from the 1996 NCEER and 1998 NCEER/NSF Workshops on Evaluation of Liquefaction Resistance of Soils, 2001

(2) MSHA Manual on Coal Waste Embankments, Chapter 7 Seismic Design: Stability and Deformation Analyses, May 2009



ATTACHMENT 2

REFERENCES

Evaluation of soil liquefaction resistance is an important aspect of geotechnical engineering practice. To update and enhance criteria that are routinely applied in practice, workshops were convened in 1996 and 1998 to gain consensus from 20 experts on updates and augmentations that should be made to standard procedures that have evolved over the past 30 years. At the outset, the goal was to develop this state-of-the-art summary of consensus recommendations. A commitment was also made to those who participated in the workshops that all would be listed as co-authors. Unfortunately, the previous publication of this summary paper (April 2001) listed only the co-chairs of the workshop, Profs. Youd and Idriss, as authors; the remaining workshop participants were acknowledged in a footnote. In order to correct this error and to fully acknowledge and credit those who significantly contributed to the work, this paper is being republished in its entirety, at the request of the journal's editors, with all the participants named as co-authors. All further reference to this paper should be to this republication. The previous publication should no longer be cited. Also, several minor errors are corrected in this republication.

LIQUEFACTION RESISTANCE OF SOILS: SUMMARY REPORT FROM THE **1996 NCEER AND 1998 NCEER/NSF WORKSHOPS ON EVALUATION** OF LIQUEFACTION RESISTANCE OF SOILS^a

By T. L. Youd,¹ Chair, Member, ASCE, I. M. Idriss,² Co-Chair, Fellow, ASCE, Ronald D. Andrus,³ Ignacio Arango,⁴ Gonzalo Castro,⁵ John T. Christian,⁶ Richardo Dobry,⁷ W. D. Liam Fifin,⁸ Leslie F. Harder Jr.,⁹ Mary Ellen Hynes,¹⁰ Kenji Ishihara,¹¹ Joseph P. Koester,¹² Sam S. C. Liao,¹³ William F. Marcuson III,¹⁴ Geoffrey R. Martin,¹⁵ James K. Mitchell,¹⁶ Yoshiharu Moriwaki,¹⁷ Maurice S. Power,¹⁸ Peter K. Robertson,¹⁹ Raymond B. Seed,²⁰ and Kenneth H. Stokoe II²¹

ABSTRACT: Following disastrous earthquakes in Alaska and in Nijgata, Japan in 1964, Professors H. B. Seed and I. M. Idriss developed and published a methodology termed the "simplified procedure" for evaluating liquefaction resistance of soils. This procedure has become a standard of practice throughout North America and much of the world. The methodology which is largely empirical, has evolved over years, primarily through summary papers by H. B. Seed and his colleagues. No general review or update of the procedure has occurred, however, since 1985, the time of the last major paper by Professor Seed and a report from a National Research Council workshop on liquefaction of soils. In 1996 a workshop sponsored by the National Center for Earthquake Engineering Research (NCEER) was convened by Professors T. L. Youd and I. M. Idriss with 20 experts to review developments over the previous 10 years. The purpose was to gain consensus on updates and augmentations to the simplified procedure. The following topics were reviewed and recommendations developed: (1) criteria based on standard penetration tests; (2) criteria based on cone penetration tests; (3) criteria based on shear-wave velocity measurements; (4) use of the Becker penetration test for gravelly soil; (4) magnitude scaling factors; (5) correction factors for overburden pressures and sloping ground; and (6) input values for earthquake magnitude and peak acceleration. Probabilistic and seismic energy analyses were reviewed but no recommendations were formulated.

This Summary Report, originally published in April 2001, is being republished so that the contribution of all workshop participants as authors can be officially recognized. The original version listed only two authors, plus a list of 19 workshop participants. This was incorrect; all 21 individuals should have been identified as authors. ASCE deeply regrets the error.

- ¹Prof., Brigham Young Univ., Provo, UT 84602.
- ²Prof., Univ. of California at Davis, Davis, CA 95616.
- ³Prof., Clemson Univ., Clemson, SC 29634-0911; formerly, Nat. Inst. of Standards and Technol., Gaithersburg, MD.
- Bechtel Corp., San Francisco, CA 94119-3965.
- PhD, GEI Consultants, Inc., Winchester, MA 01890.
- PhD, Engrg. Consultant, Waban, MA 02468-1103,
- ¹⁷Prof., Rensselaer Polytechnic Inst., Troy, NY 12180.
- ⁸Prof., Univ. of British Columbia, Vancouver, BC, Canada.
- ⁹California Dept. of Water Resour., Sacramento, CA 94236-0001.
- ¹⁰U.S. Army Engr. Wtrwy. Experiment Station, Vicksburg, MS 39180. ¹¹Prof., Sci. Univ. of Tokyo, Tokyo, Japan.

¹²U.S. Army Engr. Wtrwy. Experiment Station, Vicksburg, MS 39180. ¹³Parsons Brinckerhoff, Boston, MA 02116.

¹⁴PhD, U.S. Army Engr. Wtrwy. Experiment Station, Vicksburg, MS 39180.

¹⁵Prof., Univ. of Southern California, Los Angeles, CA 90089-2531.

¹⁶Prof., Virginia Polytechnic Inst., Blacksburg, VA 24061.

¹⁷PhD, Prin., Geomatrix Consultants, Santa Ana, CA 94612.

¹⁸Geomatrix Consultants, Oakland, CA 94612.

- ¹⁹Prof., Univ. of Alberta, Edmonton, Alberta, Canada.
- ²⁰Prof., Univ. of California, Berkeley, CA 94720.
- ²¹Prof., Univ. of Texas at Austin, Austin, TX 78712.

Note. Discussion open until March 1, 2002. To extend the closing date one month, a written request must be filed with the ASCE Manager of Journals. The manuscript for this paper was submitted for review and possible publication on January 18, 2000; revised November 14, 2000. This paper is part of the Journal of Geotechnical and Geoenvironmental Engineering, Vol. 127, No. 10, October, 2001. ©ASCE, ISSN 1090-0241/01/0010-0817--0833/\$8.00 + \$.50 per page. Paper No. 22223.

INTRODUCTION

Over the past 25 years a methodology termed the "simplified procedure" has evolved as a standard of practice for evaluating the liquefaction resistance of soils. Following disastrous earthquakes in Alaska and in Niigata, Japan in 1964, Seed and Idriss (1971) developed and published the basic "simplified procedure." That procedure has been modified and improved periodically since that time, primarily through landmark papers by Seed (1979), Seed and Idriss (1982), and Seed et al. (1985). In 1985, Professor Robert V. Whitman convened a workshop on behalf of the National Research Council (NRC) in which 36 experts and observers thoroughly reviewed the state-of-knowledge and the state-of-the-art for assessing liquefaction hazard. That workshop produced a report (NRC 1985) that has become a widely used standard and reference for liquefaction hazard assessment. In January 1996, T. L. Youd and I. M. Idriss convened a workshop of 20 experts to update the simplified procedure and incorporate research findings from the previous decade. This paper summarizes recommendations from that workshop (Youd and Idriss 1997).

To keep the workshop focused, the scope of the workshop was limited to procedures for evaluating liquefaction resistance of soils under level to gently sloping ground. In this context, liquefaction refers to the phenomena of seismic generation of large pore-water pressures and consequent softening of granular soils. Important postliquefaction phenomena, such as residual shear strength, soil deformation, and ground failure, were beyond the scope of the workshop.

The simplified procedure was developed from empirical evaluations of field observations and field and laboratory test data. Field evidence of liquefaction generally consisted of surficial observations of sand boils, ground fissures, or lateral spreads. Data were collected mostly from sites on level to gently sloping terrain, underlain by Holocene alluvial or fluvial sediment at shallow depths (<15 m). The original procedure was verified for, and is applicable only to, these site conditions. Similar restrictions apply to the implementation of the updated procedures recommended in this report.

Liquefaction is defined as the transformation of a granular material from a solid to a liquefied state as a consequence of increased pore-water pressure and reduced effective stress (Marcuson 1978). Increased pore-water pressure is induced by the tendency of granular materials to compact when subjected to cyclic shear deformations. The change of state occurs most readily in loose to moderately dense granular soils with poor drainage, such as silty sands or sands and gravels capped by or containing seams of impermeable sediment. As liquefaction occurs, the soil stratum softens, allowing large cyclic deformations to occur. In loose materials, the softening is also accompanied by a loss of shear strength that may lead to large shear deformations or even flow failure under moderate to high shear stresses, such as beneath a foundation or sloping ground. In moderately dense to dense materials, liquefaction leads to transient softening and increased cyclic shear strains, but a tendency to dilate during shear inhibits major strength loss and large ground deformations. A condition of cyclic mobility or cyclic liquefaction may develop following liquefaction of moderately dense granular materials. Beneath gently sloping to flat ground, liquefaction may lead to ground oscillation or lateral spread as a consequence of either flow deformation or cyclic mobility. Loose soils also compact during liquefaction and reconsolidation, leading to ground settlement. Sand boils may also erupt as excess pore water pressures dissipate.

CYCLIC STRESS RATIO (CSR) AND CYCLIC RESISTANCE RATIO (CRR)

Calculation, or estimation, of two variables is required for evaluation of liquefaction resistance of soils: (1) the seismic demand on a soil layer, expressed in terms of CSR; and (2) the capacity of the soil to resist liquefaction, expressed in terms of CRR. The latter variable has been termed the cyclic stress ratio or the cyclic stress ratio required to generate liquefaction, and has been given different symbols by different writers. For example, Seed and Harder (1990) used the symbol CSR ℓ , Youd (1993) used the symbol CSRL, and Kramer (1996) used the symbol CSR_L to denote this ratio. To reduce confusion and to better distinguish induced cyclic shear stresses from mobilized liquefaction resistance, the capacity of a soil to resist liquefaction is termed the CRR in this report. This term is recommended for engineering practice.

EVALUATION OF CSR

Seed and Idriss (1971) formulated the following equation for calculation of the cyclic stress ratio:

$$\mathrm{CSR} = (\tau_{\mathrm{av}}/\sigma_{\mathrm{vo}}') = 0.65(a_{\mathrm{max}}/g)(\sigma_{\mathrm{vo}}/\sigma_{\mathrm{vo}}')r_d \tag{1}$$

where $a_{\text{max}} =$ peak horizontal acceleration at the ground surface generated by the earthquake (discussed later); g = acceleration of gravity; σ_{vo} and σ'_{vo} are total and effective vertical overburden stresses, respectively; and r_d = stress reduction coefficient. The latter coefficient accounts for flexibility of the soil profile. The workshop participants recommend the following minor modification to the procedure for calculation of CSR.

For routine practice and noncritical projects, the following equations may be used to estimate average values of r_d (Liao and Whitman 1986b):

$$r_d = 1.0 - 0.00765z$$
 for $z \le 9.15$ m (2a)

$$r_d = 1.174 - 0.0267z$$
 for 9.15 m < $z \le 23$ m (2b)

where z = depth below ground surface in meters. Some investigators have suggested additional equations for estimating r_d at greater depths (Robertson and Wride 1998), but evaluation of liquefaction at these greater depths is beyond the depths where the simplified procedure is verified and where routine applications should be applied. Mean values of r_d calculated from (2) are plotted in Fig. 1, along with the mean and range of values proposed by Seed and Idriss (1971). The workshop participants agreed that for convenience in programming spreadsheets and other electronic aids, and to be consistent with past practice, r_d values determined from (2) are suitable for use in routine engineering practice. The user should understand, however, that there is considerable variability in the



FIG. 1. r_d versus Depth Curves Developed by Seed and Idriss (1971) with Added Mean-Value Lines Plotted from Eq. (2)

818 / JOURNAL OF GEOTECHNICAL AND GEOENVIRONMENTAL ENGINEERING / OCTOBER 2001

flexibility and thus r_d at field sites, that r_d calculated from (2) are the mean of a wide range of possible r_d , and that the range of r_d increases with depth (Golesorkhi 1989).

For ease of computation, T. F. Blake (personal communication, 1996) approximated the mean curve plotted in Fig. 1 by the following equation:

$$r_{d} = \frac{(1.000 - 0.4113z^{0.5} + 0.04052z + 0.001753z^{1.5})}{(1.000 - 0.4177z^{0.5} + 0.05729z - 0.006205z^{1.5} + 0.001210z^{2})}$$
(3)

where z = depth beneath ground surface in meters. Eq. (3) yields essentially the same values for r_d as (2), but is easier to program and may be used in routine engineering practice.

I. M. Idriss [Transportation Research Board (TRB) (1999)] suggested a new procedure for determining magnitude-dependent values of r_d . Application of these r_d require use of a corresponding set of magnitude scaling factors that are compatible with the new r_d . Because these r_d were developed after the workshop and have not been independently evaluated by other experts, the workshop participants chose not to recommend the new factors at this time.

EVALUATION OF LIQUEFACTION RESISTANCE (CRR)

A major focus of the workshop was on procedures for evaluating liquefaction resistance. A plausible method for evaluating CRR is to retrieve and test undisturbed soil specimens in the laboratory. Unfortunately, in situ stress states generally cannot be reestablished in the laboratory, and specimens of granular soils retrieved with typical drilling and sampling techniques are too disturbed to yield meaningful results. Only through specialized sampling techniques, such as ground freezing, can sufficiently undisturbed specimens be obtained. The cost of such procedures is generally prohibitive for all but the most critical projects. To avoid the difficulties associated with sampling and laboratory testing, field tests have become the state-of-practice for routine liquefaction investigations.

Several field tests have gained common usage for evaluation of liquefaction resistance, including the standard penetration test (SPT), the cone penetration test (CPT), shear-wave velocity measurements (V_s) , and the Becker penetration test (BPT). These tests were discussed at the workshop, along with associated criteria for evaluating liquefaction resistance. The participants made a conscientious attempt to correlate liquefaction resistance criteria from each of the various field tests to provide generally consistent results, no matter which test is applied. SPTs and CPTs are generally preferred because of the more extensive databases and past experience, but the other tests may be applied at sites underlain by gravelly sediment or where access by large equipment is limited. Primary advantages and disadvantages of each test are listed in Table 1.

SPT

Criteria for evaluation of liquefaction resistance based on the SPT have been rather robust over the years. Those criteria are largely embodied in the CSR versus $(N_1)_{60}$ plot reproduced



FIG, 2. SPT Clean-Sand Base Curve for Magnitude 7.5 Earthquakes with Data from Liquefaction Case Histories (Modified from Seed et al. 1985)

in Fig. 2. $(N_1)_{60}$ is the SPT blow count normalized to an overburden pressure of approximately 100 kPa (1 ton/sq ft) and a hammer energy ratio or hammer efficiency of 60%. The normalization factors for these corrections are discussed in the section entitled Other Corrections. Fig. 2 is a graph of calculated CSR and corresponding $(N_1)_{60}$ data from sites where liquefaction effects were or were not observed following past earthquakes with magnitudes of approximately 7.5. CRR curves on this graph were conservatively positioned to separate regions with data indicative of liquefaction from regions with data indicative of nonliquefaction. Curves were developed for granular soils with the fines contents of 5% or less, 15%, and 35% as shown on the plot. The CRR curve for fines contents <5% is the basic penetration criterion for the simplified procedure and is referred to hereafter as the "SPT cleansand base curve." The CRR curves in Fig. 2 are valid only for magnitude 7.5 earthquakes. Scaling factors to adjust CRR curves to other magnitudes are addressed in a later section of this report.

SPT Clean-Sand Base Curve

Several changes to the SPT criteria are recommended by the workshop participants. The first change is to curve the trajec-

TABLE 1. Comparison of Advantages and Disadvantages of Various Field Tests for Assessment of Liquefaction Resistance

	Test Type							
Feature	SPT	CPT	V,	BPT				
Past measurements at liquefaction sites	Abundant	Abundant	Limited	Sparse				
Type of stress-strain behavior influencing test	Partially drained, large strain	Drained, large strain	Small strain	Partially drained, large strain				
Quality control and repeatability	Poor to good	Very good	Good	Poor				
Detection of variability of soil deposits	Good for closely spaced tests	Very good	Fair	Fair				
Soil types in which test is recommended	Nongravel	Nongravel	All	Primarily gravel				
Soil sample retrieved	Yes	No	No	No				
Test measures index or engineering property	Index	Index	Engineering	Index				

tory of the clean-sand base curve at low $(N_1)_{60}$ to a projected intercept of about 0.05 (Fig. 2). This adjustment reshapes the clean-sand base curve to achieve greater consistency with CRR curves developed for the CPT and shear-wave velocity procedures. Seed and Idriss (1982) projected the original curve through the origin, but there were few data to constrain the curve in the lower part of the plot. A better fit to the present empirical data is to bow the lower end of the base curve as indicated in Fig. 2.

At the University of Texas, A. F. Rauch (personal communication, 1998), approximated the clean-sand base curve plotted in Fig. 2 by the following equation:

$$CRR_{7.5} = \frac{1}{34 - (N_1)_{60}} + \frac{(N_1)_{60}}{135} + \frac{50}{[10 \cdot (N_1)_{60} + 45]^2} - \frac{1}{200}$$
(4)

This equation is valid for $(N_1)_{60} < 30$. For $(N_1)_{60} \ge 30$, clean granular soils are too dense to liquefy and are classed as non-liquefiable. This equation may be used in spreadsheets and other analytical techniques to approximate the clean-sand base curve for routine engineering calculations.

Influence of Fines Content

In the original development, Seed et al. (1985) noted an apparent increase of CRR with increased fines content. Whether this increase is caused by an increase of liquefaction resistance or a decrease of penetration resistance is not clear. Based on the empirical data available, Seed et al. developed CRR curves for various fines contents reproduced in Fig. 2. A revised correction for fines content was developed by workshop attendees to better fit the empirical database and to better support computations with spreadsheets and other electronic computational aids.

The workshop participants recommend (5) and (6) as approximate corrections for the influence of fines content (FC) on CRR. Other grain characteristics, such as soil plasticity, may affect liquefaction resistance as well as fines content, but widely accepted corrections for these factors have not been developed. Hence corrections based solely on fines content should be used with engineering judgment and caution. The following equations were developed by I. M. Idriss with the assistance of R. B. Seed for correction of $(N_1)_{60}$ to an equivalent clean sand value, $(N_1)_{60c}$:

$$(N_1)_{60cs} = \alpha + \beta (N_1)_{60}$$
(5)

where α and β = coefficients determined from the following relationships:

$$\alpha = 0 \quad \text{for FC} \le 5\% \tag{6a}$$

$$\alpha = \exp[1.76 - (190/FC^2)]$$
 for 5% < FC < 35% (6b)

$$\alpha = 5.0 \quad \text{for FC} \ge 35\% \tag{6c}$$

$$\beta = 1.0 \quad \text{for FC} \le 5\% \tag{7a}$$

$$\beta = [0.99 + (FC^{1.5}/1,000)] \text{ for } 5\% < FC < 35\%$$
(7b)

$$\beta = 1.2 \quad \text{for FC} \ge 35\% \tag{7c}$$

These equations may be used for routine liquefaction resistance calculations. A back-calculated curve for a fines/content of 35% is essentially congruent with the 35% curve plotted in Fig. 2. The back-calculated curve for a fines contents of 15% plots to the right of the original 15% curve.

Other Corrections

Several factors in addition to fines content and grain characteristics influence SPT results, as noted in Table 2. Eq. (8) incorporates these corrections

 TABLE 2.
 Corrections to SPT (Modified from Skempton 1986) as

 Listed by Robertson and Wride (1998)

Factor	Equipment variable	Term	Correction
Overburden pressure		C_N	$(P_a/\sigma'_{10})^{0.5}$
Overburden pressure		C_N	$C_N \leq 1.7$
Energy ratio	Donut hammer	C_{R}	0.5-1.0
Energy ratio	Safety hammer	C_R	0.7 - 1.2
Energy ratio	Automatic-trip Donut- type hammer	C_E	<i>•</i> 0.8–1.3
Borehole diameter	65–115 mm	C_{R}	1.0
Borehole diameter	150 mm	C_{n}	1.05
Borehole diameter	200 mm	$\tilde{C_{R}}$	1.15
Rod length	<3 m	C_R	0.75
Rod length	3–4 m	C_R	0.8
Rod length	46 m	C_{R}	0.85
Rod length	6–10 m	C_R	0.95
Rod length	10–30 m	$\hat{C_R}$	1.0
Sampling method	Standard sampler	C_{s}	1.0
Sampling method	Sampler without liners	$\tilde{C_s}$	1.1-1.3

$$(N_1)_{60} = N_m C_N C_E C_B C_R C_S \tag{8}$$

where N_m = measured standard penetration resistance; C_N = factor to normalize N_m to a common reference effective overburden stress; C_E = correction for hammer energy ratio (ER); C_B = correction factor for borehole diameter; C_R = correction factor for rod length; and C_s = correction for samplers with or without liners.

Because SPT N-values increase with increasing effective overburden stress, an overburden stress correction factor is applied (Seed and Idriss 1982). This factor is commonly calculated from the following equation (Liao and Whitman 1986a):

$$C_N = \left(P_a / \sigma_{\rm vo}' \right)^{0.5} \tag{9}$$

where C_N normalizes N_m to an effective overburden pressure σ'_{vo} of approximately 100 kPa (1 atm) P_a . C_N should not exceed a value of 1.7 [A maximum value of 2.0 was published in the National Center for Earthquake Engineering Research (NCEER) workshop proceedings (Youd and Idriss 1997), but later was reduced to 1.7 by consensus of the workshop participants] Kayen et al. (1992) suggested the following equation, which limits the maximum C_N value to 1.7, and in these writers' opinion, provides a better fit to the original curve specified by Seed and Idriss (1982):

$$C_N = 2.2/(1.2 + \sigma'_{\rm yo}/P_a) \tag{10}$$

Either equation may be used for routine engineering applications.

The effective overburden pressure σ'_{vo} applied in (9) and (10) should be the overburden pressure at the time of drilling and testing. Although a higher ground-water level might be used for conservatism in the liquefaction resistance calculations, the C_N factor must be based on the stresses present at the time of the testing.

The C_N correction factor was derived from SPT performed in test bins with large sand specimens subjected to various confining pressures (Gibbs and Holtz 1957; Marcuson and Bieganousky 1997a,b). The results of several of these tests are reproduced in Fig. 3 in the form of C_N curves versus effective overburden stress (Castro 1995). These curves indicate considerable scatter of results with no apparent correlation of C_N with soil type or gradation. The curves from looser sands, however, lie in the lower part of the C_N range and are reasonably approximated by (9) and (10) for low effective overburden pressures [200 kPa (<2 tsf)]. The workshop participants endorsed the use of (9) for calculation of C_N , but acknowledged that for overburden pressures >200 kPa (2 tsf) the results are uncertain. Eq. (10) provides a better fit for overburden

820 / JOURNAL OF GEOTECHNICAL AND GEOENVIRONMENTAL ENGINEERING / OCTOBER 2001



FIG. 3. C_N Curves for Various Sands Based on Field and Laboratory Test Data along with Suggested C_N Curve Determined from Eqs. (9) and (10) (Modified from Castro 1995)

pressures up to 300 kPa (3 tsf). For pressures >300 kPa (3 tsf), the uncertainty is so great that (9) should not be applied. At these high pressures, which are generally below the depth for which the simplified procedure has been verified, C_N should be estimated by other means.

Another important factor is the energy transferred from the falling hammer to the SPT sampler. An ER of 60% is generally accepted as the approximate average for U.S. testing practice and as a reference value for energy corrections. The ER delivered to the sampler depends on the type of hammer, anvil, lifting mechanism, and the method of hammer release. Approximate correction factors ($C_E = ER/60$) to modify the SPT results to a 60% energy ratio for various types of hammers and anvils are listed in Table 2. Because of variations in drilling and testing equipment and differences in testing procedures, a rather wide range in the energy correction factor C_E has been observed as noted in the table. Even when procedures are carefully monitored to conform to established standards, such as ASTM D 1586-99, some variation in C_E may occur because of minor variations in testing procedures. Measured energies at a single site indicate that variations in energy ratio between blows or between tests in a single borehole typically vary by as much as 10%. The workshop participants recommend measurement of the hammer energy frequently at each site where the SPT is used. Where measurements cannot be made, careful observation and notation of the equipment and procedures are required to estimate a C_E value for use in liquefaction resistance calculations. Use of good-quality testing equipment and carefully controlled testing procedures conforming to ASTM D 1586-99 will generally yield more consistent energy ratios and C_E with values from the upper parts of the ranges listed in Table 2.

Skempton (1986) suggested and Robertson and Wride (1998) updated correction factors for rod lengths <10 m, borehole diameters outside the recommended interval (65–125 mm), and sampling tubes without liners. Range for these correction factors are listed in Table 2. For liquefaction resistance calculations and rod lengths <3 m, a C_R of 0.75 should be applied as was done by Seed et al. (1985) in formulating the simplified procedure. Although application of rod-length correction factors listed in Table 2 will give more precise $(N_1)_{60}$ values, these corrections may be neglected for liquefaction resistance calculations for rod lengths between 3 and 10 m because rod-length corrections were not applied to SPT test data from these depths in compiling the original liquefaction case

history databases. Thus rod-length corrections are implicitly incorporated into the empirical SPT procedure.

A final change recommended by workshop participants is the use of revised magnitude scaling factors rather than the original Seed and Idriss (1982) factors to adjust CRR for earthquake magnitudes other than 7.5. Magnitude scaling factors are addressed later in this report.

CPT

Aprimary advantage of the CPT is that a nearly continuous profile of penetration resistance is developed for stratigraphic interpretation. The CPT results are generally more consistent and repeatable than results from other penetration tests listed in Table 1. The continuous profile also allows a more detailed definition of soil layers than the other tools listed in the table. This stratigraphic capability makes the CPT particularly advantageous for developing liquefaction-resistance profiles. Interpretations based on the CPT, however, must be verified with a few well-placed boreholes preferably with standard penetration tests, to confirm soil types and further verify liquefactionresistance interpretations.

Fig. 4 provides curves prepared by Robertson and Wride (1998) for direct determination of CRR for clean sands (FC $\leq 5\%$) from CPT data. This figure was developed from CPT case history data compiled from several investigations, including those by Stark and Olson (1995) and Suzuki et al. (1995). The chart, valid for magnitude 7.5 earthquakes only, shows calculated cyclic resistance ratio plotted as a function of dimensionless, corrected, and normalized CPT resistance q_{clN} from sites where surface effects of liquefaction were or were not observed following past earthquakes. The CRR curve conservatively separates regions of the plot with data indicative of liquefaction from regions indicative of nonliquefaction.

Based on a few misclassified case histories from the 1989 Loma Prieta earthquake, I. M. Idriss suggested that the clean sand curve in Fig. 4 should be shifted to the right by 10–15%. However, a majority of workshop participants supported a curve in its present position, for three reasons. First, a purpose of the workshop was to recommend criteria that yield roughly equivalent CRR for the field tests listed in Table 1. Shifting the base curve to the right makes the CPT criteria generally more conservative. For example, for $(N_1)_{60} > 5$, $q_{clN}:(N_1)_{60}$ ra-



FIG. 4. Curve Recommended for Calculation of CRR from CPT Data along with Empirical Liquefaction Data from Compiled Case Histories (Reproduced from Robertson and Wride 1998)

tios between the two clean-sand base curves, plotted in Figs. 4 and 2, respectively, range from 5 to 8-values that are slightly higher than those expected for clean sands. Shifting the CPT base curve to the right by 10 to 15% would increase those ratios to unusually high values ranging from 6 to 9. Second, base curves, such as those plotted in Figs. 2 and 4, were intended to be conservative, but not necessarily to encompass every data point on the plot. Thus the presence of a few points beyond the base curve should be allowable. Finally, several studies have confirmed that the CPT criteria in Fig. 4 are generally conservative. Robertson and Wride (1998) verified these criteria against SPT and other data from sites they investigated. Gilstrap and Youd (1998) compared calculated liquefaction resistances against field performance at 19 sites and concluded that the CPT criteria correctly predicted the occurrence or nonoccurrence of liquefaction with >85% reliability.

The clean-sand base curve in Fig. 4 may be approximated by the following equation (Robertson and Wride 1998):

If
$$(q_{c1N})_{cs} < 50$$
 CRR_{7.5} = 0.833[$(q_{c1N})_{cs}/1,000$] + 0.05 (11*a*)

If
$$50 \le (q_{c1N})_{cs} < 160$$
 CRR_{7.5} = $93[(q_{c1N})_{cs}/1,000]^3 + 0.08$
(11b)

where $(q_{c1N})_{cs}$ = clean-sand cone penetration resistance normalized to approximately 100 kPa (1 atm).

Normalization of Cone Penetration Resistance

The CPT procedure requires normalization of tip resistance using (12) and (13). This transformation yields normalized, dimensionless cone pentration resistance q_{c1N}

$$q_{c1N} = C_Q(q_c/P_a) \tag{12}$$

where

$$C_o = (P_a/\sigma'_{\rm vo})^n \tag{13}$$

and where C_q = normalizing factor for cone penetration resistance; $P_a = 1$ atm of pressure in the same units used for σ'_{vo} ; n = exponent that varies with soil type; and $q_c =$ field cone penetration resistance measured at the tip. At shallow depths C_{q} becomes large because of low overburden pressure; however, values >1.7 should not be applied. As noted in the following paragraphs, the value of the exponent n varies from 0.5 to 1.0, depending on the grain characteristics of the soil (Olsen 1997)

The CPT friction ratio (sleeve resistance f_s divided by cone tip resistance q_c) generally increases with increasing fines content and soil plasticity, allowing rough estimates of soil type and fines content to be determined from CPT data. Robertson and Wride (1998) constructed the chart reproduced in Fig. 5 for estimation of soil type. The boundaries between soil types 2-7 can be approximated by concentric circles and can be used to account for effects of soil characteristics on q_{cin} and CRR. The radius of these circles, termed the soil behavior type index I_c is calculated from the following equation:

$$I_c = \left[(3.47 - \log Q)^2 + (1.22 + \log F)^2 \right]^{0.5}$$
(14)

$$P = [(q_c - \sigma_{vo})/P_a][(P_a/\sigma'_{vo})^n]$$

where

$$F = [f_r / (q_c - \sigma_{y_0})] \times 100\%$$
(16)

The soil behavior chart in Fig. 5 was developed using an exponent n of 1.0, which is the appropriate value for clayey soil types. For clean sands, however, an exponent value of 0.5 is more appropriate, and a value intermediate between 0.5 and



- 1. Sensitive, fine grained
- 2. Organic soils peats
- 3. Clays silty clay to clay
- 4. Silt mixtures clayey silt to silty clay
- 5. Sand mixtures silty sand to sandy silt

*Heavily overconsolidated or cemented

FIG. 5. CPT-Based Soil Behavior-Type Chart Proposed by Robertson (1990)

7. Gravelly sand to dense sand

9. Very stiff, fine grained*

8. Very stiff sand to clayey sand*

1.0 would be appropriate for silts and sandy silts. Robertson and Wride recommended the following procedure for calculating the soil behavior type index I_c . The first step is to differentiate soil types characterized as clays from soil types characterized as sands and silts. This differentiation is performed by assuming an exponent n of 1.0 (characteristic of clays) and calculating the dimensionless CPT tip resistance Q from the following equation:

$$Q = [(q_{e} - \sigma_{vo})/P_{a}][P_{a}/\sigma_{vo}]^{1.0} = [(q_{e} - \sigma_{vo})/\sigma_{vo}]$$
(17)

If the I_c calculated with an exponent of 1.0 is >2.6, the soil is classified as clayey and is considered too clay-rich to liquefy, and the analysis is complete. However, soil samples should be retrieved and tested to confirm the soil type and liquefaction resistance. Criteria such as the Chinese criteria might be applied to confirm that the soil is nonliquefiable. The so-called Chinese criteria, as defined by Seed and Idriss (1982), specify that liquefaction can only occur if all three of the following conditions are met:

- 1. The clay content (particles smaller than 5 μ) is <15% by weight.
- The liquid limit is <35%. 2.
- The natural moisture content is >0.9 times the liquid 3. limit.

If the calculated I_c is <2.6, the soil is most likely granular in nature, and therefore C_q and Q should be recalculated using an exponent n of 0.5. I_c should then be recalculated using (14). If the recalculated I_c is <2.6, the soil is classed as nonplastic and granular. This I_c is used to estimate liquefaction resistance, as noted in the next section. However, if the recalculated I_c is

822 / JOURNAL OF GEOTECHNICAL AND GEOENVIRONMENTAL ENGINEERING / OCTOBER 2001

(15)

2.6, the soil is likely to be very silty and possibly plastic. In this instance, q_{c1N} should be recalculated from (12) using an intermediate exponent *n* of 0.7 in (13). I_c is then recalculated from (14) using the recalculated value for q_{c1N} . This intermediate I_c is then used to calculate liquefaction resistance. In this instance, a soil sample should be retrieved and tested to verify the soil type and whether the soil is liquefiable by other criteria, such as the Chinese criteria.

Because the relationship between I_c and soil type is approximate, the consensus of the workshop participants is that all soils with an I_c of 2.4 or greater should be sampled and tested to confirm the soil type and to test the liquefiability with other criteria. Also, soil layers characterized by an $I_c > 2.6$, but with a normalized friction ratio F < 1.0% (region 1 of Fig. 5) may be very sensitive and should be sampled and tested. Although not technically liquefiable according to the Chinese criteria, such sensitive soils may suffer softening and strength loss during earthquake shaking.

Calculation of Clean-Sand Equivalent Normalized Cone Penetration Resistance $(q_{c1N})_{cs}$

The normalized penetration resistance (q_{c1N}) for silty sands is corrected to an equivalent clean sand value $(q_{c1N})_{cs}$, by the following relationship:

$$(q_{c1N})_{cs} = K_c q_{c1N} \tag{18}$$

where K_c , the correction factor for grain characteristics, is defined by the following equation (Robertson and Wride 1998):

for
$$I_c \le 1.64$$
 $K_c = 1.0$ (19a)

for
$$I_c > 1.64$$
 $K_c = -0.403I_c^4 + 5.581I_c^3 - 21.63I_c^2$

$$+ 33.75I_c - 17.88$$
 (19b)

The K_c curve defined by (19) is plotted in Fig. 6. For $I_c > 2.6$, the curve is shown as a dashed line, indicating that soils in this range of I_c are most likely too clay-rich or plastic to liquefy.

With an appropriate I_c and K_c , (11) and (19) can be used to calculate CRR_{7.5}. To adjust CRR to magnitudes other than 7.5, the calculated CRR_{7.5} is multiplied by an appropriate magnitude scaling factor. The same magnitude scaling factors are used with CPT data as with SPT data. Magnitude scaling factors are discussed in a later section of this report.

Olsen (1997) and Suzuki et al. (1995) Procedures

Olsen (1997), who pioneered many of the techniques for assessing liquefaction resistance from CPT soundings, sug-



FIG. 6. Grain-Characteristic Correction Factor K_c for Determination of Clean-Sand Equivalent CPT Resistance (Reproduced from Robertson and Wride 1998)

gested a somewhat different procedure for calculating CRR from CPT data. Reasons for recommending the Robertson and Wride (1998) procedure over that of Olsen are the ease of application and the ease with which relationships can be quantified for computer-aided calculations. Results from Olsen's procedure, however, are consistent with results from the procedure proposed here for shallow (<15 m deep) sediment beneath level to gently sloping terrain. Olsen (1997) noted that almost any CPT normalization technique will give results consistent with his normalization procedure for soil layers in the 34-15 m depth range. For deeper layers, significant differences may develop between the two procedures. Those depths are also beyond the depth for which the simplified procedure has been verified. Hence any procedure based on the simplified procedure yields rather uncertain results at depths >15 m.

Suzuki et al. (1995) also developed criteria for evaluating CRR from CPT data. Those criteria are slightly more conservative than those of Robertson and Wride (1998) and were considered by the latter investigators in developing the criteria recommended herein.

Correction of Cone Penetration Resistance for Thin Soil Layers

Theoretical as well as laboratory studies indicate that CPT tip resistance is influenced by softer soil layers above or below the cone tip. As a result, measured CPT tip resistance is smaller in thin layers of granular soils sandwiched between softer layers than in thicker layers of the same granular soil. The amount of the reduction of penetration resistance in soft layers is a function of the thickness of the softer layer and the stiffness of the stiffer layers.

Using a simplified elastic solution, Vreugdenhil et al. (1994) developed a procedure for estimating the thick-layer equivalent cone penetration resistance of thin stiff layers lying within softer strata. The correction applies only to thin stiff layers embedded within thick soft layers. Because the corrections have a reasonable trend, but appear rather large, Robertson and Fear (1995) recommended conservative corrections from the $q_{cA}/q_{cB} = 2$ curve sketched in Fig. 7.

Further analysis of field data by Gonzalo Castro and Peter Robertson for the NCEER workshop indicates that corrections based on the $q_{cA}/q_{cB} = 2$ curve may still be too large and not adequately conservative. They suggested, and the workshop participants agreed, that the lower bound of the range of field data plotted by G. Castro in Fig. 7 provides more conservative K_H values that should be used until further field studies and analyses indicate that higher values are viable. The equation for the lower bound of the field curve is

$$K_H = 0.25[((H/d_c)/17) - 1.77]^2 + 1.0$$
(20)

where H = thickness of the interbedded layer in mm; q_{cA} and $q_{cB} =$ cone resistances of the stiff and soft layers, respectively; and $d_c =$ diameter of the cone in mm (Fig. 7).

V.

Andrus and Stokoe (1997, 2000) developed liquefaction resistance criteria from field measurements of shear wave velocity V_s . The use of V_s as a field index of liquefaction resistance, is soundly based because both V_s and CRR are similarly, but not proportionally, influenced by void ratio, effective confining stresses, stress history, and geologic age. The advantages of using V_s include the following: (1) V_s measurements are possible in soils that are difficult to penetrate with CPT and SPT or to extract undisturbed samples, such as gravelly soils, and at sites where borings or soundings may not be permitted; (2) V_s is a basic mechanical property of soil materials, directly related to small-strain shear modulus; and (3) the





FIG. 7. Thin-Layer Correction Factor K_H for Determination of Equivalent Thick-Layer CPT Resistance (Modified from Robertson and Fear 1995)

small-strain shear modulus is a parameter required in analytical procedures for estimating dynamic soil response and soilstructure interaction analyses.

Three concerns arise when using V_s for liquefaction-resistance evaluations: (1) seismic wave velocity measurements are made at small strains, whereas pore-water pressure buildup and the onset of liquefaction are medium- to high-strain phenomena; (2) seismic testing does not provide samples for classification of soils and identification of nonliquefiable soft clay-rich soils; and (3) thin, low V_s strata may not be detected if the measurement interval is too large. Therefore the preferred practice is to drill sufficient boreholes and conduct in situ tests to detect and delineate thin liquefiable strata, nonliquefiable clay-rich soils, and silty soils above the ground-water table that might become liquefiable should the water table rise. Other tests, such as the SPT or CPT, are needed to detect liquefiable weakly cemented soils that may have high V_s values.

V, Criteria for Evaluating Liquefaction Resistance

Following the traditional procedures for correcting penetration resistance to account for overburden stress, V, is also corrected to a reference overburden stress using the following equation (Sykora 1987; Kayen et al. 1992; Robertson et al. 1992):

$$V_{s1} = V_s \left(\frac{P_a}{\sigma_{vo}'}\right)^{0.25}$$
(21)

where V_{s1} = overburden-stress corrected shear wave velocity; P_a = atmospheric pressure approximated by 100 kPa (1 TSF); and σ'_{vo} = initial effective vertical stress in the same units as P_a . Eq. (21) implicitly assumes a constant coefficient of earth pressure K'_o which is approximately 0.5 for sites susceptible to liquefaction. Application of (21) also implicitly assumes that V_s is measured with both the directions of particle motion and wave propagation polarized along principal stress directions and that one of those directions is vertical (Stokoe et al. 1985).

Fig. 8 compares seven CRR-V_{s1} curves. The "best fit" curve by Tokimatsu and Uchida (1990) was determined from laboratory cyclic triaxial test results for various sands with <10% fines and 15 cycles of loading. The more conservative "lower bound" curve for Tokimatsu and Uchida's laboratory test results is also shown as a lower bound for liquefaction occurrences. The bounding curve by Robertson et al. (1992) was developed using field performance data from sites in Imperial Valley, Calif., along with data from four other sites. The curves by Kayen et al. (1992) and Lodge (1994) are from sites that did and did not liquefy during the 1989 Loma Prieta earthquake. Andrus and Stokoe's (1997) curve was developed for uncemented, Holocene-age soils with 5% or less fines using field performance data from 20 earthquakes and over 50 measurement sites. Andrus and Stokoe (2000) revised this curve based on new information and an expanded database that includes 26 earthquakes and more than 70 measurement sites.

Andrus and Stokoe (1997) proposed the following relationship between CRR and V_{s1} :

$$CRR = a \left(\frac{V_{s1}}{100}\right)^2 + b \left(\frac{1}{V_{s1}^* - V_{s1}} - \frac{1}{V_{s1}^*}\right)$$
(22)

where $V_{s1}^* = \text{limiting upper value of } V_{s1}$ for liquefaction occurrence; and *a* and *b* are curve fitting parameters. The first parenthetical term of (22) is based on a modified relationship



FIG. 8. Comparison of Seven Relationships between Liquefaction Resistance and Overburden Stress-Corrected Shear Wave Velocity for Granular Soils

824 / JOURNAL OF GEOTECHNICAL AND GEOENVIRONMENTAL ENGINEERING / OCTOBER 2001

between V_{s1} and CSR for constant average cyclic shear strain suggested by R. Dobry (personal communication to R. D. Andrus, 1996). The second parenthetical term is a hyperbola with a small value at low V_{s1} , and a very large value as V_{s1} approaches V_{s1}^* , a constant limiting velocity for liquefaction of soils.

CRR versus V_{s1} curves recommended for engineering practice by Andrus and Stokoe (2000) for magnitude 7.5 earthquakes and uncemented Holocene-age soils with various fines contents are reproduced in Fig. 9. Also plotted and presented in Fig. 9 are points calculated from liquefaction case history information for magnitude 5.9–8.3 earthquakes. The three curves shown were determined through an iterative process of varying the values of *a* and *b* until nearly all the points indicative of liquefaction were bounded by the curves with the least number of nonliquefaction points plotted in the liquefaction region. The final values of *a* and *b* used to draw the curves were 0.022 and 2.8, respectively. Values of V_{s1}^* were assumed to vary linearly from 200 m/s for soils with fines content of 35% to 215 m/s for soils with fines content of 5% or less.

The recommended curves shown in Fig. 9 are dashed above CRR of 0.35 to indicate that field-performance data are limited in that range. Also, they do not extend much below 100 m/s, because there are no field data to support extending them to the origin. The calculated CRR is 0.033 for a V_{s1} of 100 m/s. This minimal CRR value is generally consistent with intercept CRR values assumed for the CPT and SPT procedures. Eq. (22) can be scaled to other magnitude values through use of magnitude scaling factors. These factors are discussed in a later section of this paper.

BPT

Liquefaction resistance of nongravelly soils has been evaluated primarily through CPT and SPT, with occasional V, measurements. CPT and SPT measurements, however, are not generally reliable in gravelly soils. Large gravel particles may interfere with the normal deformation of soil materials around the penetrometer and misleadingly increase penetration resistance. Several investigators have employed large-diameter



FIG. 9. Liquefaction Relationship Recommended for Clean, Uncemented Soils with Liquefaction Data from Compiled Case Histories (Reproduced from Andrus and Stokoe 2000)

penetrometers to surmount these difficulties; the Becker penetration test (BPT) in particular has become one of the more effectively and widely used larger tools. The BPT was developed in Canada in the late 1950s and consists of a 168-mm diameter, 3-m-long double-walled casing driven into the ground with a double-acting diesel-driven pile hammer. The hammer impacts are applied at the top of the casing and peneration is continuous. The Becker penetration resistance is defined as the number of blows required to drive the casing through an increment of 300 mm.

^V The BPT has not been standardized, and several different types of equipment and procedures have been used. There are currently very few liquefaction sites from which BPT data have been obtained. Thus the BPT cannot be directly correlated with field behavior, but rather through estimating equivalent SPT *N*-values from BPT data and then applying evaluation procedures based on the SPT. This indirect method introduces substantial additional uncertainty into the calculated CRR.

To provide uniformity, Harder and Seed (1986) recommended newer AP-1000 drill rigs equipped with supercharged diesel hammers, 168-mm outside diameter casing, and a plugged bit. From several sites where both BPT and SPT tests were conducted in parallel soundings, Harder and Seed (1986) developed a preliminary correlation between Becker and standard penetration resistance [Fig. 10(a)]. Additional comparative data compiled since 1986 are plotted in Fig. 10(b). The original Harder and Seed correlation curve (solid line) is drawn in Fig. 10(b) along with dashed curves representing 20% over- and underpredictions of SPT blow counts. These plots indicate that SPT blow counts can be roughly estimated



FIG. 10. Correlation between Corrected Becker Penetration Resistance N_{BC} and Corrected SPT Resistance N_{60} : (a) Harder and Seed (1986); (b) Data from Additional Sites (Reproduced from Harder 1997)

from BPT measurements. These plots indicate that although SPT blow counts can be roughly estimated from BPT measurements, there can be considerable uncertainty for calculating liquefaction resistance because the data scatter is greatest in the range of greatest importance [N-values of 0-30 blows/ 300 mm (ft)].

A major source of variation in BPT blow counts is deviations in hammer energy. Rather than measuring hammer energy directly, Harder and Seed (1986) monitored bouncechamber pressures and found that uniform ⁴ combustion conditions (e.g., full throttle with a supercharger) correlated rather well with variations in Becker blow count. From this information, Harder and Seed developed an energy correction procedure based on measured bounce-chamber pressure.

Direct measurement of transmitted hammer energy could provide a more theoretically rigorous correction for Becker hammer efficiency. Sy and Campanella (1994) and Sy et al. (1995) instrumented a small length of Becker casing with strain gauges and accelerometers to measure transferred energy. They analyzed the recorded data with a pile-driving analyzer to determine strain, force, acceleration, and velocity. The transferred energy was determined by time integration of force times velocity. They were able to verify many of the variations in hammer energy previously identified by Harder and Seed (1986), including effects of variable throttle settings and energy transmission efficiencies of various drill rigs. However, they were unable to reduce the amount of scatter and uncertainty in converting BPT blow counts to SPT blow counts. Because the Sy and Campanella procedure requires considerably more effort than monitoring of bounce-chamber pressure without producing greatly improved results, the workshop participants agreed that the bounce-chamber technique is adequate for routine practice.

Friction along the driven casing also influences penetration resistance. Harder and Seed (1986) did not directly evaluate the effect of casing friction; hence, the correlation in Fig. 10(b) intrinsically incorporates an unknown amount of casing friction. However, casing friction remains a concern for depths >30 m and for measurement of penetration resistance in soft soils underlying thick deposits of dense soil. Either of these circumstances could lead to greater casing friction than is intrinsically incorporated in the Harder and Seed correlation.

The following procedures are recommended for routine practice: (1) the BPT should be conducted with newer AP-1000 drill rigs equipped with supercharged diesel hammers to drive plugged 168-mm outside diameter casing; (2) bouncechamber pressures should be monitored and adjustments made to measured BPT blow counts to account for variations in diesel hammer combustion efficiency-for most routine applications, correlations developed by Harder and Seed (1986) may be used for these adjustments; and (3) the influence of some casing friction is indirectly accounted for in the Harder and Seed BPT-SPT correlation. This correlation, however, has not been verified and should not be used for depths >30 m or for sites with thick dense deposits overlying loose sands or gravels. For these conditions, mudded boreholes may be needed to reduce casing friction, or specially developed local correlations or sophisticated wave-equation analyses may be applied to quantify frictional effects.

MAGNITUDE SCALING FACTORS (MSFs)

The clean-sand base or CRR curves in Figs. 2 (SPT), 4 (CPT), and 10 (V_{s1}) apply only to magnitude 7.5 earthquakes. To adjust the clean-sand curves to magnitudes smaller or larger than 7.5, Seed and Idriss (1982) introduced correction factors termed "magnitude scaling factors (MSFs)." These factors are used to scale the CRR base curves upward or downward on CRR versus $(N_{1})_{60}$, q_{c1N} , or V_{s1} plots. Conversely, magnitude

weighting factors, which are the inverse of magnitude scaling factors, may be applied to correct CSR for magnitude. Either correcting CRR via magnitude scaling factors, or correcting CSR via magnitude weighting factors, leads to the same final result. Because the original papers by Seed and Idriss were written in terms of magnitude scaling factors, the use of magnitude scaling factors is continued in this report.

To illustrate the influence of magnitude scaling factors on calculated hazard, the equation for factor of safety (FS) against liquefaction is written in terms of CRR, CSR, and MSF as follows:

$$FS = (CRR_{7.5}/CSR)MSF$$
(23)

where CSR = calculated cyclic stress ratio generated by the earthquake shaking; and $CRR_{7.5} =$ cyclic resistance ratio for magnitude 7.5 earthquakes. $CRR_{7.5}$ is determined from Fig. 2 or (4) for SPT data, Fig. 4 or (11) for CPT data, or Fig. 9 or (22) for V_{s1} data.

Seed and Idriss (1982) Scaling Factors

Because of the limited amount of field liquefaction data available in the 1970s, Seed and Idriss (1982) were unable to adequately constrain bounds between liquefaction and nonliquefaction regions on CRR plots for magnitudes other than 7.5. Consequently, they developed a set of MSF from average numbers of loading cycles for various earthquake magnitudes and laboratory test results. A representative curve developed by these investigators, showing the number of loading cycles required to generate liquefaction for a given CSR, is reproduced in Fig. 11. The average number of loading cycles for various magnitudes of earthquakes are also noted on the plot. The initial set of magnitude scaling factors was derived by dividing CSR values on the representative curve for the number of loading cycles corresponding to a given earthquake magnitude by the CSR for 15 loading cycles (equivalent to a magnitude 7.5 earthquake). These scaling factors are listed in column 2 of Table 3 and are plotted in Fig. 12. These MSFs have been routinely applied in engineering practice since their introduction in 1982.

Revised Idriss Scaling Factors

In preparing his H. B. Seed Memorial Lecture, I. M. Idriss reevaluated the data that he and the late Professor Seed used to calculate the original (1982) magnitude scaling factors. In so doing, Idriss replotted the data on a log-log plot and suggested that the data should plot as a straight line. He noted, however, that one outlying point had strongly influenced the original analysis, causing the original plot to be nonlinear and characterized by unduly low MSF values for magnitudes <7.5. Based on this reevaluation, Idriss defined a revised set of magnitude scaling factors listed in column 3 of Table 3 and plotted



FIG. 11. Representative Relationship between CSR and Number of Cycles to Cause Liquefaction (Reproduced from Seed and Idriss 1982)

826 / JOURNAL OF GEOTECHNICAL AND GEOENVIRONMENTAL ENGINEERING / OCTOBER 2001

	Seed and		Ambraseys (1988)	Arango	(1996)	Andrus and	Youd and Noble (1997b)				
Magnitude, M	Idriss (1982)	Idriss*		Distance based	Energy based	Stokoe (1997)	$P_L < 20\%$	P _L < 32%	$P_{1} < 50\%$		
5.5	1,43	2.20	2.86	3.00	2.20	2.8	2.86	3.42	4 44		
6.0	1.32	1.76	2.20	2.00	1.65	2.0	1.02	3.42	4.44		
6.5	1.19	1.44	1.69	1.60	1.00	1.6	1.95	2.55	2.92		
7.0	1.08	1 19	1 30	1.00	1.40	1.0	1.54	1.00	1.99		
7.5	1.00	1.00	1.00	1.2.5	1.10	1.25	1.00	1.20	1.39		
80	0.04	0.94	1.00	1.00	1.00	1.00			1.00		
85	0.94	0.04	0.07	0.75	4,85	0.87		S 1.2	0.73?		
0.5	0.89	0.72	0.44	6 - 1	¥	0.65?	- 16° 💶 - 10°		0.56?		

Note: ? = Very uncertain values.

1995 Seed Memorial Lecture, University of California at Berkeley (I. M. Idriss, personal communication to T. L. Youd, 1997).



FIG. 12. Magnitude Scaling Factors Derived by Various Investigators (Reproduced from Youd and Noble 1997a)

in Fig. 12. The revised MSFs are defined by the following equation:

$$MSF = 10^{2.24} / M_w^{2.56}$$
(24)

The workshop participants recommend these revised scaling factors as a lower bound for MSF values.

The revised scaling factors are significantly higher than the original scaling factors for magnitudes <7.5 and somewhat lower than the original factors for magnitudes >7.5. Relative to the original scaling factors, the revised factors lead to a reduced calculated liquefaction hazard for magnitudes <7.5, but increase calculated hazard for magnitudes >7.5.

Ambraseys (1988) Scaling Factors

Field performance data collected since the 1970s for magnitudes <7.5 indicate that the original Seed and Idriss (1982) scaling factors are overly conservative. For example, Ambraseys (1988) analyzed liquefaction data compiled through the mid-1980s and plotted calculated cyclic stress ratios for sites that did or did not liquefy versus $(N_1)_{60}$. From these plots, Ambraseys developed empirical exponential equations that define CRR as a function of $(N_1)_{60}$ and moment magnitude M_{w} . By holding the value of $(N_1)_{60}$ constant in the equations and taking the ratio of CRR determined for various magnitudes of earthquakes to the CRR for magnitude 7.5 earthquakes, Ambraseys derived the magnitude scaling factors listed in column 4 of Table 3 and plotted in Fig. 12. For magnitudes <7.5, the MSFs suggested by Ambraseys are significantly larger than both the original factors developed by Seed and Idriss (column 2, Table 3) and the revised factors suggested by Idriss (column 3). Because they are based on observational data, these factors have validity for estimating liquefaction hazard; however, they have not been widely used in engineering practice.

For magnitudes >7.5, Ambraseys factors are significantly lower and much more conservative than the original (Seed and Idriss 1982) and Idriss's revised scaling factors. Because there are few data to constrain Ambraseys' scaling factors for magnitudes >7.5, they are not recommended for hazard evaluation for large earthquakes.

Arango (1996) Scaling Factors

Arango (1996) developed two sets of magnitude scaling factors. The first set (column 5, Table 3) is based on furthest observed liquefaction effects from the seismic energy source, the estimated average peak accelerations at those distant sites, and the seismic energy required to cause liquefaction. The second set (column 6, Table 3) was developed from energy concepts and the relationship derived by Seed and Idriss (1982) between numbers of significant stress cycles and earthquake magnitude. The MSFs listed in column 5 are similar in value (within about 10%) to the MSFs of Ambraseys (column 4), and the MSFs listed in column 6 are similar in value (within about 10%) to the revised MSFs proposed by Idriss (column 3).

Andrus and Stokoe (1997) Scaling Factors

From their studies of liquéfaction resistance as a function of shear wave velocity V, Andrus and Stokoe (1997) drew bounding curves and developed (22) for calculating CRR from V. for magnitude 7.5 earthquakes. These investigators drew similar bounding curves for sites where surface effects of liquefaction were or were not observed for earthquakes with magnitudes of 6, 6.5, and 7. The positions of the CRR curves were visually adjusted on each graph until a best-fit bound was obtained. Magnitude scaling factors were then estimated by taking the ratio of CRR for a given magnitude to the CRR for magnitude 7.5 earthquakes. These MSFs are quantified by the following equation:

$$MSF = (M_{w}/7.5)^{-2.56}$$
(25)

MSFs for magnitudes <6 and >7.5 were extrapolated from this equation. The derived MSFs are listed in column 7 of Table 3, and plotted in Fig. 12. For magnitudes <7.5, the MSFs proposed by Andrus and Stokoe are rather close in value (within about 5%) to the MSFs proposed by Ambraseys. For magnitudes >7.5, the Andrus and Stokoe MSFs are slightly smaller than the revised MSFs proposed by Idriss.

Youd and Noble (1997a) Scaling Factors

Youd and Noble (1997a) used a probabilistic or logistic analysis to analyze case history data from sites where effects of liquefaction were or were not reported following past earthquakes. This analysis yielded the following equation, which was updated after publication of the NCEER proceedings (Youd and Idriss 1997):

$$Logit(P_L) = \ln(P_L/(1 - P_L)) = -7.0351 + 2.1738M_w$$

$$- 0.2678(N_1)_{60cs} + 3.0265 \ln CRR$$
 (26)

where P_L = probability that liquefaction occurred; $1 - P_L$ = probability that liquefaction did not occur; and $(N_1)_{60cs}$ = corrected equivalent clean-sand blow count. For magnitudes <7.5, Youd and Noble recommended direct application of this equation to calculate the CRR for a given probability of liquefaction. In lieu of direct application, Youd and Noble defined three sets of MSFs for use with the simplified procedure. These MSFs are for probabilities of liquefaction occurrence <20, 32, and 50%, respectively, and are defined by the following equations:

Probability $P_L < 20\%$ MSF = $10^{3.81}/M^{4.53}$ for $M_w < 7$ (27) Probability $P_L < 32\%$ MSF = $10^{3.74}/M^{4.33}$ for $M_w < 7$ (28)

Probability $P_L < 50\%$ MSF = $10^{4.21}/M^{4.81}$ for $M_w < 7.75$ (29)

New Recommendation by Idriss

I. M. Idriss (TRB 1999) proposed a new set of MSFs that are compatible with, and are only to be used with, the magnitude-dependent r_d that he also proposed. These new MSFs have lower values than the revised MSFs listed in Table 3, but slightly higher values than the original Seed and Idriss (1982) MSFs. Because the proposed r_d and associated MSFs have not been published and the factors have not been independently verified, the workshop participants chose not to recommend the new r_d or MSFs at this time.

Recommendations for Engineering Practice

The workshop participants reviewed the MSFs listed in Table 3, and all but one (S. S. C. Liao) agree that the original factors were too conservative and that increased MSFs are warranted for engineering practice for magnitudes <7.5. Rather than recommending a single set of factors, the workshop participants suggest a range of MSFs from which the engineer is allowed to choose factors that are requisite with the acceptable risk for any given application. For magnitudes <7.5, the lower bound for the recommended range is the new MSF proposed by Idriss [column 3 in Table 3, or (23)]. The suggested upper bound is the MSF proposed by Andrus and Stokoe [column 7 in Table 3, or (26)]. The upper-bound values are consistent with MSFs suggested by Ambraseys (1988), Arango (1996), and Youd and Noble (1997a) for $P_L < 20\%$.

For magnitudes >7.5, the new factors recommended by Idriss [column 3 in Table 3; (25)] should be used for engineering practice. These new factors are smaller than the original Seed and Idriss (1982) factors, hence their application leads to increased calculated liquefaction hazard compared to the original factors. Because there are only a few well-documented liquefaction case histories for earthquakes with magnitudes >8, MSFs in that range are poorly constrained by field data. Thus the workshop participants agreed that the greater conservatism embodied in the revised MSF by Idriss (column 3, Table 3) should be recommended for engineering practice.

CORRECTIONS FOR HIGH OVERBURDEN STRESSES, STATIC SHEAR STRESSES, AND AGE OF DEPOSIT

Correction factors K_{σ} and K_{α} were developed by Seed (1983) to extrapolate the simplified procedure to larger overburden pressure and static shear stress conditions than those embodied in the case history data set from which the simplified procedure was derived. As noted previously, the simplified procedure was developed and validated only for level to gently sloping sites (low static shear stress) and depths less than about 15 m (low overburden pressures). Thus applications using K_{σ} and K_{α} are beyond routine practice and require specialized expertise. Because these factors were discussed at the workshop and some new information was developed, recommendations from those discussions are included here. These recommendations, however, apply mostly to liquefaction hazard analyses of embankment dams and other large structures. These factors are applied by extending (23) to include K_{σ} and K_{α} as follows:

$$FS = (CRR_{7.5}/CSR) \cdot MSF \cdot K_{\sigma} \cdot K_{\alpha}$$
(30)

K, Correction Factor

Cyclically loaded laboratory test data indicate that liquefaction resistance increases with increasing confining stress. The rate of increase, however, is nonlinear. To account for the nonlinearity between CRR and effective overburden pressure, Seed (1983) introduced the correction factor K_{σ} to extrapolate the simplified procedure to soil layers with overburden pressures >100 kPa. Cyclically loaded, isotropically consolidated triaxial compression tests on sand specimens were used to measure CRR for high-stress conditions and develop K_{σ} values. By taking the ratio of CRR for various confining pressures to the CRR determined for approximately 100 kPa (1 atm) Seed (1983) developed the original K_{σ} correction curve. Other investigators have added data and suggested modifications to better define K_{σ} for engineering practice. For example, Seed and Harder (1990) developed the clean-sand curve reproduced in Fig. 13. Hynes and Olsen (1999) compiled and analyzed an enlarged data set to provide guidance and formulate equations for selecting K_{σ} values (Fig. 14). The equation they derived for calculating K_{σ} is

$$K_{\sigma} = (\sigma_{vo}'/P_a)^{(f-1)} \tag{31}$$

where σ'_{vo} , effective overburden pressure; and P_a , atmospheric pressure, are measured in the same units; and f is an exponent that is a function of site conditions, including relative density, stress history, aging, and overconsolidation ratio. The work-shop participants considered the work of previous investigators and recommend the following values for f (Fig. 15). For relative densities between 40 and 60%, f = 0.7-0.8; for relative densities between 60 and 80%, f = 0.6-0.7. Hynes and Olsen recommended these values as minimal or conservative esti-



FIG. 13. K_{o} -Values Determined by Various Investigators (Reproduced from Seed and Harder 1990)

828 / JOURNAL OF GEOTECHNICAL AND GEOENVIRONMENTAL ENGINEERING / OCTOBER 2001



FIG. 14. Laboratory Data and Compiled K_{σ} Curves (Reproduced from Hynes and Olsen 1999)



FIG. 15. Recommended Curves for Estimating K_{σ} for Engineering Practice

mates of K_{σ} for use in engineering practice for both clean and silty sands, and for gravels. The workshop participants concurred with this recommendation.

K_a Correction Factor for Sloping Ground

The liquefaction resistance of dilative soils (moderately dense to dense granular materials under low confining stress) increases with increased static shear stress. Conversely, the liquefaction resistance of contractive soils (loose soils and moderately dense soils under high confining stress) decreases with increased static shear stresses. To incorporate the effect of static shear stresses on liquefaction resistance, Seed (1983) introduced a correction factor K_{α} . To generate values for this factor, Seed normalized the static shear stress τ_{sr} acting on a plane with respect to the effective vertical stress $\sigma'_{v\alpha}$ yielding a parameter α , where

$$\alpha = \tau_{st} / \sigma_{vo}' \tag{32}$$

Gyclically loaded triaxial compression tests were then used to empirically determine values of the correction factor K_{α} as a function of α .

For the NCEER workshop, Harder and Boulanger (1997) reviewed past publications, test results, and analyses of K_{α} . They noted that a wide range of K_{α} values have been proposed,

indicating a lack of convergence and a need for continued research. The workshop participants agreed with this assessment. Although curves relating K_{α} to α have been published (Harder and Boulanger 1997), these curves should not be used by nonspecialists in geotechnical earthquake engineering or in routine engineering practice.

Influence of Age of Deposit

Several investigators have noted that liquefaction resistance of soils increases with age. For example, Seed (1979) observed significant increases in liquefaction resistance with aging of reconstituted sand specimens tested in the laboratory. Increases of as much as 25% in cyclic resistance ratio were noted between freshly constituted and 100-day-old specimens. Youd and Hoose (1977) and Youd and Perkins (1978) noted that liquefaction resistance increases markedly with geologic age. Sediments deposited within the past few thousand years are generally much more susceptible to liquefaction than older Holocene sediments; Pleistocene sediments are even more resistant; and pre-Pleistocene sediments are generally immune to liquefaction. Although qualitative time-dependent increases have been documented as noted above, few quantitative data a have been collected. In addition, the factors causing increased liquefaction resistance with age are poorly understood. Consequently, verified correction factors for age have not been developed.

In the absence of quantitative correction factors, engineering judgment is required to estimate the liquefaction resistance of sediments more than a few thousand years old. For deeply buried sediments dated as more than a few thousand years old, some knowledgeable engineers have omitted application of the K_{σ} factor as partial compensation for the unquantified, but substantial increase of liquefaction resistance with age. For manmade structures, such as thick fills and embankment dams, aging effects are minimal, and corrections for age should not be applied in calculating liquefaction resistance.

SEISMIC FACTORS

Application of the simplified procedure for evaluating liquefaction resistance requires estimates of two ground motion parameters—earthquake magnitude and peak horizontal ground acceleration. These factors characterize duration and intensity of ground shaking, respectively. The workshop addressed the following questions with respect to selection of magnitude and peak acceleration values for liquefaction resistance analyses.

Earthquake Magnitude

Records from recent earthquakes, such as 1979 Imperial Valley, 1988 Armenia, 1989 Loma Prieta, 1994 Northridge, and 1995 Kobe, indicate that the relationship between duration and magnitude is rather uncertain and that factors other than magnitude also influence duration. For example, unilateral faulting, in which rupture begins at one end of the fault and propagates to the other, usually produces longer shaking duration for a given magnitude than bilateral faulting, in which slip begins near the midpoint on the fault and propagates in both directions simultaneously. Duration also generally increases with distance from the seismic energy source and may vary with tectonic province, site conditions, and bedrock topography (basin effects).

Question: Should correction factors be developed to adjust duration of shaking to account for the influence of earthquake source mechanism, fault rupture mode, distance from the energy source, basin effects, etc.?

Answer: Faulting characteristics and variations in shaking duration are difficult to predict in advance of an earthquake event. The influence of distance generally is of secondary importance within the range of distances to which damaging liquefaction effects commonly develop. Basin effects are not yet sufficiently predictable to be adequately accounted for in engineering practice. Thus the workshop participants recommend continued use of the generally conservative relationship between magnitude and duration that is embodied in the simplified procedure.

Question: An important difference between eastern U.S. earthquakes and western U.S. earthquakes is that eastern ground motions are generally richer in high-frequency energy and thus could generate more significant stress cycles and equivalently longer durations than western earthquakes of the same magnitude. Is a correction needed to account for higher frequencies of motions generated by eastern U.S. earthquakes?

Answer: The high-frequency motions of eastern earthquakes are generally limited to near-field rock sites. High-frequency motions attenuate or are damped out rather quickly as they propagate through soil layers. This filtering action reduces the high-frequency energy at soil sites and thus reduces differences in numbers of significant loading cycles. Because liquefaction occurs only within soil strata, duration differences on soil sites between eastern and western earthquakes are not likely to be great. Without more instrumentally recorded data from which differences in ground motion characteristics can be quantified, there is little basis for the development of additional correction factors for eastern localities.

Another difference between eastern and western U.S. earthquakes is that strong ground motions generally propagate to greater distances in the east than in the west. By applying present state-of-the-art procedures for estimating peak ground acceleration at eastern sites, differences in amplitudes of ground motions between western and eastern earthquakes are properly taken into account.

Question: Which magnitude scale should be used for selection of earthquake magnitudes for liquefaction resistance analyses?

Answer: Seismologists commonly calculate earthquake magnitudes using five different scales: (1) local or Richter magnitude M_L ; (2) surface-wave magnitude M_r ; (3) short-period body-wave magnitude m_b ; (4) long-period body-wave magnitude m_B ; and (5) moment magnitude M_w . Moment magnitude, the scale most commonly used for engineering applications, is the scale preferred for calculation of liquefaction resistance. As Fig. 16 shows, magnitudes from other scales may be substituted directly for M_w within the following limitations— $M_L < 6$, $m_B < 7.5$, and $6 < M_s < 8--m_b$, a scale commonly used for eastern U.S. earthquakes, may be used for magnitudes between 5 and 6, provided m_b values are corrected to equivalent M_w values. The curves plotted in Fig. 16 may be used for this adjustment (Idriss 1985).

Peak Acceleration

In the simplified procedure, peak horizontal acceleration a_{\max} is used to characterize the intensity of ground shaking. To provide guidance for estimation of a_{\max} , the workshop addressed the following questions.

Question: What procedures are preferred for estimating a_{max} at potentially liquefiable sites?

Answer: The following methods, in order of preference, may be used for estimating a_{max} :

1) The preferred method for estimating a_{max} is through empirical correlations of a_{max} with earthquake magnitude, distance from the seismic energy source, and local site conditions. Several correlations have been published for estimating a_{max} for sites on bedrock or stiff to moderately stiff soils. Preliminary attenuation relationships have also been developed for a limited range of soft soil sites (Idriss 1991). Selection of an at-



FIG. 16. Relationship between Moment M_w and Other Magnitude Scales (Reproduced from Heaton et al., Unpublished Report, 1982)

tenuation relationship should be based on such factors as region of the country, type of faulting, and site condition.

2) For soft sites and other soil profiles that are not compatible with available attenuation relationships, a_{max} may be estimated from local site response analyses. Computer programs such as SHAKE and DESRA may be used for these calculations (Schnabel et al. 1972; Finn et al. 1977). Input ground motions in the form of recorded accelerograms are preferable to synthetic records. Accelerograms derived from white noise should be avoided. A suite of plausible earthquake records should be used in the analysis, including as many as feasible from earthquakes with similar magnitudes, source distances, etc.

3) The third and least desirable method for estimating peak ground acceleration is through amplification ratios, such as those developed by Idriss (1990, 1991) and Seed et al. (1994). These factors use a multiplier or ratio by which bedrock outcrop motions are amplified to estimate surface motions at soil sites. Because amplification ratios are influenced by strain level, earthquake magnitude, and frequency content, caution and considerable engineering judgment are required in the application of these relationships.

Question: Which peak acceleration should be used: (1) the largest horizontal acceleration recorded on a three-component accelerogram; (2) the geometric mean (square root of the product) of the two maximum horizontal components; or (3) a vectorial combination of horizontal accelerations?

Answer: According to I. M. Idriss (oral discussion at NCEER workshop, 1996), where recorded motions were available, the larger of the two horizontal peak components of acceleration was used in the compilation of data used to derive the original simplified procedure. Where recorded values were not available, which was the circumstance for most sites, peak acceleration values were estimated from attenuation relationships based on the geometric mean of the two orthogonal peak horizontal accelerations. In nearly all instances where recorded motions were used, the peaks from the two horizontal records were approximately equal. Thus where a single peak was used, the peak and the geometric mean of the two peaks were about the same value. Based on this information, the workshop participants concurred that use of the geometric mean is consistent with the development of the procedure and is preferred for use in engineering practice. However, use of the larger of

830 / JOURNAL OF GEOTECHNICAL AND GEOENVIRONMENTAL ENGINEERING / OCTOBER 2001

the two orthogonal peak accelerations yields a larger estimate of a_{max} , is conservative, and is allowable. Vectorial accelerations are seldom calculated and should not be used. Peak vertical accelerations are generally much smaller than peak horizontal accelerations and are ignored for calculation of liquefaction resistance.

Question: Liquefaction usually develops at soil sites where ground motion amplification may occur and where sediment may soften, reducing motions as excess pore pressure develop. How should investigators account for these factors in estimating peak acceleration?

Answer: The recommended procedure is to calculate or estimate the a_{max} that would occur at the site in the absence of increased pore pressure or the onset of liquefaction. That peak acceleration incorporates the influence of site amplification, but neglects the influence of excess pore-water pressure.

Question: Should high-frequency spikes (periods <0.1 s) in acceleration records be considered or ignored?

Answer: In general, short-duration, high-frequency acceleration spikes are too short in duration to generate significant instability or deformation of granular structures, and should be ignored. By using attenuation relationships for estimation of peak acceleration, as noted above, high-frequency spikes are evsentially ignored because few high-frequency peaks are incorporated in databases from which attenuation the relationships were derived. Similarly, ground response analyses programs such as SHAKE and DESRA generally attenuate or filter out high-frequency spikes, reducing their influence. Where amplification ratios are used, engineering judgment should be used to determine which bedrock acceleration is to be amplified.

ENERGY-BASED CRITERIA AND PROBABILISTIC ANALYSES

The workshop considered two additional topics: (1) liquefaction resistance criteria based on seismic energy passing through a liquefiable layer (Kayen and Mitchell 1997; Youd et al. 1997), and probabilistic analyses of case history data (Liao et al. 1988; Youd and Noble 1997b). Although probabilistic or risk analyses have been made for some localities and critical facilities, the workshop participants concluded that probabilistic procedures are still under development and not sufficiently formulated for routine engineering practice. Similarly, new energy-based criteria need to be independently tested before recommendations can be made for general practice. The workshop participants recommend that research and development continue on both of these relatively new and potentially useful procedures.

CONCLUSIONS

The participants in the NCEER workshop reviewed the state-of-the-art for evaluating liquefaction resistance and recommend several augmentations to that procedure. Specific recommendations, including procedures and equations, are listed in each section of this summary paper. Consensus conclusions from the workshop are:

- 1. Four field tests are recommended for routine evaluation of liquefaction resistance—the cone penetration test (CPT), the standard penetration test (SPT), shear-wave ,velocity (V_s) measurements, and for gravelly sites the Gecker penetration test (BPT). Criteria for each test were
- reviewed and revised to incorporate recent developments and to achieve consistency between resistances calculated from the various tests. Each test has its advantages and limitations (Table 1). the CPT provides the most detailed soil stratigraphy and robust field-data based liq-

uefaction resistance curves now available. CPT testing should always be accompanied by soil sampling for validation of soil type identification. The SPT has a longer record of application and provides disturbed soil samples from which fines content and other grain characteristics can be determined. Measured shear-wave velocities provide fundamental information on small-strain soil behavior that is useful beyond analyses of liquefaction resistance. V_s is also applicable at sites, such as landfills and gravelly sediments, where CPT and SPT soundings may not be possible or reliable. The BPT test is recommended only for gravelly sites and requires use of rough correlations between BPT and SPT, making the results less certain than other tests. Where possible, two or more test procedures should be applied to assure adequate definition of soil stratigraphy and a consistent evaluation of liquefaction resistance.

- 2. The magnitude scaling factors originally derived by Seed and Idriss (1982) are overly conservative for earthquakes with magnitudes <7.5. A range of scaling factors is recommended for engineering practice, the lower end of the range being the new MSF recommended by Idriss (column 3, Table 3), and the upper end of the range being the MSF suggested by Andrus and Stokoe (column 7, Table 3). These MSFs are defined by (25) and (26), respectively. For magnitudes >7.5, the new factors by Idriss (column 3, Table 3) should be used. These factors, which are more conservative than the original Seed and Idriss (1982) factors, should be applied.
- 3. The K_{σ} factors suggested by Seed and Harder (1990) appear to be overly conservative for some soils and field conditions. The workshop participants recommend K_{σ} values defined by the curves in Fig. 14 or (31). Because K_{σ} values are usually applied to depths greater than those verified for the simplified procedure, special expertise is generally required for their application.
- 4. Procedures for evaluation of liquefaction resistance beneath sloping ground or embankments (slopes greater than about 6%) have not been developed to a level allowable for routine use. Special expertise is required for evaluation of liquefaction resistance beneath sloping ground.
- 5. Moment magnitude M_w should be used for liquefaction resistance calculations. Magnitude, as used in the simplified procedure, is a measure of the duration of strong ground shaking. The present magnitude criteria are conservative and should not be corrected for source mechanism, style of faulting, distance from the energy source, subsurface bedrock topography (basin effect), or tectonic region (eastern versus western U.S. earthquakes).
- 6. The peak acceleration a_{max} applied in the procedure is the peak horizontal acceleration that would occur at ground surface in the absence of pore pressure increases or liquefaction. Attenuation relationships compatible with soil conditions at a site should be applied in estimating a_{max} . Relationships based on the geometric mean of the peak horizontal accelerations are preferred, but use of relationships based on peak horizontal acceleration is allowable and conservative. Where site conditions are incompatible with existing attenuation relationships, sitespecific response calculations, using programs such as SHAKE or DESRA, should be used. The least preferable technique is application of amplification factors.

ACKNOWLEDGMENTS

Financial support for the January 1996 workshop was provided by the NCEER. Support for a second workshop in August 1998 was provided by both NCEER and the National Science Foundation. Brigham Young

University graduate students Steven Noble, Samuel Gilstrap, and Curt Peterson, assisted in organizing and conducting the workshops.

REFERENCES

- Ambraseys, N. N. (1988). "Engineering seismology." Earthquake Engrg. and Struct. Dynamics, 17, 1-105.
- Andrus, R. D., and Stokoe, K. H., II (1997). "Liquefaction resistance based on shear wave velocity." Proc., NCEER Workshop on Evaluation of Liquefaction Resistance of Soils, Nat. Ctr. for Earthquake Engrg. Res., State Univ. of New York at Buffalo, 89-128.
- Andrus, R. D., and Stokoe, K. H., II (2000). "Liquefaction resistance of soils from shear-wave velocity." J. Geotech. and Geoenvir. Engrg., ASCE, 126(11), 1015-1025.
- Arango, I. (1996). "Magnitude scaling factors for soil liquefaction evaluations." J. Geotech. Engrg., ASCE, 122(11), 929-936.
- ASTM. (2000). "Annual book of ASTM standards." 04.08, D 1586-99, West Conshohocken, Pa.
- Castro, G. (1995). "Empirical methods in liquefaction evaluation." Primer Ciclo d Conferencias Internationales, Leonardo Zeevaert, Universidad Nacional Autonoma de Mexico, Mexico City.
- Finn, W. D. L., Martin, G. R., and Lee, K. W. (1977). "An effective stress model for liquefaction." J. Geotech. Engrg Div., ASCE, 103(6), 517-533.
- Gibbs, H. J., and Holtz, W. G. (1957). "Research on determining the density of sand by spoon penetration testing." Proc., 4th Int. Conf. on Soil Mech. and Found. Engrg., Vol. I, 35-39.
- Gilstrap, S. D., and Youd, T. L. (1998). "CPT based liquefaction resistance analyses using case histories." *Tech. Rep. CEG-90-01*, Dept. of Civ. and Envir. Energ. Brigham Young University, Provo, Utah.
- Civ. and Envir. Engrg., Brigham Young University, Provo, Utah. Golesorkhi, R. (1989). "Factors influencing the computational determination of earthquake-induced shear stresses in sandy soils." PhD dissertation, University of California at Berkeley.
- Harder, L. F., Jr. (1988). "Use of penetration tests to determine the cyclic loading resistance of gravelly soils during earthquake shaking." PhD dissertation, University of California at Berkeley.
- Harder, L. F., Jr. (1997). "Application of the Becker Penetration test for evaluating the liquefaction potential of gravelly soils." Proc., NCEER Workshop on Evaluation of Liquefaction Resistance of Soils. National Center for Engineering Research, Buffalo, 129-148.
- Harder, L. F., Jr., and Boulanger, R. W. (1997). "Application of K_{σ} and K_{α} correction factors." *Proc.*, *NCEER Workshop on Evaluation of Liquefaction Resistance of Soils*, Nat. Ctr. for Earthquake Engrg. Res., State Univ. of New York at Buffalo, 167-190.
- Harder, L. F., Jr., and Seed, H. B. (1986). "Determination of penetration resistance for coarse-grained soils using the Becker harmer drill." *Rep.* UCB/EERC-86/06, Earthquake Engrg. Res. Ctr., University of California at Berkeley.
- Hynes, M. E., and Olsen, R. S. (1999). "Influence of confining stress on liquefaction resistance." Proc., Int. Workshop on Phys. and Mech. of Soil Liquefaction, Balkema, Rotterdam, The Netherlands, 145-152.
- Idriss, I. M. (1985). "Evaluating seismic risk in engineering practice." Proc., 11th Int. Conf. on Soil Mech. and Found. Engrg., Vol. 1, 255-320.
- Idriss, I. M. (1990). "Response of soft soil sites during earthquakes." Proc., H. Bolton Seed Memorial Symp., Vol. 2, BiTech Publishers, Ltd., Vancouver, 273-290.
- Idriss, I. M. (1991). "Earthquake ground motions at soft soil sites." Proc., 2nd Int. Conf. on Recent Adv. in Geotech. Earthquake Engrg. and Soil Dyn., Vol. 3, 2265-2271.
- Kayen, R. E., and Mitchell, J. K. (1997). "Assessment of liquefaction potential during earthquakes by Arias intensity." J. Geotech and Geoenvir. Engrg., ASCE, 123(12), 1162-1174.
- Kayen, R. E., Mitchell, J. K., Seed, R. B., Lodge, A., Nishio, S., and Coutinho, R. (1992). "Evaluation of SPT-, CPT-, and shear wave-based methods for liquefaction potential assessment using Loma Prieta data." Proc., 4th Japan-U.S. Workshop on Earthquake-Resistant Des. of Lifeline Fac. and Countermeasures for Soil Liquefaction, Vol. 1, 177-204.
- Kramer S. L. (1996). Geotechnical earthquake engineering, Prentice-Hall, Englewood Cliffs, N.J., 653.
- Liao, S., and Whitman, R. V. (1986a). "Overburden correction factors for SPT in sand." J. Geotech. Engrg., ASCE, 112(3), 373-377.
- Liao, S. S. C., Veneziano, D., and Whitman, R. V. (1988). "Regression models for evaluating liquefaction probability." J. Geotech. Engrg., ASCE, 114(4), 389-411.
- Liao, S. S. C., and Whitman, R. V. (1986b). "Catalogue of liquefaction and non-liquefaction occurrences during earthquakes." *Res. Rep.*, Dept. of Civ. Engrg., Massachusetts Institute of Technology, Cambridge, Mass.

Lodge, A. L. (1994). "Shear wave velocity measurements for subsurface

characterization." PhD dissertation, University of California at Berkeley.

- Marcuson, W. F., III (1978). "Definition of terms related to liquefaction." J. Geotech, Engrg. Div., ASCE, 104(9), 1197-1200.
- Marcuson, W. F., III, and Bieganousky, W. A. (1977a). "Laboratory standard penetration tests on fine sands." J. Geotech. Engrg. Div., ASCE, 103(6), 565-588.
- Marcuson, W. F., III, and Bieganousky, W. A. (1977b). "SPT and relative density in coarse sands." J. Geotech. Engrg. Div., ASCE, 103(11), 1295-1309.
- National Research Council (NRC). (1985). Liquefaction of soils during earthquakes, National Academy Press, Washington, D.C.
- Olsen, R. S. (1984). "Liquefaction analysis using the cone penetrometer test (CPT)." Proc., 8th World Conf. on Earthquake Engrg., Vol. 3, 247-254.
- Olsen, R. S. (1997). "Cyclic liquefaction based on the cone penetration test." Proc., NCEER Workshop on Evaluation of Liquefaction Resistance of Soils, Nat. Ctr. for Earthquake Engrg. Res., State Univ. of New York at Buffalo, 225-276.
- Robertson, P. K. (1990). "Soil classification using CPT." Can. Geotech. J., Ottawa, 27(1), 151-158.
- Robertson, P. K., and Fear, C. E. (1995). "Liquefaction of sands and its evaluation." Proc., 1st Int. Conf. on Earthquake Geotech. Engrg.
- Robertson, P. K., Woeller, D. J., and Finn, W. D. (1992). "Seismic cone penetration test for evaluating liquefaction potential under cyclic loading." Can. Geotech. J., Ottawa, 29, 686–695.
- Robertson, P. K., and Wride, C. E. (1998). "Evaluating cyclic liquefaction potential using the cone penetration test." Can. Geotech. J., Ottawa, 35(3), 442-459.
- Schnabel, P. B., Lysmer, J., and Seed, H. B. (1972). "A computer program for earthquake response analysis of horizontally layered sites." *Rep. No. EERC* 72-12, University of California at Berkeley.
- Seed, H. B. (1979). "Soil liquefaction and cyclic mobility evaluation for level ground during earthquakes." J. Geotech. Engrg. Div., ASCE, 105(2), 201-255.
- Seed, H. B. (1983). "Earthquake-resistant design of earth dams." Proc., Symp. Seismic Des. of Earth Dams and Caverns, ASCE, New York, 41-64.
- Seed, H. B., and Idriss, I. M. (1971). "Simplified procedure for evaluating soil liquefaction potential." J. Geotech. Engrg. Div., ASCE, 97(9), 1249-1273.
- Seed, R. B., Dickenson, S. E., Rau, G. A., White, R. K., and Mok, C. M. (1994). "Site effects on strong shaking and seismic risk: Recent developments and their impact on seismic design codes and practice." *Proc., Struct. Congr. II*, Vol. 1, ASCE, New York, 573-578.
- Seed, R. B., and Harder, L. F., Jr. (1990). "SPT-based analysis of cyclic pore pressure generation and undrained residual strength." Proc., H. Bolton Seed Memorial Symp., BiTech Publishers Ltd., Vancouver, 351– 376.
- Seed, H. B., and Idriss, I. M. (1982). "Ground motions and soil liquefaction during earthquakes." Earthquake Engineering Research Institute Monograph, Oakland, Calif.
- Seed, H. B., Tokimatsu, K., Harder, L. F., and Chung, R. M. (1985). "The influence of SPT procedures in soil liquefaction resistance evaluations." J. Geotech. Engrg., ASCE, 111(12), 1425-1445. Skempton, A. K. (1986). "Standard penetration test procedures and the
- Skempton, A. K. (1986). "Standard penetration test procedures and the effects in sands of overburden pressure, relative density, particle size, aging, and overconsolidation." *Géotechnique*, London, 36(3), 425-447.
- Stark, T. D., and Olson, S. M. (1995). "Liquefaction resistance using CPT and field case histories." J. Geotech. Engrg., ASCE, 121(12), 856-869.
- Stokoe, K. H., II, Lee, S. H. H., and Knox, D. P. (1985). "Shear moduli measurements under true triaxial stresses." Advances in the art of testing under cyclic conditions, ASCE, New York, 166-185.
- Suzuki, Y., Tokimatsu, K., Koyamada, K., Taya, Y., and Kubota, Y. (1995). "Field correlation of soil liquefaction based on CPT data." Proc., Int. Symp. on Cone Penetration Testing, Vol. 2, 583-588.
- Sy, A., and Campanella, R. G. (1994). "Becker and standard penetration tests (BPT-SPT) correlations with consideration of casing friction." *Can. Geotech. J.*, Ottawa, 31, 343-356.
- Sy, A., Campanella, R. G., and Stewart, R. A. (1995). "BPT-SPT correlations for evaluation of liquefaction resistance in gravelly soils." *Proc., Spec. Session on Dyn. Properties of Gravelly Soil*, ASCE, New York.
- Sykora, D. W. (1987). "Creation of a data base of seismic shear wave velocities for correlation analysis." Geotech. Lab. Misc. Paper GL-87-26, U.S. Army Engr. Waterways Experiment Station, Vicksburg, Miss.
- Transportation Research Board (TRB). (1999). "TRB workshop on new approaches to liquefaction analysis." Publ. No. FHWA-RD-99-165, Federal Highway Administration, Washington, D.C. (on CD-ROM).

832 / JOURNAL OF GEOTECHNICAL AND GEOENVIRONMENTAL ENGINEERING / OCTOBER 2001

Tokimatsu, K., and Uchida, A. (1990). "Correlation between liquefaction resistance and shear wave velocity." Soils and Found., Tokyo, 30(2), 33-42.

- Vreugdenhil, R., Davis, R., and Berrill, J. (1994). "Interpretation of cone penetration results in multilayered soils." Int. J. Numer. and Analytical Methods in Geomech., 18, 585-599.
- Youd, T. L. (1993). "Liquefaction-induced lateral spread displacement." NCEL Tech. Note N-1862, U.S. Navy, Port Hueneme, Calif., 44.
- Youd, T. L., and Hoose, S. N. (1977). "Liquefaction susceptibility and geologic setting." Proc., 6th World Conf. on Earthquake Engrg., Vol. 3, Prentice-Hall, Englewood Cliffs, N.J., 2189-2194.
- Youd, T. L., and Idriss, I. M., eds. (1997). Proc., NCEER Workshop on Evaluation of Liquefaction Resistance of Soils, Nat. Ctr. for Earthquake Engrg. Res., State Univ. of New York at Buffalo.
- Youd, T. L., Kayen, R. E., and Mitchell, J. K. (1997). "Liquefaction criteria based on energy content of seismograms." *Proc.*, *NCEER Workshop on Evaluation of Liquefaction Resistance of Soils*, Nat. Ctr. for Earthquake Engrg. Res., State Univ. of New York at Buffalo, 217-224.
- Youd, T. L., and Noble, S. K. (1997a). "Magnitude scaling factors." Proc., NCEER Workshop on Evaluation of Liquefaction Resistance of Soils, Nat. Ctr. for Earthquake Engrg. Res., State Univ. of New York at Buffalo, 149-165.
- Youd, T. L., and Noble, S. K. (1997b). "Liquefaction criteria based on statistical and probabilistic analyses." *Proc.*, *NCEER Workshop on Evaluation of Liquefaction Resistance of Soils*, Nat. Ctr. for Earthquake Engrg. Res., State Univ. of New York at Buffalo, 201–215.
- Youd, T. L., and Perkins, D. M. (1978). "Mapping of liquefactioninduced ground failure potential." J. Geotech. Engrg. Div., ASCE, 104(4), 433-446.

NOTATION

The following symbols are used in this paper:

- a, b = curve fitting parameters for use with V_s criteria for evaluating liquefaction resistance;
- a_{max} = peak horizontal acceleration at ground surface;
- C_{B} = correction factor for borehole diameter;
- C_E = correction factor for hammer energy;
- C_N = correction factor for overburden pressure applied to SPT;
- C_{ϱ} = correction factor for overburden pressure applied to CPT;
- C_R = correction factor for drilling rod length;

 C_s = correction factor for split spoon sampler without liners;

- $CRR_{7.5}$ = cyclic resistance ratio for $M_w = 7.5$ earthquakes;
 - d_c = diameter of CPT tip;
 - F = normalized friction ratio;

- f = exponent estimated from site conditions used in calculation of K_{σ} ;
- f_s = sleeve friction measured with CPT;
- g =acceleration of gravity;
- H = thickness of thin granular layer between softer sediment layers;
- I_c = soil behavior type index for use with CPT liquefaction criteria;
- K_c = correction factor for grain characteristics applied to CPT;
- $K_{H_{ij}}$ = thin-layer correction factor for use with CPT;
- K_{α}^{γ} = correction factor for soil layers subjected to large static shear stresses;
- K_{σ} = correction factor for soil layers subjected to large static normal stresses;
- M_L = local or Richter magnitude of earthquake;
- M_s = surface-wave magnitude of earthquake;
- M_{w} = moment magnitude of earthquake;
- $m_B = \text{long period body-wave magnitude of earthquake;}$
- m_b = short period body-wave magnitude of earthquake;
- N_m = measured standard penetration resistance;
- $(N_1)_{60}$ = corrected standard penetration resistance;
- $(N_1)_{60cs} = (N_1)_{60}$ adjusted to equivalent clean-sand value;
 - n = exponent used in normalizing CPT resistance for overburden stress;
 - P_a = atmospheric pressure, approximately 100 kPa;
 - P_L = probability of liquefaction;
 - Q = normalized and dimensionless cone penetration resistance;
 - q_{cin} = normalized cone penetration resistance;
- $(q_{clN})_{cs}$ = normalized cone penetration resistance adjusted to equivalent clean-sand value;
 - r_d = stress reduction coefficient to account for flexibility in soil profile;
 - V_s = measured shear-wave velocity;
 - V_{s1} = overburden-stress corrected shear-wave velocity;
 - V_{s1}^* = limiting upper value of V_{s1} for liquefaction occurrences;
 - z = depth below ground surface (m);
 - α , β = coefficients, that are functions of fines content, used to correct $(N_1)_{60}$ to $(N_1)_{60cs}$;
 - σ'_{vo} = effective overburden pressure;
 - τ_{av} = average horizontal shear stress acting on soil layer during shaking generated by given earthquake; and
 - τ_{sr} = static shear stress acting on soil element due to gravitational forces.



ATTACHMENT 3

BORING LOCATION PLAN



A	11/10/10	EAM	TRG	RWB	ISSUED FOR REVIEW
NO.	DATE	DWN	СНКД	APPVD	DESCRIPTION

	26/26
20000	
322000_	
321500	
321000	
320500	
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE	
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN PLEOSODISS 10 doo LMS CAD FUE	
<u>NOTE:</u> COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_10.dgn LMS CAD FILE pleas1_10.dgn Cross Sections LMS CAD pleas2_10.dgn Cross Sections LMS CAD	FILE FILE
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_10.dgn LMS CAD FILE pleas1_10.dgn Cross Sections LMS CAD pleas2_10.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0	FILE FILE
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_10.dgn LMS CAD FILE pleas1_10.dgn Cross Sections LMS CAD pleas2_10.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. O BY ALLEGHENY ENERGY SUPPLY	FILE FILE
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_I0.dgn LMS CAD FILE pleasl_I0.dgn Cross Sections LMS CAD pleas2_I0.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C795033I9 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY	FILE FILE
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_I0.dgn LMS CAD FILE pleasl_I0.dgn Cross Sections LMS CAD pleas2_I0.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C795033I9 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY	FILE FILE
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_10.dgn LMS CAD FILE pleas1_10.dgn Cross Sections LMS CAD pleas2_10.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY	FILE FILE
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_10.dgn LMS CAD FILE pleas1_10.dgn Cross Sections LMS CAD pleas2_10.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING	FILE FILE RTY
 NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_I0.dgn LMS CAD FILE pleas1_I0.dgn Cross Sections LMS CAD pleas2_I0.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) 	FILE FILE RTY G.
 NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_I0.dgn LMS CAD FILE pleasI.I0.dgn Cross Sections LMS CAD pleas2_I0.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, I2, I3, & I4 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO 	FILE FILE RTY G. RING N SOILS)
 NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRCINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6.10.dgn LMS CAD FILE pleas1.10.dgn Cross Sections LMS CAD pleas2.10.dgn Cross Sections Cross Sections LMS CAD pleas2.10.dgn Cross S	FILE FILE RTY G. RING IN SOILS)
 NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6.10.dgn LMS CAD FILE pleasl.10.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO 	FILE FILE RTY G. RING IN SOILS)
 NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_I0.dgn LMS CAD FILE pleasl_I0.dgn Cross Sections LMS CAD pleas2_I0.dgn Cross Sections LMS CA	FILE FILE RTY G. RING N SOILS)
 NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. A06-964 PROPERTY PLAN Pleasants6.10.dgn LMS CAD FILE pleasl.10.dgn Cross Sections LMS CAD pleas2.10.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO 	FILE FILE RTY G. RING IN SOILS)
 NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_10.dgn LMS CAD FILE pleas1.10.dgn Cross Sections LMS CAD pleas2.10.dgn Cross Sections LMS CAD contour INTERVAL = 2' BASED ON PLAN DWG, C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO MAPP OF STAGE 2A AND STAGE NGS USED IN LIQUEFACTION ANAL ENERGY SUPPLY CO II C 	FILE FILE RTY G. RING IN SOILS)
 NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINIA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6_10.dgn LMS CAD FILE pleasl_10.dgn Cross Sections LMS CAD Dleas2_10.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (P SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO) APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO) ENERGY SUPPLY CO., LLC SANTS POWER STATION DFILL AND IMPOUNDMENT FACILITY OGRAPHIC MAP COMPOSITE 	FILE FILE RTY G. RING IN SOILS) 3 YSIS
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. A06-964 PROPERTY PLAN Pleasants6.10.dgn LMS CAD FILE pleas1.0.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO	FILE FILE C. RING IN SOILS)
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN PleasantsE.lo.dgn Cross Sections LMS CAD pleas1.10.dgn Cross Sections LMS CAD CONTOUR INTERVAL = 2' BASED ON PLAN DWG, C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPE BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BO (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO EMAP OF STAGE 2A AND STAGE NAME EMAP OF STAGE 2A AND STAGE AND STATION ANALLED AND HOUNDATION AND FOUNDATION AN	S. RTY 3 YSIS RWB D/10
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6.10.dgn LMS CAD FILE pleas.10.dgn Cross Sections LMS CAD pleas2.10.dgn Cross Sections LMS CAD STATE PLANE PLEASANT SECTION INTERVAL = 2' BASED ON PLAN DWG. C79503319 REV. 0 BY ALLEGHENY ENERGY SUPPLY INDICATES CURRENT PROPER BOUNDARY APPROXIMATE LOCATION OF PIEZOMETER (CP SERIES NUMBERS) NOTE: CP 9, II, 12, 13, & 14 - FLYASH SAMPLING APPROXIMATE LOCATION OF EXPLORATION BD (US SERIES-COMPACTED CLAY) (SP AND B SERIES-ALLUVIAL AND FOUNDATIO) EMAP OF STAGE 2A AND STAGE NAME SERIES ALLUVIAL AND FOUNDATIO ENERGY SUPPLY CO., LLC SANTS POWER STATION DIFL MAP COMPOSITE RIAL PHOTOGRAPHY 5-5-10 DRAWNRAM APPROVEDRAME STATION DIFLE AND IMPOUNDMENT FACILITY OGRAPHIC MAP COMPOSITE RIAL PHOTOGRAPHY 5-5-10 DRAWNRAM APPROVEDRAME STATION DIFLE AND IMPOUNDMENT FACILITY OGRAPHIC MAP COMPOSITE RIAL PHOTOGRAPHY 5-5-10	FILE FILE RTY G. RING N SOILS) 3 YSIS RWB D/10
NOTE: COORDINATES SHOWN ARE BASED ON THE WEST VIRGINA STATE PLANE COORDINATE SYSTEM NORTH ZONE, NAD 83. 406-964 PROPERTY PLAN Pleasants6.10.dgn Cross Sections LMS CAD pleas2.10.dgn Cross Sections LMS CAD pleas2.10.dgn Cross Sections LMS CAD STATE PLANE Pleasents6.10.dgn Cross Sections LMS CAD pleas2.10.dgn Cross Sections LMS CAD STATE PLANE	S. RING N SOILS)